



**UNIVERSITI PUTRA MALAYSIA**

**DEVELOPMENT OF A MICROWAVE INSTRUMENTATION SYSTEM  
FOR THE DETERMINATION OF MOISTURE CONTENT IN OIL PALM  
FRUITS**

**LEE KIM YEE**

**FS 2008 1**



**DEVELOPMENT OF A MICROWAVE INSTRUMENTATION SYSTEM  
FOR THE DETERMINATION OF MOISTURE CONTENT IN OIL PALM  
FRUITS**

**By**

**LEE KIM YEE**

**Thesis Submitted to the School of Graduate Studies, Universiti Putra Malaysia,  
in Fulfilment of the Requirements for the Degree of Doctor of Philosophy**

**February 2008**



**To my beloved family and friends,  
and specially for in loving memory of my mother.....**



Abstract of thesis presented to the Senate of Universiti Putra Malaysia in fulfilment of the requirement for the Degree of Doctor of Philosophy

**DEVELOPMENT OF A MICROWAVE INSTRUMENTATION SYSTEM  
FOR THE DETERMINATION OF MOISTURE CONTENT IN OIL PALM  
FRUITS**

By

**LEE KIM YEE**

**February 2008**

**Chairperson : Zulkifly Abbas, PhD**

**Faculty : Science**

This thesis describes the development of a microwave instrument for moisture content determination of oil palm fruits. The developed PC-based Six Port Reflectometer provides a simple, fast and accurate solution to the more expensive and bulky Vector Network Analyzer for monitoring the ripeness of oil palm fruit at various stages based on the moisture content measurement. The Microwave Office software (MWO) was used to design and analyzed the Six Port Reflectometer. Various coaxial sensors were simulated using FEMLAB to study the reflection coefficient of the sensor corresponding to the moisture content and ripeness stage of oil palm fruit. The developed Six Port Reflectometer operating at 2 GHz consists of a stripline ring junction, three diode detectors and an Analog to Digital converter. Two types of coaxial sensors were selected for this work: the open ended coaxial and monopole sensors. A computer software was developed using Agilent Visual Environment Engineering (VEE) graphical programming for hardware control and



implement all computation work. The performance of the developed Six Port Reflectometer in reflection coefficient measurement was tested. The empirical equations which relate the measured reflection coefficient and moisture content were found. The comparison of a batch of 200 fruit samples was done and it is found that the empirical equations is in the best agreement with the samples follow by finite element method (FEM) simulation and capacitance model. The monopole sensor phase shift measurement was found to be the best for moisture content measurement of oil palm fruits with 3.5% mean error. In bunch measurement, the apical region has the highest accuracy of moisture content measurement with 2.7% mean error followed by equatorial region, 3.0%, and basal region, 5.8%. For whole bunch moisture content measurement, the mean error was found to be 3.8%. The uncertainty of the developed Six Port Reflectometer system is calculated to be 5.5% for reflection coefficient measurement. This study shows that the Six Port Reflectometer is suitable for moisture content measurement of oil palm fruit and bunch. It is simple, fast, accurate, and a portable instrumentation system. It is suitable for early quality check of fruit and bunch ripeness.



Abstrak tesis yang dikemukakan kepada Senat Universiti Putra Malaysia  
sebagai memenuhi keperluan untuk ijazah Doktor Falsafah

**PEMBANGUNAN SISTEM INSTRUMENTASI MICROGELOMBANG  
UNTUK PENENTUAN KELENGASAN DALAM BUAH KELAPA SAWIT**

Oleh

**LEE KIM YEE**

**Februari 2008**

**Pengerusi : Zulkifly Abbas, PhD**

**Fakulti : Sains**

Tesis ini memperihalkan tentang pembangunan sistem peralatan mikrogelombang untuk menentukan kandungan kelegasan dalam buah kelapa sawit. Meter pantulan Enam Pangkalan mikrogelombang berkomputer yang menyediakan penyelesaian mudah, cepat dan tepat berbanding Penganalisis Rangkaian Vektor yang mahal dan besar untuk penentuan kematangan buah kelapa sawit berasaskan pengukuran pekali pantulan. Perisian Microwave Office (MWO) telah digunakan untuk reka-bentuk dan analisis meter pantulan Enam Pangkalan. Pelbagai peranti deria sepaksi disimulasi dengan menggunakan FEMLAB untuk mengkaji pekali pantulan dengan berpandukan kelegasan dan tahap kematangan buah kelapa sawit. Meter pantulan Enam Pangkalan yang beroperasi pada 2 GHz yang dibina ini terdiri daripada satu simpang cincin garislucutan, tiga pengesan diod, satu litar penukaran analog ke digital. Dua jenis pengesan sepaksi telah dipilih untuk kerja ini iaitu: pengesansekutub dan sepaksi hujung terbuka. Satu program komputer telah

dihasilkan dengan menggunakan perisian program bergambar Agilent VEE untuk mengawal perkakas dan menerapkan semua kerja pengiraan dalam meter pantulan Enam Pangkalan. Prestasi dari meter pantulan Enam Pangkalan yang dihasilkan telah diuji. Persamaan empirika yang menghubungkan pekali pantulan yang terukur dan kelegasan telah diperolehi. Perbandingan telah dilakukan dengan data pengukuran kumplan 200 biji buah kelapa sawit dan didapati persamaan empirika ini adalah dalam persetujuan terbaik diikuti dengan simulasi kaedah unsur terhingga (FEM) dan model kapasitan. Pengukuran anjakan fasa bagi peranti deria sekutub didapati adalah yang terbaik untuk mengukur kelegasan dalam kelapa sawit dengan purata ralat 3.5%. Dalam pengukuran tandan, bahagian pucuk mempunyai ketepatan tertinggi dengan 2.7% purata ralat diikuti dengan bahagian pertengahan, 3.0%, dan bahagian hujung, 5.8%. Bagi pengukuran kelegasan keseluruhan tandan purata ralat adalah sebanyak 3.8%. Ketidapastian sistem meter pantulan Enam Pangkalan adalah sebanyak 5.5% dalam pengukuran pekali pantulan. Ia adalah ringkas, cepat, tepat dan adalah sistem instrumentasi mudah alih. Ia sesuai untuk pemeriksaan awal kualiti kematangan buah dan tandan.

## ACKNOWLEDGEMENTS

The author would like to acknowledge Universiti Putra Malaysia in providing the laboratory facility and instrumentation along his study; University Farm Research Center for the oil palm samples supply, Applied Electromagnetic laboratory for Vector Network Analyzer usage, RF & Microwave laboratory for the fabrication and measurement.

The author extends his deepest gratitude to the chairman of the supervisory committee, Dr. Zulkifly Abbas, for his kindness supervision, invaluable guidance, unfailing help, advice and suggestions throughout the course of this study. Thanks are also for his financial support along this study as research assistant.

The author also grateful to the members of the supervisory committee, Prof. Dr. Kaida Khalid and Dr. Jumiah Hassan for their constant advice, supervision and guidance.

The author wishes to thank all the lecturers, staffs, friends, and students in Department of Physics and Faculty Science for their unreserved help and motivations.

Lastly but not least, the author would like to express his appreciation to his dedicated family members for their love, support and encouragement as well as for always being there for him.





I certify that an Examination Committee has met on 7<sup>th</sup> January 2008 to conduct the final examination of Lee Kim Yee on his Doctor of Philosophy thesis entitled “Development of a Microwave Instrumentation System for the Determination of Moisture Content in Oil Palm Fruits” in accordance with Universiti Pertanian Malaysia (Higher Degree) Act 1980 and Universiti Pertanian Malaysia (Higher Degree) Regulations 1981. The Committee recommends that the student be awarded the Doctor of Philosophy.

Members of the Examination Committee are as follows:

**W. Mahmood Mat Yunos, PhD**

Professor  
Faculty of Science  
Universiti Putra Malaysia  
(Chairman)

**Azmi Zakaria, PhD**

Associate Professor  
Faculty of Science  
Universiti Putra Malaysia  
(Internal Examiner)

**Hishamuddin Zainuddin, PhD**

Associate Professor  
Faculty of Science  
Universiti Putra Malaysia  
(Internal Examiner)

**Tharek Abd Rahman, PhD**

Professor  
Faculty of Electtical Engineering  
Universiti Teknologi Malaysia  
(External Examiner)

---

**HASANAH MOHD. GHAZALI, PhD**

Professor and Deputy Dean  
School of Graduate Studies  
Universiti Putra Malaysia.

Date: 21 February 2008



This thesis was submitted to the Senate of Universiti Putra Malaysia and has been accepted as fulfilment of the requirement for the degree of Doctor of Philosophy. The members of the Supervisory Committee were as follows:

**Zulkifly Abbas, PhD**

Lecturer

Faculty of Science

Universiti Putra Malaysia.

(Chairman)

**Kaida Khalib, PhD**

Professor

Faculty of Science

Universiti Putra Malaysia.

(Member)

**Jumiah Hassan, PhD**

Associate Professor

Faculty of Science

Universiti Putra Malaysia.

(Member)

---

**AINI IDERIS, PhD**

Professor and Dean

School of Graduate Studies

Universiti Putra Malaysia

Date: 21 February 2008



## **DECLARATION**

I declare that the thesis is my original work except for quotations and citations which have been duly acknowledged. I also declare that it has not been previously, and is not concurrently, submitted for any other degree at Universiti Putra Malaysia or at any other institution.

---

**LEE KIM YEE**

Date: 18 February 2008



## TABLE OF CONTENTS

	<b>Page</b>
<b>DEDICATION</b>	ii
<b>ABSTRACT</b>	iii
<b>ABSTRAK</b>	v
<b>ACKNOWLEDGEMENTS</b>	vii
<b>APPROVAL</b>	viii
<b>DECLARATION</b>	x
<b>LIST OF TABLES</b>	xiv
<b>LIST OF FIGURES</b>	xvi
<b>LIST OF ABBREVIATIONS</b>	xxii
<b>CHAPTER</b>	
<b>1 INTRODUCTION</b>	
1.1 Microwave Moisture Measurement in Agriculture	1.2
1.2 Oil Palm –An Overview	1.3
1.2.1 Fruits Morphology	1.4
1.2.2 Oil Palm Industry	1.6
1.2.3 The Importance of Oil Palm Fruit Ripeness	1.8
1.2.4 Conventional Technique of Assessing Fruit Ripeness	1.9
1.3 Problem Statement	1.13
1.4 PC-Based Microwave Six Port Reflectometer for Oil Palm Moisture Content Measurement	1.15
1.4.1 Microwave Circuit Design Software	1.16
1.4.2 EM Simulation of Coaxial Sensor	1.17
1.4.3 Graphical Programming	1.18
1.5 Objective	1.19
1.6 The Scope of the Thesis	1.21
<b>2 LITERATURE REVIEW</b>	
2.1 Review of Six Port Reflectometer	2.1
2.1.1 Six Port Reflectometer Hardware Configurations	2.2
2.1.2 Six Port Reflectometer Calibration Techniques	2.7
2.1.3 Calibration Standards	2.11
2.2 Development of Microwave Research for the Determination of Moisture Content in Oil Palm Fruits	2.13
2.2.1 Transmission-Reflection Technique	2.13
2.2.2 Transmission Technique	2.15
2.2.3 Reflection Technique	2.17
2.3 Modeling of Coaxial Sensor	2.20
2.3.1 Analytical Model	2.21
2.3.2 Numerical modeling	2.32



<b>3</b>	<b>THEORY OF SIX PORT REFLECTOMETER AND COAXIAL SENSORS</b>	
3.1	Six Port Reflectometer	3.1
3.1.1	Basic Concept of Six Port Reflectometer	3.1
3.1.2	Calibration Procedure of Six port Reflectometer	3.5
3.1.3	Theory of Six Port Reflectometer Hardware: Ring Junction	3.6
3.2	Microwave Coaxial sensor	3.10
3.2.1	Open-Ended Coaxial and Monopole Sensor for Oil Palm Fruits Moisture Content Determination	3.10
3.2.2	Finite Element Analysis using FEMLAB	3.12
3.2.3	Dielectric Properties of Oil Palm Fruit	3.19
<b>4</b>	<b>METHOD, DESIGN AND ANALYSIS</b>	
4.1	Design and Analysis of Six Port Reflectometer Circuit: Stripline Ring Junction	4.1
4.1.1	Stripline Design Parameters	4.2
4.1.2	Stripline Ring Junction Design and Analysis using MWO	4.5
4.1.3	Tolerance Analysis of the Stripline Ring Junction	4.16
4.2	Six Port Reflectometer Algorithm	4.17
4.2.1	Specifying Six Port Reflectometer Calibration Standard and Calculation Equation	4.17
4.2.2	MWO Simulation Result	4.22
4.3	Design and Analysis of Coaxial Sensor for Oil Palm Fruits Measurement	4.25
4.3.1	Variation of Permittivity in Oil Palm Fruits	4.26
4.3.2	Prediction of Reflection Coefficient of Oil Palm Fruits Using FEMLAB	4.34
4.3.3	Tolerance Analysis	4.51
4.4	Prediction of Oil Palm Fruits Reflection Coefficient Measured By Six Port Reflectometer with Coaxial Sensor	4.52
<b>5</b>	<b>MEASUREMENT AND EXPERIMENTAL SETUP</b>	
5.1	Measurement Setup of Six Port Reflectometer	5.1
5.2	Development of Six Port Reflectometer	5.6
5.2.1	Circuit Layout, Fabrication and Specification Testing of Stripline Ring Junction	5.8
5.2.2	The Six Port Reflectometer Software Development Using Agilent VEE	5.17
5.3	Sample Preparation and Moisture Content Calculation	5.34
<b>6</b>	<b>RESULTS AND DISCUSSIONS</b>	
6.1	Performance Testing of Six Port Reflectometer	6.2
6.1.1	Effect of Frequency and Input Power on Reflection Coefficient Measurement	6.2
6.1.2	Comparison with Vector Network Analyzer	6.6
6.2	Oil Palm Fruit Moisture Content Measurement	6.8
6.2.1	Empirical relationship between Measured Reflection Coefficient and Moisture Content	6.8

6.2.2	Comparison between Measured and Calculated Reflection Coefficient	6.12
6.2.3	Verification	6.20
6.3	Oil Palm Bunch Moisture Content Prediction	6.24
6.3.1	Bunch Regional Moisture Content Prediction	6.24
6.3.2	Verification of Oil Palm Bunch Moisture Content Prediction	6.27
6.4	Uncertainty Analysis of the Six Port Reflectometer System	6.29
6.4.1	Uncertainty in Reflection Coefficient Measurement	6.29
6.4.2	Effect of Instrumentation Uncertainty in Moisture Content Measurement of Oil Palm Fruit and Bunch	6.47
6.5	Conclusion	6.49
<b>7</b>	<b>CONCLUSION AND SUGGESTION</b>	
7.1	Conclusion	7.1
7.2	Main Contributions	7.2
7.3	Recommendations for Further Work	7.3
7.3.1	Broadband Six Port Reflectometer	7.3
7.3.2	A Complete Integrated Reflectometer	7.4
7.3.3	Others Agriculture Use	7.4
7.3.4	Dual Six Port Reflectometer Technique	7.4
	<b>REFERENCES</b>	<b>R.1</b>
	<b>BIODATA OF STUDENT</b>	<b>B.1</b>



## LIST OF TABLES

<b>Table</b>		<b>Page</b>
1.1	Various proposal of oil palm ripeness based on the detached fruits. (Arrifin, 2005)	1.10
3.1	Parameters of improving model of oil palm permittivity (You, 2006)	3.21
4.1	S parameter of 50Ω stripline with various length simulated using MWO	4.4
4.2	S parameters of ring junction at 2 GHz after the optimization improvement	4.15
4.3	Comparison between simulation and theoretical ring junction S parameters at 2 GHz	4.16
4.4	Error analysis of ring junction with stripline width tolerance	4.17
4.5	S parameters of four virtual calibration standards using MWO	4.23
4.6	Unknown constant of design ring junction in MWO	4.23
4.7	Sensitivity of dielectric constant to moisture content	4.29
4.8	Sensitivity of loss factor to moisture content	4.31
4.9	several 50 Ω coaxial cable	4.34
4.10	Sensitivity of b=1.50 mm monopole sensor with different protruding inner conductor, P.	4.50
4.11	Simulated Six Port Reflectometer with sensors sensitivity	4.55
5.1	Calibration standards characteristic	5.4
5.2	Stripline ring junction S parameters at 2 GHz	5.17
5.3	Functions of <code>adc16_set_channel</code>	5.22
5.4	Function of <code>adc16_get_value</code>	5.24
6.1	Error in magnitude and phase for reflection coefficient measurement	6.4
6.2	Error of magnitude and phase under variation power	6.6
6.3	Reflection coefficient measurement comparison between VNA and Reflectometer	6.6



6.4	Reflection coefficient measurement of liquids using open ended coaxial	6.7
6.5	Reflection coefficient measurement of liquids using monopole	6.8
6.6	Contributions from the calibration procedure	6.41
6.7	Contributions from the reflection calculation	6.46
6.8	Error of Fruit moisture content	6.48
6.9	Error of bunch moisture content	6.49





## LIST OF FIGURES

Figure		Page
1.1	The morphology of a single oil palm fruit	1.4
1.2	The oil palm fruit categories (Hartley, 1977)	1.5
1.3	A tenera bunch halved to show (1) the stalk plus (2) spikelets and fruits, comprising (3) the mesocarp, (4) the shell and (5) the kernel	1.6
1.4	Average composition of tenera fruit bunch (Jacobsberg, 1974)	1.6
1.5	Variation in moisture content, <i>m.c</i> and oil content with weeks after anthesis (Abbas, 1994)	1.12
1.6	Correlation of the water content to oil content in mesocarp (Hartley, 1977)	1.12
2.1	Positions for the Six Port Reflectometer circle centers	2.3
2.2	A typical Six Port Reflectometer circuit (Engen, 1971).	2.3
2.3	An alternative Six Port Reflectometer circuit (Engen, 1977).	2.4
2.4	Three-conductor coaxial line directional coupler configuration Six Port Reflectometer.	2.4
2.5	The multistate reflectometer is a variant of the six-port.	2.5
2.6	Six Port Reflectometer circuit based on the use of a symmetric ring junction and directional coupler.	2.6
2.7	Suggested ring junction circuitry in the work.	2.6
2.8	Sliding short calibration	2.12
2.9	Fixed standard calibration	2.12
2.10	Boundary condition for oil palm fruits moisture content determination using a Transmission-reflection method.	2.14
2.11	Transmission techniques measurement	2.15
2.12	Attenuation sensors for oil palm ripeness determination	2.17
2.13	Oil palm fruit moisture measurement using open-ended coaxial.	2.19

2.14	Equivalent circuits for reflections method. (a) General equivalent circuit and (b) simplified equivalent circuit	2.22
2.15	Open-ended reflection method. (a) Coaxial probe terminated by a semi-infinite sample and (b) capacitive equivalent circuit at plane A-A'	2.22
2.16	Equivalent circuit for antenna model	2.24
2.17	Virtual line model	2.26
2.18	Rational function model	2.28
2.19	Short antennas used for materials property characterization. (a) Short coaxial monopole antenna and (b) very short coaxial monopole antenna	2.31
2.20	FEM mesh of open-ended coaxial region (Gajda <i>et al.</i> , 1983)	2.34
2.21	Interface between different dielectric media in MoM (Gajda <i>et al.</i> , 1983)	2.37
2.22	FD-TD mesh and the graphical solution of open-ended coaxial line with an extended center conductor (Maloney <i>et al.</i> , 1990)	2.39
3.1	Incident and reflected waves on a transmission line	3.3
3.2	General Six Port Reflectometer diagram	3.3
3.3	Symbol of Six Port Reflectometer	3.3
3.4	Optimum location of $q_1$ , $q_2$ and $q_3$ for a Six Port Reflectometer. (Engen, 1973)	3.4
3.5	Locus of $\Gamma$ in the complex plane	3.6
3.6	Wave distribution of ring junction	3.8
3.7	Two types of coaxial line with baffle	3.11
3.8	The electromagnetic field of coaxial line	3.11
3.9	Open-circuited reflection technique interface	3.12
3.10	Excitation boundary of symmetric region of coaxial line	3.17
4.1	Stripline configuration	4.2

4.2	Simulated 50 $\Omega$ stripline for variation substrates and RTDurioid substrates. (Lee, 2004)	4.3
4.3	Configuration of complete ring junction circuit	4.6
4.4	Detail of ring junction circuit in MWO workspace	4.6
4.5	Ring junction S parameter of MWO simulation with trail value w1, w2, r1.	4.11
4.6	Variable section in MWO	4.12
4.7	Detail of random function in MWO	4.13
4.8	Ring junction optimization result	4.13
4.9	S parameter of the design ring junction after optimization	4.15
4.10	q points and radius of design ring junction in complex plane	4.24
4.11	Ring junction outputs of various positions in virtual sliding short simulated using MWO	4.24
4.12	Calculated reflection coefficient in complex plane	4.25
4.13	Flow chart of oil palm fruits reflection coefficient prediction	4.26
4.14	Syntax command in MATLAB Script to calculate the permittivity of variation oil palm fruit.	4.27
4.15	Dielectric Constant of the oil palm fruit as a function of frequency and moisture content	4.28
4.16	Dielectric Constant of the oil palm fruit under variation moisture content.	4.28
4.16	Loss factor of the oil palm fruit as a function of frequency and moisture content	4.30
4.18	Loss Factor of the oil palm fruit under variation moisture content.	4.31
4.19	Relative error $\Delta\epsilon'/\epsilon'$ of various moisture content	4.33
4.20	Relative error $\Delta\epsilon''/\epsilon''$ of various moisture content	4.34
4.21	Flow chart of FEM simulation procedure	4.35
4.22	FEMLAB simulation reflection coefficient magnitude of various coaxial cables	4.44



4.23	FEMLAB simulation reflection coefficient phase of several coaxial cables	4.45
4.24	Predicted reflection coefficient magnitude with moisture content for open ended coaxial sensor	4.46
4.25	Predicted reflection coefficient phase with moisture content for open ended coaxial sensor	4.47
4.26	Comparison of $b=1.50\text{mm}$ monopole sensor with different protruding inner conductor, P.	4.49
4.27	Tolerance of magnitude	4.51
4.28	Tolerance of phase	4.51
4.29	Flow chart of reflection coefficient calculation procedure	4.53
4.30	Load impedance of various moisture content in oil palm fruit	4.54
4.31	Predicted reflection coefficient for variation of moisture content	4.55
5.1	The measurement setup of the Six Port Reflectometer	5.2
5.2	Six Port Reflectometer components	5.3
5.3	Flow chart of Six Port Reflectometer development procedure	5.8
5.4	Layout cells of ring junction circuit in MWO	5.9
5.6	Flow chart of ring junction fabrication procedure	5.10
5.7	Example of ring junction circuit transparence mask	5.11
5.9	A box was used to protect the substrate from light and dust	5.12
5.10	RS 555-279 UV exposure unit	5.13
5.11	Ring junction circuit after the etching and removal of photoresist process	5.14
5.12	Structures of ring junction before packaging	5.15
5.13	Fabricated stripline ring junction	5.15
5.14	Measured S parameters of stripline ring junction	5.16
5.15	Panel view of Six Port Reflectometer software	5.18
5.16	Program detail for acquire voltages from PICO ADC-16 circuit	5.20

5.17	The open view of Import Library compiled functions	5.21
5.18	The open view of <i>Call adc16.adc16_open_unit</i>	5.21
5.19	The open view of <i>Call adc16.adc16_set_channel</i>	5.22
5.20	Open view of <i>Call ade16.adc16_get_value</i>	5.23
5.21	The open view of <i>ADC_TO_VOLTS and Formula</i>	5.24
5.22	The objects in <i>Selection Control</i> programming	5.25
5.23	<i>Cal Standard</i> object	5.25
5.24	<i>Case</i> object	5.26
5.25	<i>Color Alarm</i> object	5.27
5.26	The open view of To File object	5.28
5.27	The open view of <i>Call adc16.adc16_close_unit</i>	5.28
5.28	Program detail of <i>calibration</i> module	5.30
5.29	The open view of Form File object	5.31
5.30	The open view of MATLAB Scrip Calibration	5.32
5.31	Part of program detail of <i>Measurement</i> module	5.33
5.32	The open view of MATLAB Script Six Port Reflectometer Equation	5.34
5.33	Contact of coaxial sensor and oil palm fruit during measurement	5.36
6.1	Measured reflection coefficient of HP8505B calibration standard for frequencies between 1.8 -2.2 GHz using Six Port Reflectometer	6.3
6.2	Measured reflection coefficient under variation power	6.5
6.3	Measurement data and empirical fitting of open ended coaxial sensor	6.9
6.4	Measurement data and empirical fitting of monopole sensor	6.11
6.5	Comparison of measurement data and simulation results of open ended coaxial sensor.	6.14
6.6	Error between measured and predicted value	6.16
6.7	Comparison of measurement and simulation data of monopole sensor	6.17

6.8	Error in open ended coaxial sensor measurement	6.20
6.9	Predicted moisture content obtained from empirical equation and Standard Oven Drying moisture content for Open Ended Coaxial	6.22
6.10	Predicted moisture content obtained from empirical equation and Standard Oven drying moisture content for monopole	6.23
6.11	The region division of the oil palm bunch	6.24
6.12	Predicted moisture content and moisture content measured using standard oven drying of various oil palm bunches	6.25
6.13	Relative error of predicted moisture content	6.26
6.14	Relationship between bunch moisture content to region moisture content	6.27
6.15	Comparison between the moisture content obtained using different method for weeks after anthesis	6.28
6.16	Calibration Standards Measurement	6.30
6.17	Uncertainty of the Six Port Reflectometer calibration procedure	6.32
6.18	Uncertainly of the Six Port Reflection coefficient measurement	6.43
6.19	Flow chart of error of oil palm fruit moisture content measurement	6.47
6.20	Flow chart of error of oil palm bunch moisture content measurement	6.48



## LIST OF ABBREVIATIONS

$\epsilon$	permittivity
$\epsilon^*$	complex permittivity
$\epsilon_r^*, \epsilon_r$	relative complex permittivity
$\epsilon_0$	permittivity of vacuum (F/m)
$\epsilon'$	real part of permittivity or dielectric constant
$\epsilon''$	imaginary part of permittivity or loss factor
$\epsilon_\infty$	optical permittivity
$\epsilon_s$	static permittivity
$\epsilon_c$	relative permittivity of coaxial line (PTFE)
$\epsilon_w^*$	complex permittivity of water
$\epsilon_f^*$	complex permittivity of fiber
$\epsilon_o^*$	complex permittivity of oil
$\epsilon_r$	Substrate permittivity
$j$	square root of -1
$\mu_0$	free space permeability (H/m)
$\mu$	permeability (H/m)
$\sigma$	conductivity (S/m)
$\gamma$	propagation constant ( $m^{-1}$ )
$t$	time (s)
$T$	temperature ( $^{\circ}C$ )

$\omega$	angular frequency (rad/s)
$\tau$	relaxation time (s)
$\tau_o$	proportionality factor of Arrhenius equation (s)
$\tan \delta$	loss tangent
$v_w$	volume fraction of water
$v_f$	volume fraction of fiber
$v_o$	volume fraction of oil
$\rho_w$	relative density of water
$\rho_f$	relative density of fiber
$\rho$	radius coordinate of point at aperture probe
$\rho_o$	relative density of oil
$\eta$	intrinsic impedance of medium
$\vec{H}$	magnetic field / magnetic intensity (A/m)
$H_\phi$	Azimuthal component of magnetic field for coaxial line
$f$	frequency
$\lambda$	wavelength
$\Gamma$ or S11	reflection coefficient
$ \Gamma $ or $ S11 $	magnitude reflection coefficient
$\Gamma_{AA'}$	measured reflection coefficient at the plane AA'
$\phi$	angle coordinate of point at aperture probe (rad)
$a$	inner radius of coaxial probe (m)



$b$	outer radius of coaxial probe (m)
$\frac{B(0)}{Y_0}$	normalized susceptance
$B$	susceptance (S)
$c$	velocity of light
$C_o, C$	static value of the fringe-field capacitance (F)
$C_f$	fringe-field capacitance of coaxial line (F)
$C_T$	total fringe-field capacitance of coaxial line (F)
$D$	physical length of the probe (m)
$G$	conductance (S)
$\frac{G(0)}{Y_0}$	normalized conductance
$m_w$	mass of water
$m_f$	mass of fiber
$m_o$	mass of oil
$mc$	moisture content
$oc$	oil content
$P$	protruding inner conductor
$U$	uncertainty
$Y$	aperture admittance
$Y_0$	characteristic admittance of coaxial line
$\tilde{Y}$	normalized admittance
$z$	distance from the center point of aperture probe (m)