



UNIVERSITI PUTRA MALAYSIA

**BIOLOGICAL NUTRIENT REMOVAL OF DOMESTIC SEWAGE
USING COMBINED ANAEROBIC-ANOXIC-AEROBIC REACTOR**

MAHERAN BT ISMAIL

FK 2001 12

**BIOLOGICAL NUTRIENT REMOVAL OF DOMESTIC SEWAGE USING
COMBINED ANAEROBIC-ANOXIC-AEROBIC REACTOR**

**By
MAHERAN BT ISMAIL**

**Thesis Submitted in Fullfilment of the Requirements for the
Degree of Master of Science in the Faculty of Engineering
Universiti Putra Malaysia
July 2001**



Specially dedicated to,

My husband, Zul, son Fikri and family,

Thanks for your prayers and encouragement.

Abstract of thesis submitted to the Senate of Universiti Putra Malaysia in fulfilment
of the requirement for the degree of Master of Science

**BIOLOGICAL NUTRIENT REMOVAL OF DOMESTIC SEWAGE USING
COMBINED ANAEROBIC-ANOXIC-AEROBIC REACTOR**

By

MAHERAN BT ISMAIL

July 2001

Chairman: Assoc. Prof Dr. Azni Idris

Faculty: Engineering

The overall objectives of this study is to develop an innovative technology to treat nutrients especially nitrogen and phosphorus in domestic wastewater. This process is called the Anaerobic-anoxic-aerobic (AAA). Biological nitrification-denitrification and phosphorus removal in a single reactor have been shown applicable to treat nutrients with some modification in an aerobic zone, where 'cosmo-ball' media were introduced to enhance bacterial growth.

The vertical reactor with 'up flow' influent was operated using a continuous system with an anaerobic-anoxic-aerobic zone sequence. This experiment was operated at HRT total of 7 hours where the anaerobic, anoxic and aerobic zone takes 1.5, 1.5 and 4 hours respectively. The experimental run was conducted in the Environmental laboratory using raw samples from an Extended Aeration treatment plant at Serdang Raya, Sri Kembangan, Selangor.



The results showed that nitrification-denitrification process could be achieved using this anaerobic-anoxic-aerobic (AAA) reactor with 63% $\text{NH}_4\text{-N}$ removal and 51% PO_4 removal. Removal of BOD, COD, TSS, VSS were 84%, 78%, 85% and 83% respectively. The results obtained also shows that organic and pH has significance effects on nutrient removal for a medium strength wastewater. The treatment of sewage effluent was also carried out in anaerobic-anoxic-aerobic reactor to study the kinetics parameters for nitrification and denitrification processes and the results obtained were: $Y_N = 0.041 \text{ mg VSS/mg NH}_4$, $K_d = 0.0417 \text{ day}^{-1}$, $\mu_m = 1.6470 \text{ day}^{-1}$, $K_N = 0.8996 \text{ mg/l}$ (kinetic parameter for denitrification). Meanwhile parameters kinetic for denitrification were: $Y_D = 0.017 \text{ mg VSS/mg NO}_3$, $K_{d1} = 0.0014 \text{ day}^{-1}$, $\mu_{m1} = 0.00407 \text{ day}^{-1}$, $K_D = 8.036 \text{ mg/l}$. It has been found that the reactor was succeeded in removing nutrients from sewage samples.



Abstrak tesis ini dikemukakan kepada Senat Universiti Putra Malaysia sebagai memenuhi keperluan untuk memperolehi ijazah Master Sains

**PENYINGKIRAN NUTRIEN SECARA BIOLOGI BAGI SISA KUMBAHAN
MENGUNAKAN SATU REAKTOR ANEROBIK-ANOXIK-AEROBIK**

Oleh

MAHERAN BT ISMAIL

Julai 2001

Pengerusi: Prof. Madya Dr. Azni Idris

Fakulti: Kejuruteraan

Secara keseluruhannya kajian ini adalah untuk menghasilkan teknologi yang inovatif bagi merawat nutrien terutamanya nitrogen and fosforus dari air kumbahan. Proses ini dikenali sebagai Penyingkiran Nutrien Secara Biologi (Anerobik-anosik-aerobik). Proses nitrifikasi-denitrifikasi secara biologi dan proses penyingkiran fosforus menggunakan satu reaktor tegak menunjukkan kebolehpayaan untuk merawat nutrien iaitu dengan modifikasi di dalam aerobik zon. Bebola cosmo dimasukkan kedalam zon ini untuk menggalakkan pertumbuhan bakteria.

Influen dengan secara 'aliran atas' yang berterusan digunakan bagi reactor iaitu dengan turutan zon-zon anerobik-anoxik-aerobik. Ujikaji ini, secara keseluruhannya beroperasi selama 7 jam dimana anerobik zone diperuntukkan selama 1.5 jam, anoxik zone selama 1.5 jam dan aerobik zone selama 4 jam. Ujikaji ini dijalankan di Makmal Alam Sekitar menggunakan sampel kumbahan dari Loji 'Extended Aeration' di Serdang Raya, Sri Kembangan, Selangor.

Keputusan yang diperolehi dari ujikaji ini menunjukkan proses nitrifikasi-denitrifikasi boleh dicapai menggunakan reactor anerobik-anoxic-aerobic dengan 63% penyingkiran ammonia dan 51% penyingkiran fosforus. Penyingkiran BOD, COD, TSS dan VSS masing-masing adalah 84%, 78%, 85% dan 83%. Keputusan yang didapati juga menunjukkan bahan organik, DO dan pH memberi kesan terhadap penyingkiran nutrien bagi kekuatan kumbahan yang sederhana. Rawatan air sisa kumbahan juga dijalankan untuk menentukan kinetic parameter bagi proses nitrifikasi dan juga proses denitrifikasi dan keputusan yang diperolehi adalah: $Y_N = 0.041$ mg VSS/mg NH_4 , $K_d = 0.0417$ hari⁻¹, $\mu_m = 1.6470$ hari⁻¹, $K_N = 0.8996$ mg/l (parameter kinetik untuk nitrifikasi). Sementara itu parameter kinetik untuk proses denitrifikasi adalah: $Y_D = 0.017$ mg VSS/mg NO_3 , $K_{d1} = 0.0014$ hari⁻¹, $\mu_{m1} = 0.00407$ hari⁻¹, $K_D = 8.036$ mg/l. Reactor anerobik-anoxic-aerobik dalam kajian ini didapati dapat merawat nutrien di dalam air sisa kumbahan.

ACKNOWLEDGEMENTS

All praise to the Almighty Allah, the most merciful and the most gracious.
Peace and blessings to Prophet Muhammad S.A.W.

First and foremost, I would like to express my heartfelt gratitude and appreciation towards my respected supervisor, Associate Professor Dr. Azni Idris, for his rendered advice, invaluable guidance and encouragement throughout the course of this project.

An indebted thank you also goes to Dr. Fakhrul Razi Ahmadun and Associate Professor Dr Sa'ari Mustapha as members of supervisory committee for this project, for their support and advice in enabling me to complete this study project successfully.

Not forgetting, also appreciation for all persons whose directly or indirectly involved in my project and especially to lab assistant from Department of Chemical and Environmental Engineering for their kind cooperation and helping. Finally, I also forward my sincere appreciations to all my fellow course mates and friends who have helped me in my project progress.



I certify that an Examination Committee has met on 19 th July 2001 to conduct the final examination of Maheran .bt Ismail on her Master of Science thesis entitled “Biological Nutrient Removal of Domestic Sewage Using Anaerobic-Anoxic-Aerobic Reactor” in accordance with Universiti Pertanian Malaysia (Higher Degree) Act 1980 and Universiti Pertanian Malaysia (Higher Degree) Regulation 1981. The Committee recommends that the candidate be awarded the relevant degree. Members of the Examination Committee are as follows:

ABDUL GHANI LIEW ABDULLAH
Lecturer
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

AZNI HAJI IDRIS, Ph.D.
Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

FAKHRU’L-RAZI AHMADUN, Ph.D.
Head Department of Chemical and Environmental Engineering
Faculty of Engineering
Universiti Putra Malaysia
(Member)

SA’ARI MUSTAPHA, Ph.D.
Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)


MOHD. GHAZALI MOHAYIDIN, Ph.D.
Professor/Deputy Dean of Graduate School
Universiti Putra Malaysia

Date: 11 SEP 2001

This thesis submitted to the Senate of Universiti Putra Malaysia and has been accepted as fulfilment of the requirement for the degree of Master of Science.




AINI IDERIS, Ph.D.
Professor/Dean of Graduate School
Universiti Putra Malaysia

Date: **13** DEC 2001

DECLARATION

I hereby declare that the thesis is based on my original work except for quotations and citations, which have been duly acknowledged. I also declare that it has not been previously or concurrently submitted for any other degree at UPM or other institutions.



Maheran bt Ismail
Date: 12 Sept 2001

TABLE OF CONTENTS

	Page
ABSTRACT	iii
ABSTRAK	v
ACKNOWLEDGEMENTS	vii
APPROVAL	viii
DECLARATION	x
LIST OF TABLES	xiv
LIST OF FIGURES	xvi
LIST OF PLATES	xix
LIST OF ABBREVIATIONS	xx
 CHAPTER	
I INTRODUCTION	1
Background.....	1
Objective.....	3
Scope of Study.....	4
Significance of the Study.....	6
 II LITERATURE REVIEW	 7
Introduction.....	7
Wastewater Treatment and Nutrient Issues.....	9
Environmental Limit on Nitrogen and Phosphorus.....	11
The Adverse Impacts of Excessive Nutrients Discharge into Waterbody.....	13
Nitrogen.....	16
Sources of Nitrogen.....	16
Form of Nitrogen.....	16
Nitrogen Pathways in Environment.....	17
Phosphorus.....	20
Sources of Phosphorus.....	20
Form of Phosphorus.....	21
Phosphorus Pathways in Environment.....	22
Treatment Process for The Removal of Nitrogen.....	24
Biological unit processes for the removal of nitrogen.....	27
Biological Nitrification and Denitrification.....	27
Classification of Nitrification and Denitrification Process Unit.....	29
Process Chemistry and Biochemistry of Nitrification... Nitrification.....	31
Kinetics of Nitrification.....	33
Environmental Factors Affecting Nitrification.....	35
Process Chemistry and Biochemistry of Denitrification.....	38
Denitrification	38
Kinetics of Denitrification.....	40
Environmental Factor Affecting Denitrification.....	41



Combined Nitrification-Denitrification.....	44
Treatment Process for The Removal of Phosphorus.....	45
Biological Phosphorus Removal.....	47
A/O Process.....	50
Phostrip Process.....	51
Sequencing Batch Reactor.....	51
Combined Removal of Nitrogen and Phosphorus.....	56
Capabilities of BNR System.....	57
AAO Process.....	58
Modified Bardenpho Process.....	60
UCT Process.....	62
VIP Process.....	63
SBR Process.....	64
Phostrip Process.....	65
Orbal Process.....	65
Anoxic/Anaerobic/Aerobic Process.....	67
III MATERIALS AND METHODS.....	68
Experimental Rig Description.....	68
Storage Tank.....	68
Anaerobic-Anoxic-Aerobic Reactor.....	69
Recycling Pump.....	71
Peristalsic Pump.....	71
Air Pump.....	72
Samples.....	72
Methodology and Experimental Procedures.....	73
Experimental Procedure.....	74
Laboratory Analysis.....	75
Dissolved Oxygen.....	75
pH.....	76
BOD ₅	76
COD.....	76
Solids.....	77
Nitrogen.....	77
Phosphorus.....	78
IV RESULTS AND DISCUSSIONS.....	86
General.....	86
Variation in Water Quality of All Phases.....	88
Removal of Nitrogen.....	90
Nitrification.....	90
Influence of Organics Changes on Nitrification.....	97
Influence of DO and pH Changes on Nitrification.....	100
Mass Balance of Nitrification.....	105
Kinetic of Nitrification.....	108
Biomass Balance.....	108
Substrate Balance.....	111
Determination of Kinetic Data.....	112
Denitrification.....	117



	Influence of Organics Changes on Denitrification Process.....	121
	Influence of DO and pH Changes on Denitrification.....	122
	Mass Balance for Denitrification.....	126
	Kinetic of Denitrification.....	127
	Removal of Phosphorus.....	131
	Influence of Organic Changes on Phosphorus Removal...	133
	Influence of Nitrate, Oxygen and pH on Phosphorus Removal.....	139
	Mass Balance of Phosphorus.....	143
	Organic Removal.....	145
	Effect of Organic Loading on the Effluent Quality.....	150
	Solids Removal.....	147
	Problem Encountered.....	157
V	CONCLUSIONS AND RECOMMENDATIONS.....	158
	Conclusions.....	158
	Recommendations.....	160
	REFERENCES.....	162
	APPENDICES.....	169
	Appendix A Raw Experimental Data.....	169
	Appendix B Performance (Removal) Data.....	187
	Appendix C Environmental Quality (Sewage and Industrial) Regulations 1979.....	199
	Appendix D Interim Water Quality Standard for Malaysia.....	200
	Appendix E WHO Standard for Drinking Water (Inorganic Constituents of Health Significant).....	205
	Appendix F U.S.EPA Primary Drinking Water Standards.....	206
	Appendix G Aeration Calculation for Required Amount of Oxygen.....	207
	Appendix H Mass Balance Calculation.....	209
	Appendix I Kinetic Data.....	210
	Appendix J Determination of Kinetic Data	214
	BIODATA OF AUTHOR.....	218



LIST OF TABLES

Table	Page
2.1 Typical Composition of Untreated Domestic Wastewater.....	9
2.2 Effect of Various Treatment Operation and Processes on Nitrogen Compounds.....	26
2.3 Classification of Different Combined Nitrification/Denitrification and Separate Stage Nitrification or Denitrification Unit.....	31
2.4 Shows The Summarizing of The Kinetic Constants For Nitrifying Bacteria.....	35
2.5 Combined Nitrification-Denitrification Process.....	45
2.6 Effect of Various Treatment Operations and Processes on Phosphorus Removal.....	47
2.7 Advantages and Disadvantages of Biological Phosphorus Removal Processes.....	55
2.8 Typical Design Information for Biological Phosphorus Removal Processes.....	56
2.9 Process Design Parameters for Biological Nutrient Removal Systems.....	57
3.1 Summary of BNR Biofil System Specification.....	60
3.2 Technical Configuration of Reactor.....	70
3.3 Technical Specification of Media.....	71
4.1 TKN Data for Serdang Raya Sewage Samples.....	98
4.2 Influence of DO Reported from Previous Study.....	100
4.3 Flowrate and Mass for Ammoniacal Nitrogen.....	106
4.4 Comparison Kinetic Parameter With Previous Study.....	114
4.5 Influence of DO on Denitrification Reported from Previous Study.....	123



4.6	Flowrate and Mass for Nitrate Nitrogen.....	127
4.7	Comparison Kinetic Parameter with Previous Study.....	128
4.8	TP Data for Serdang Raya Sewage Samples.....	134
4.9	Flowrate and Mass for Phosphate.....	144



LIST OF FIGURES

Figure		Page
2.1	Generalised Nitrogen Cycle.....	19
2.2	Phosphorus Cycle.....	23
2.3	Defination Sketch for The Transformation of Various Forms of Nitrogen in Biological Treatment Processes..	29
2.4	Alternative biological phosphorus removal systems.....	53
2.5	The AAO Process.....	59
2.6	Bardenpho Process.....	61
2.7	UCT Process.....	62
2.8	VIP Process.....	63
2.9	Sequencing Batch Reactor	64
2.10	Orbal Process.....	66
2.11	Anoxic/Anaerobic/Aerobic System.....	67
3.1	Schematic Diagram of Anaerobic-Anoxic-Aerobic Reactor	79
3.2	Front View of a Reactor.....	80
3.3	Plan View of a Reactor	81
3.4	Normal Exertion of Oxygen Demand for Carbonaceous and Nitrogenous Oxygen Demand in a Waste Sample....	82
4.1	Profile of Biodegradable Organic Matter, Ammoniacal Nitrogen, Phosphate and Nitrate in a Three Stage BNR System for Serdang Raya Treatment Plant.....	89
4.2	Ammoniacal Nitrogen Concentration versus Time.....	92
4.3	Ammoniacal Nitrogen Removal versus Time.....	92



4.4	Nitrate Concentration versus Time.....	94
4.5	Nitrate Conversion (%) versus Time.....	95
4.6	Nitrification Rate After Start-Up of The Anaerobic- Anoxic-Aerobic Reactor.....	96
4.7	Nitrification Rate versus Ammoniacal Nitrogen Effluent.....	96
4.8	The Relation of BOD/NH ₄ ratio and NH ₄ Removal....	99
4.9	The Relation of COD/NH ₄ ratio and NH ₄ Removal....	99
4.10	Variation of DO for Every Zone.....	101
4.11	Influence of DO on Nitrification.....	101
4.12	Variation of pH for Every Zone.....	103
4.13	Influence of pH on Nitrification.....	104
4.14	Flow Chart Showing Mass Balance of Ammoniacal Nitrogen.....	106
4.15	Graph $Qc / 1 + Qc(Kd)$ versus $1/N$	115
4.16	Graph $Q(N_0 - N)XV$ versus $1/Qc$	116
4.17	Denitrification Rate versus Time.....	120
4.18	The Relation of COD/NO ₃ and Denitrification Rate...	121
4.19	Influence of DO on Denitrification.....	123
4.20	Influence of pH on Denitrification.....	125
4.21	Flow Chart for Mass Balance of Nitrate Nitrogen.....	126
4.22	Graph $Qc / 1 + Qc(Kd_1)$ versus $1/D$	129
4.23	Graph $Q(D_0 - D)$ versus $1/Qc$	130
4.22	Phosphate Concentration versus Time.....	132
4.23	Phosphate Removal versus Time.....	132
4.24	The Relation Between BOD/PO ₄ and Phosphorus Removal	134
4.25	The Relation Between COD/PO ₄ and Phosphate Removal.	136



4.26	Schematic of Biological Phosphorus Removal Mechanism	138
4.27	Relation Between DO and Phosphate Removal.....	141
4.28	Relation Between pH and Phosphate Removal.....	142
4.29	Flow Chart for Mass Balance of Phosphate	143
4.30	BOD Concentration versus Time.....	145
4.31	COD Concentration versus Time.....	146
4.32	BOD Removal versus Time.....	147
4.33	COD Removal versus Time.....	147
4.34	BOD Removal versus BOD/COD ratio.....	149
4.35	Percentage BOD Removal versus Organic Loading Rate... 150	
4.36	Percentage COD Removal versus Organic Loading Rate.... 151	
4.37	BOD Removed versus BOD Added.....	152
4.38	COD Removed versus COD Added.....	152
4.39	TSS Concentration Against Days.....	153
4.40	TSS Removal Against Days.....	154
4.41	VSS Concentration Against Days.....	154
4.42	VSS Removal Against Days.....	155



LIST OF PLATES

Plate		Page
3.1	Reactor placed at the Environmental Lab, UPM.....	83
3.2	Reactor Cover With Aluminium Foil to Avoid from Direct Sunlight.....	83
3.2	Storage Tank for Influent.....	84
3.4	Cosmo Ball Media Attached with Microorganism....	84
3.5	Raw Effluent from Extended Aeration Treatment Plant and Effluent Quality after Treated Using Anaerobic-Anoxic-Aerobic Reactor.....	85
4.1	Solids Accumulation on the Surface of the Reactor.....	156



LIST OF ABBREVIATIONS

AAO	-	Anaerobic-Anoxic-Oxic
AO	-	Anaerobic-Oxic
Anoxic	-	Partial oxygen condition
BOD ₅	-	Biological Oxygen Demand (after 5 days incubation of samples at 20°C in the dark)
BOD/N	-	Biochemical Oxygen Demand to Nitrogen ratio
BOD/P	-	Biochemical Oxygen Demand to Phosphorus ratio
BNR	-	Biological Nutrient Removal
BPR	-	Biological Phosphorus Removal
COD	-	Chemical Oxygen Demand (after 2 hours digest in acid medium)
COD/N	-	Chemical Oxygen Demand to Nitrogen Ratio
COD/P	-	Chemical Oxygen Demand to Phosphorus ratio
C/N	-	Carbon to Nitrogen ratio
DO	-	Dissolved Oxygen
F/M	-	Food to microorganism ratio
HRT	-	Hydraulic Retention Time
MLVSS	-	Mixed Liquor Volatile Suspended Solid
NH ₄ -N	-	Ammoniacal Nitrogen
NO ₃ -N	-	Nitrate
Oxic	-	Aerobic condition
PO ₄ -P	-	Phosphate
Q ₀	-	Influent flowrate for BNR reactor
Q _r	-	Recycle flowrate



SBR	-	Sequencing Batch Reactor
TKN	-	Total Kjeldahl Nitrogen
TSS	-	Total Suspended Solid
UCT	-	University of Cape Town
U.S.EPA	-	United State Environmental Protection Agency
VIP	-	Virginia Institute Plant
VSS	-	Volatile Suspended Solid



CHAPTER I

INTRODUCTION

Background

Recently, it has been identified that domestic effluent is one of the major sources of nutrient pollution in Malaysia (Saharuddin, 1996). Nutrient is one of the contaminant that causes pollutant in the receiving waterways. Nutrient is consisted of inorganic elements such as nitrogen, phosphorus, sulphur, potassium, calcium and magnesium. However, nitrogen and phosphorus are the principal nutrients of concern in treated wastewater because the discharge of these pollutants may accelerate the 'eutrophication' of lakes and reservoirs and may stimulate the growth of algae and rooted aquatic plants in the shallow streams (Peavy et al., 1985).

In addition to being aesthetically unsightly, the presence of algae and aquatic plants may interfere with beneficial uses of the water resources, particularly when they are used for water supplies, fish propagation and recreation. Significant concentration of nitrogen in treated effluents may also have other adverse effects including depleting dissolved oxygen in receiving waters, exhibiting toxicity toward aquatic life, affecting chlorine disinfections efficiency, presenting a public health hazard, and affecting the suitability of wastewater for reuse (Crites and Tchobanoglous, 1998). Therefore, the control of nitrogen and phosphorus is

becoming increasingly important in water quality management and in the design of wastewater treatment plants.

The concentration of each component in the effluent varies considerably with the type of treatment plant. The effluent from treatment plant must be treated to comply with the Environmental Quality (Sewage and Industrial Effluent) Regulation 1978 before it can be discharge to the watercourses. However, the weakness of this regulation is that there are no established limits for nutrients (neither nitrogen nor phosphorus). They are only mentioned in the Interim Water Quality Standards for Malaysia (INWQS).

Various treatment methods have been used employing chemical, physical and biological systems to limit or control the amount of nutrients discharged by the treatment system. However, recently the most popular method to treat nutrient in wastewater is biological treatment. In biological treatment, mixed microbial culture will feed substrate in the effluent and finally removed it from the solution. Thus, microorganisms are used to consume organics, nitrify ammonia, denitrify nitrate, and release and uptake phosphorus (Metcalf and Eddy, 1991).

Recent advancements in biological waste treatment technology are capable of providing enhance nutrient removal by some modification in their process. These processes are called Biological Nutrient Removal (BNR) processes. Many of these processes are proprietary and use the form of the activated-sludge process but employ the combinations of anaerobic, anoxic and aerobic zones or compartments to accomplish nitrogen and phosphorus removal (Qasim, 1999).

Objective

This project aims to study the applicability of the biological nutrient removal process to treat nitrogen and phosphorus from domestic effluent. The overall objectives of the study are as follows:

1. To study nutrient removal process for sewage treatment using an anaerobic-anoxic-aerobic process.
2. To determine the important parameters that affects the removal of Nitrogen and Phosphorus.
3. To determine the removal of nutrient using combined reactor in removing nutrients, organics and solids and to investigate the effectiveness of using attached growth media in the aerobic zone
4. To develop kinetic parameters for nitrification and denitrification processes.