UNIVERSITI PUTRA MALAYSIA

TREATMENT OF WASTEWATER FROM KENAF WATER-RETTING PROCESS

ZAWANI BINTI ZAINUDDIN

FK 2014 170

TREATMENT OF WASTEWATER FROM KENAF WATER-RETTING PROCESS

By

ZAWANI BINTI ZAINUDDIN

© COPYRIGHT UPM

The submitted to the School of Graduates Studies, Universiti Putra Malaysia, in fulfilment of the requirements for the Degree of Doctor of Philosophy

August 2014

All material contained within the thesis, including without limitation text, logos, icons, photographs and all other artwork, is copyright material of Universiti Putra Malaysia unless otherwise stated. Use may be made of any material contained within the thesis for non-commercial purposes from the copyright holder. Commercial use of material may only be made with the express, prior, written permission of Universiti Putra Malaysia.

Copyright © Universiti Putra Malaysia

© COPYRIGHT UPM

Abstract of thesis presented to the senate of universiti putra malaysia in fulfilment of the requirement for the degree if doctor of philosophy

TREATMENT OF WASTEWATER FROM KENAF WATER-RETTING PROCESS

By

ZAWANI BINTI ZAINUDDIN

August 2014

Chair: Luqman Chuah Abdullah, PhD

Faculty: Engineering

Treatment wastewater from kenaf-retting process was implemented using three types of treatment process, namely coagulation, sequencing batch reactor (SBR) and adsorption process. Each of the tested process has advantages and disadvantages. Characteristic of wastewater was measured to determine presence of chemical composition. Concentration of chemical oxygen demand and colour were recorded in high concentration, which is more than 2000mg/L and 1000mg/L respectively. Most of parameters tested did not comply with the standard and regulation that regulated by Department of Environment (DOE) Malaysia.

In coagulation process, five types of coagulants were selected based on its reputation achieved in previous research. There are ferric chloride, aluminium sulphate, ferric sulphate, *Moringa oleifera* and *Jatropha curcas*. Results obtained from the experiment have given satisfactory results; more than 90% of turbidity was removed from the wastewater by all coagulants tested. All coagulants tested except ferric sulphate required acidic condition to work at optimum condition. Nevertheless, for the removal of COD all coagulants showed an average performance.

Then, the wastewater was tested with biological treatment, which activated sludge from nearby sewerage treatment plant used as source of bacteria. Diversity of microorganisms live in the sludge is a main criterion for the selection. Acclimatization process was implemented before biological treatment executed. Achromobacter, bacillus and acinetobacter were identified as dominant species lived in the wastewater. For biological treatment, sequencing batch reactor was selected to treat the wastewater. Two main parameters were tested; there are food-to-microorganisms (F/M) ratio and hydraulic retention time (HRT). SBR shows the best condition at low F/M ratio, which is 0.25, and the lowest of COD concentration recorded was 163mg/L. whilst, for HRT, SBR showed the best efficiency at HRT 24 per cycle. At higher HRT, the performance of SBR becomes less efficient. The lowest COD value in the final effluent for HRT24 was recorded at 114mg/L.

© COPYRIGHT UPM

The last treatment process tested was adsorption process. Activated charcoal was selected as an adsorbent. The highest uptake rate in various initial pH was found at pH8, and the adsorption process efficiency in this experiment was pH dependent. The increasing amount of adsorbent dosage enhanced the COD removal rate, but not the sorption capacity. However, 1.0g of activated charcoal was selected as the best dosage when the cost of adsorbent and treatment take into consideration and the value of COD in the effluent was 339mg/L. In equilibrium studies, COD concentration had shown well agreed with the Redlich-Peterson with high correlation coefficient values compared to other models

Combination of coagulation process with SBR and activated charcoal showed a good performance and high efficiency in removing total suspended solids, chemical oxygen demand and colour. Coagulation process is capable to remove COD and TSS averagely around 80% and 40% respectively. Through SBR-AC process, the value of COD become lower with the reduction recorded around 133mg/L only. Overall the integration process was the best treatment process compared to other three processes.

© COPYRIGHT UPM

Abstrak tesis yang dikemukakan kepada Senat Unversiti Putra Malaysia sebagai memenuhi keperluan untuk ijazah Doktor Falsafah

RAWATAN AIR SISA DARI PROSES RENDAMAN KENAF

Oleh

ZAWANI BINTI ZAINUDDIN

Ogos 2014

Pengerusi: Luqman Chuah Abdullah, PhD

Fakulti: Kejuruteraan

Rawatan air sisa dari proses pemisahan fiber Kenaf dilakukan melalui empat jenis rawatan iaitu process pengumpalan, reaktor penjujukan berkelompok, process penjerapan dan proses pengumpalan bersama reaktor penjujukan berkelompok yang berintegrasi dengan bahan penjerap. Setiap proses yang diuji memberikan kelebihan dan kekurangan yang tersendiri. Karakter bagi air sisa diuji terlebih dahulu bagi memastikan komposisi kimia yang hadir didalamnya. Kehadiran keperluan oksigen kimia, pepejal dan warna yang tinggi melebihi 1000mg/L. Kebanyakan parameter yang diuji menunjukkan bahawa kandungan didalam air sisa tersebut tidak mematuhi piawaian yang ditetapkan oleh Jabatan Alam Sekitar Malaysia.Kandungan bahan organik dan bukan organik juga diuji bagi mengetahui bahan spesifik yang terkandung didalam air sisa yang dikaji. Elemen bukan organik yang diuji seperti mempunyai kepekatan yang rendah. Manakala bahan organik pula terdiri daripada bahan semulajadi yang terdapat pada tumbuhan kenaf.

Melalui proses pengumpalan yang dilakukan, lima jenis pengumpal telah dipilih berdasarkan reputasi yang dicapai melalui kajian yang lepas. Ia adalah, *ferric chloride, aluminium sulphate, ferric sulphate, Moringa Oleifera* dan *Jatropha Curcas.* Melalui eksperimen yang telah dijalankan, didapati bahawa proses tersebut menunjukkan hasil yang sangat memuaskan dimana, penyingkiran kekeruhan dari sampel air sisa melebihi 90% dari jumlah keseluruhan kepekatan kekeruhan dari sampel. Kesemua pengumpal kecuali *ferric sulphate* memerlukan keadaan berasid bagi membolehkannya berfungsi secara optima. Namun begitu, dari segi penyingkiran keperluan oksigen kimia berada diparas sederhana bagi kesemua jenis pengumpal yang diuji.

Seterusnya, air sisa diuji pula dengan rawatan secara biologi dengan menggunakan bakteria yang diambil dari loji rawatan kumbahan yang berdekatan. Melalui proses penyesuaian yang dijalankan, terbukti bakteria yang digunakan mampu merawat air sisa dengan baik. *Achromobacter, bacillius* dan *acinetobacter* merupakan spesis yang mendominasi didalam sampel air sisa . Bagi ujian kaedah penjujukan berkelompok, dua jenis parameter yang diuji iaitu nisbah *food-to-microorganisms*

© COPYRIGHT UPM

(F/M) dan juga masa tertahan hidraulik (HRT). Melalui ujian yang telah dijalankan, didapati bahawa, semakin rendah kadar nisbah F/M yang digunakan semakin bagus reaktor merawat air sisa. Nisbah F/M yang paling berkesan dalam rawatan ini adalah 0.25 dan nilai COD didalam sampel akhir adalah sekitar163mg/L. Manakala bagi masa tertahan hidarulik pula yang diperlukan oleh reaktor adalah lebih kurang 24 jam bagi satu pusingan. Semakin tinggi masa tertahan hidraulik yang digunakan semakin rendah kecekapan reaktor merawat air sisa yang diuji. Nilai COD paling rendah yang diperolehi adalah sekitar 114mg/L sahaja.

Seterusnya, proses penjerapan dengan mengunakan bahan karbon teraktif sebagai penjerap. Berdasarkan daripada kepeutusan yang diperolehi menunjukkan bahawa bahan penjerap berupaya menyingkirkan kepekatan COD pada keadaan pH8 dan 283mg/L merupakan nilai COD akhir yang dicatatkan. Bagi ujian perbezaan berat bahan karbon teraktif yang dijalankan menunjukkan bahawa semakin berat bahan karbon teraktif yang digunakan semakin tinggi kadar penyingkiran kepekatan COD diperolehi. Namun begitu, dengan mengambila kira kos bahan dan rawatan, 1.0g bahan penjerap dikira yang paling baik dalam menyingkirkan bahan enapcemar daripada air sisa. Nilai COD akhir yang dicatatkan adalah 339mg/L.

Rawatan melalui proses pengumpalan bersama kaedah penjujukan berkelompok yang berintegrasi dengan bahan penjerap (SBR-AC) merupakan kaedah yang keempat yang diuji. Melalui ujian yang dijalankan, didapati bahawa, kombinasi kaedah rawatan ini mempunyai kecekapan yang tinggi dan efisien dalam menyingkirkan permintaan oksigen kimia, pepejal terampai dan warna yang menjadi punca utama kepada masalah ini. Proses penjerapan berjaya menurunkan kadar kepekatan COD dan pepejal terampai masing-masing sekitar 80% dan 40%. Seterusnya air sisa itu dirawat dengan kaedah SBR-AC, dan nilai COD menurun sehingga 133mg/L sahaja, manakala TSS pula mengalami peningkatan sedikit. Secara keseluruhannya, keputusan ujian yang telah dijalankan menunjukkan bahawa proses integrasi ini berjaya menurunkan kadar kepekatan bahan enapcemar dengan begitu baik sekali. Secara keseluruhannya, proses integrasi menunjukkan prestasi yang terbaik berbanding dengan kaedah rawatan yang lain.

© COPYRIGHT UPM

ACKNOWLEDGEMENT

First of all, thanks to Allah SWT the Almighty for the great opportunity and experience I had through this journey. Thank you to my supervisor, Prof. Dr. Luqman Chuah Abdullah and supervisory committee; Prof. Dr. Fakhru'l Razi Ahmadun, Assoc. Prof. Dr. Khalina Abdan and Assoc. Prof. Dr. Rosfarizan Mohamad for your advices and guidance.

My highly appreciations goes my loyal supporters; my husband, Mohd Noor Asyraf, and my mother, Sariah Haji Yahya, thank you for your loves, care, physical and mental support on during hard times and for being there for me all the times.

Not to forget to my siblings, Kak Long, Angah, Alang and Ateh, thank you for your understanding and moral support, and lastly to my late brother, Along, thanks for your love and care during your life.

Last but not least, to my lab mates, you know who you are, thank you for moral support, exchanged ideas and help along this ride. For those who directly and indirectly helped me during my study thank you.

© COPYRIGHT UPM

I certify that a Thesis Examination Committee has met on 5 August 2014 to conduct the final examination of Zawani binti Zainuddin on her thesis entitled "Treatment of Wastewater from Kenaf Water-Retting Process" in accordance with the Universities and University Colleges Act 1971 and the Constitution of the Universiti Putra Malaysia [P.U.(A) 106] 15 March 1998. The Committee recommends that the student be awarded the Doctor of Philosophy.

Members of the Thesis Examination Committee were as follows:

Salmiaton binti Ali, PhD
Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Azni bin Hj Idris, PhD
Professor
Faculty of Engineering
Universiti Putra Malaysia
(Internal Examiner)

Thomas Choong Shean Yaw, PhD
Professor, Ir
Faculty of Engineering
Universiti Putra Malaysia
(Internal Examiner)

Kenji Sakai, PhD
Professor
Graduate School of Bioresource an Bioenvironment
University of Kyushu
(External Examiner)

ZULKARNAIN ZAINAL, PhD
Professor and Deputy Dean
School of Graduate Studies
Universiti Putra Malaysia

Date: 23 January 2015

This thesis was submitted to the Senate of Universiti Putra Malaysia and has been accepted as fulfilment of the requirement for the degree of Doctor of Philpsophy. The members of the Supervisory Committee were as follows:

Luqman Chuah Abdullah, PhD
Professor
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Fakhru'l-Razi Ahmadun, PhD
Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

Khalina Abdan, PhD
Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

Rosfarizan Mohamad, PhD
Associate Professor
Faculty of Biotechnology
Universiti Putra Malaysia
(Member)

BUJANG KIM HUAT, PhD
Professor and Dean
School of Graduates Studies
Universiti Putra Malaysia

Date:

© COPYRIGHT UPM

Declaration by graduate student

I hereby confirm that:

- this thesis is my original work;
- quotations, illustrations and citations have been duly referenced;
- this thesis has not been submitted previously or concurrently for any other degree at any other institutions;
- intellectual property from the thesis and copyright of thesis are fully-owned by Universiti Putra Malaysia, as according to the Universiti Putra Malaysia (Research) Rules 2012;
- written permission must be obtained from supervisor and the office of Deputy Vice-Chancellor (Research and Innovation) before thesis is published (in the form of written, printed or in electronic form) including books, journals, modules, proceedings, popular writings, seminar papers, manuscripts, posters, reports, lecture notes, learning modules or any other materials as stated in the Universiti Putra Malaysia (Research) Rules 2012;
- there is no plagiarism or data falsification/fabrication in the thesis, and scholarly integrity is upheld as according to the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) and the Universiti Putra Malaysia (Research) Rules 2012. The thesis has undergone plagiarism detection software.

Signature: Date: 26 JUNE 2015

Name and Matric No.: ZAWANI BINTI ZAINUDDIN (GS24431)

© COPYRIGHT UPM

Declaration by Members of Supervisory Committee

This is to confirm that:

- The research conducted and the writing of this thesis was under our supervision;
- Supervision responsibilities as stated in the Universiti Putra Malaysia (graduate Studies) Rules 2003 (Revision 2012-2013) are adhered to.

Signature:		Signature	
Name of Chairman of Supervisory Committee	Prof. Dr Luqman Chuah Abdullah	Name of Member of Supervisory Committee	Assoc. Prof. Dr. Khalina Abdan
Signature		Signature	
Name of Member of Supervisory Committee	Prof. Dr. Fakhru'l-Razi Ahmadun	Name of Member of Supervisory Committee	Assoc. Prof. Dr. Rosfarizan Mohamad

© COPYRIGHT UPM

TABLE OF CONTENTS

		Page
ABSTRACT		**i**
ABSTRAK		**iii**
ACKNOWLEDGEMENT		**v**
APPROVAL		**vi**
DECLARATION		**viii**
LIST OF TABLES		**xiii**
LIST OF FIGURES		**xiv**
LIST OF ABBREVIATIONS		**xvii**
CHAPTER		
1.	**INTRODUCTION**	**1**
	1.1. Background of studies	1
	1.2. Problem statement	1
	1.3. Objectives of studies	3
	1.4. Scope of studies	3
2.	**LITERATURE REVIEW**	**5**
	2.1 Natural fibres as alternative resources	5
	2.2 Kenaf plant	5
	2.2.1 History of Kenaf	5
	2.2.2 Physical and chemical structure of Kenaf	6
	2.2.3 Development of Kenaf in Malaysia	8
	2.2.4 Application and development of products from Kenaf	9
	2.2.5 Retting process of Kenaf	9
	2.3 Wastewater treatment	13
	2.3.1 Coagulation process	13
	2.3.2 Aerobic process in wastewater treatment technology	18
	2.3.3 Adsorption process	24
	2.3.4 Integration system of treatment process – Coagulation, adsorption and SBR treatment process	32
	2.4 Summary of literature review	34
3.	**CHARACTERIZATION OF KENAF-RETTING WASTEWATER**	**35**
	3.1 Preparation of Kenaf bast-fibre	35
	3.2 Water for kenaf retting process	35
	3.3 General procedure of water-retting process	35
	3.4 Analysis of wastewater	38
	3.4.1 Characterization of wastewater	38
	3.5 Results and discussion	38
	3.5.1 Characteristic of wastewater	38
	3.5.2 Presence of other compound in the wastewater	41
	3.6 Findings on characteristics of wastewater	43

© COPYRIGHT UPM

4. TREATMENT OF KENAF-RETTING WASTEWATER USING COAGULATION PROCESS 45
4.1 Introduction 45
4.2 Wastewater sample 45
4.3 Preparation of coagulants 45
4.4 Jar test experiment 46
4.4.1 Different pH of sample 48
4.4.2 Different dosage of coagulant 48
4.5 Results and Discussion 49
4.5.1 Determination of coagulant dosage 50
4.5.2 Determination of optimum condition 51
4.6 Mechanisms of coagulation process 61
4.7 Findings of coagulation process 62

5. SEQUENCING BATCH REACTOR (SBR) EXPERIMENT TO TREAT KENAF-RETTING WASTEWATER 65
5.1 Introduction 65
5.2 Acclimatization process of activated sludge 65
5.2.1 Materials 65
5.2.2 Acclimatization procedure 66
5.2.3 Analysis of sample 67
5.2.4 Identification of microbes in acclimated sludge 68
5.2.5 Results and Discussion 72
5.3 Treatment of wastewater using SBR process 76
5.3.1 Wastewater as a food source 76
5.3.2 Inoculums 76
5.3.3 Design of reactor 77
5.3.4 Operation of reactor 77
5.3.5 Sample for analysis 78
5.3.6 Effect of hydraulic retention time (HRT) on SBR performance 78
5.3.7 Food-to-microorganisms (F/M) ratio 79
5.3.8 Results and Discussion 80
5.4 Findings of Sequencing batch reactor (SBR) 85

6. TREATMENT OF WASTERWATER FROM KENAF WATER RETTING USING ADSORPTION PROCESS: PRELIMINARY STUDY 87
6.1 Introduction 87
6.2 Materials 87
6.2.1 Adsorbent 87
6.3 Experimental Procedures 88
6.3.1 Effect of initial pH 88
6.3.2 Effect of different weight of activated carbon 89
6.4 Results and Discussion 90
6.4.1 Effect of different pH of sample 90
6.4.2 Effect of various dosages of activated carbon (AC) 91
6.4.3 Equilibrium study 92
6.4.4 Adsorption isotherm 93
6.5 Findings of adsorption process 96

© COPYRIGHT UPM

7. INTEGRATION OF COAGULATION WITH SBR-AC TO TREAT KENAF-RETTING WASTEWATER 97
7.1 Introduction 97
7.2 Materials 97
7.2.1 Coagulant 97
7.2.2 Activated sludge 97
7.2.3 Adsorbent 97
7.3 Wastewater sample 97
7.4 Design of experiment 98
7.4.1 Coagulation as pre-treatment process 98
7.4.2 Operation of reactor – SBR and adsorption as one unit treatment process 99
7.5 Analysis of sample 100
7.6 Results and discussion 102
7.6.1 pH 102
7.6.2 Chemical oxygen demand (COD) 103
7.6.3 Turbidity 104
7.6.4 Total suspended solids (TSS) 105
7.6.5 Colour 106
7.6.6 Sludge production 107
7.7 Findings of SBR-AC integrated with coagulation process 108

8. CONCLUSIONS AND RECOMMENDATIONS FOR FUTURE RESEARCH 111
8.1 General conclusions 111
8.2 Recommendation Future Research 112

REFERENCES/ BIBLIOGRAPHY 115
APPENDICES 126
BIODATA OF STUDENT 146
PUBLICATIONS 147

© COPYRIGHT UPM

LIST OF TABLES

TABLE		Page
2.1	Production of Kenaf in Malaysia (LTKN, 2009)	8
2.2	Type of retting process – traditional and alternatives method	11
2.3	Treatment of various types of wastewater done by previous researcher	16
2.4	Description of sequencing batch reactor phase	23
2.5	Type of isotherm according to value of RL	31
2.6	Previous works done by other researchers in integrated treatment process	33
3.1	Analyses results from wastewater characterization	40
3.2	List of inorganic compound identified in the sample	42
3.3	List of specific organic compound detected in the sample	43
4.1	Characteristic of wastewater sample	45
4.2	The best condition to remove turbidity and COD	62
4.3	Concentration of turbidity and COD for final effluent	63
5.1	Characteristic of wastewater	66
5.2	General description of bacteria found in the acclimated activated sludge	76
5.3	Operation parameter of SBR process for different HRT	79
5.4	Operating parameter for F/M ratio study	79
5.5	Concentration of COD in final effluent	85
6.1	The specification of AC used in the experiment	88
6.2	Summary of all isotherm model constants for the adsorption of COD onto Activated Charcoal (AC)	93
7.1	Characteristic of untreated wastewater	98
7.2	Procedure of jar test experiment	99
7.3	Operating parameter for SBR-GAC experiment	100
7.4	Summary of results for SBR-AC integrate with coagulation process experiment	109
8.1	Best condition for every type of treatment process	112

© COPYRIGHT UPM

LIST OF FIGURES

FIGURE		Page
2.1	Kenaf Plant	6
2.2	Composition of Kenaf stem (adapted from N. Nishimura et al, 2002)	7
2.3	Typical process of SBR	22
2.4	Operation of SBR process (adapted from Peter Wilderer)	22
2.5	Adsorption Isotherms (Warren, Julian, & Harriot, 1982)	35
3.1	Pictures (a) and (b) Kenaf field at Taman Pertanian Universiti (TPU) at UPM, Serdang	36
3.2	Kenaf bast-fibres were submerged in the water during retting process	36
3.3	Wastewater produced from kenaf fibre water-retting process	37
3.4	Flow chart of preparing wastewater for the experiment	43
3.5	Chromatogram from the analysis of sample using GC-MS	46
4.1	Moringa seeds	46
4.2	Jatropha seeds	46
4.3	Jar test equipment by Velp Scientifica (Italy)	47
4.4	Stages of coagulation process in the experiment.	48
4.5	Flow-chart of general process for coagulation process	49
4.6	Removal of turbidity for $AlSO_4$, $FeSO_4$ and $FeCl_3$ samples using different coagulant dosage	50
4.7	Removal of turbidity for Moringa and Jatropha samples using different coagulant dosage	51
4.8	Effect of various pH on turbidity and COD removal for aluminium sulphate (Volume of sample = 200mL)	52
4.9	Effect of various pH on turbidity and COD removal for ferric sulphate (Volume of sample = 200mL)	53
4.10	Effect of various pH on turbidity and COD removal for ferric chloride (Volume of sample = 200mL)	54
4.11	Effect of various pH on turbidity and COD removal for Moringa (Volume of sample = 200mL, volume of coagulant dosage = 3000mg/L)	55
4.12	Effect of various pH on turbidity and COD removal for Jatropha (Volume of sample = 200mL, volume of coagulant dosage = 4000mg/L)	56
4.13	Removal of turbidity and COD by Aluminium Sulphate (pH of sample = pH4, volume of sample = 200mL)	57

© COPYRIGHT UPM

4.14	Removal of turbidity and COD by ferric chloride (pH of sample = pH4, volume of sample = 200mL)	58
4.15	Removal of turbidity and COD using Ferric Sulphate (pH of sample = pH8, volume of sample = 200mL)	59
4.16	Removal of turbidity and COD for Moringa samples (pH of sample = pH4, volume of sample = 200mL)	60
4.17	Removal of turbidity and COD for Jatropha samples (pH of sample = pH4, volume of sample = 200mL)	60
4.18	Forces acting on floc particle (Tebbutt 1997)	61
5.1	Acclimatization process thru batch process	67
5.2	Dilution technique	69
5.3	Streak technique - step 1	70
5.4	Streak technique - step 2	71
5.5	Streak technique - step 3	71
5.6	Average of biomass concentration recorded in the acclimatization process (initial MLSS at Day 0= 1000.0mg/L)	72
5.7	Concentration of COD in the effluent sample (initial concentration of COD: 2300 mg/L)	73
5.8	Variety of colonies from acclimated sludge lives on the agar plate (as indicated by arrow on the figure)	74
5.9	Acclimated bacteria in the wastewater observed under microscope (magnification: 40x and 100x)	75
5.10	Peristaltic pump used in the experiment (Watson-Marlow Bredel 323Dz)	77
5.11	Schematic diagram of SBR	78
5.12	Concentration of MLSS in the reactor at different of HRT (♦ = 12hrs, ▲= 24hrs, ■ = 48hrs, x = 72hrs)	80
5.13	Concentration of COD in the effluent at different of HRT (♦ = 12hrs, ▲= 24hrs, ■ = 48hrs, x = 72hrs)	81
5.14	The concentration of MLSS recorded in the reactor for every F/M ratio (F/M ratio; ♦ = 0.5, ▲= 1.0, ■ = 1.5, x = 2.0)	83
5.15	The concentration of COD in effluent recorded in the reactor for every F/M ratio (F/M ratio; ♦ = 0.5, ▲= 1.0, ■ = 1.5, x = 2.0)	84
6.1	Charcoal activated carbon	87
6.2	General procedure of adsorption study	89

© COPYRIGHT UPM

6.3	Effect of initial pH (pH 5-9) on adsorption capacity of activated charcoal (wt = 1.0 g, C_o = 1000.0 mg/l, volume of sample = 100mL, pH of sample = 7.0±0.1 and agitated for 24 hours)	90
6.4	Effect of different dose of adsorbent on COD removal (C_o = 1000.0 mg/l, volume of sample = 100mL, pH of sample = 8.0±0.1, and agitated for 24hrs)	91
6.5	Equilibrium study of sample onto AC for 144hrs (dose of adsorbent = 1.0g, volume of sample = 100mL, pH of sample = 8.0±0.1)	92
6.6	Non-linear regression plots Langmuir isotherm for adsorption	94
6.7	Non-linear regression plots Freundlich isotherm for adsorption	94
6.8	Non-linear regression plots Redlich-Peterson isotherm for adsorption	95
7.1	General process of wastewater treatment using integration unit	101
7.2	Value of sample pH after treatment process	102
7.3	Concentration of COD after treatment process	103
7.4	Concentration of turbidity after treatment process	104
7.5	Concentration of TSS after treatment process	105
7.6	Concentration of colour after treatment process	106
7.7	Transition of colour in the wastewater at different treatment process	107
7.8	Production of sludge volume after coagulation process	108
7.9	Adsorbent (a) before SBR-AC experiment (b) after SBR-AC experiment under SEM	109

© COPYRIGHT UPM

LIST OF ABBREVIATIONS

Notations / symbols		
°C	Celcius	
Å	Length, = 10^{-10} m	
AA	Activated alumina	
ADMI	American Dye Manufacturer Institute	
AlS	Aluminium sulphate	
APHA	American Public Health Association	
AS	Acitivated sludge	
B.C	Before century	
b_j	Redlich-Peterson constant	
BOD	biological oxygen demand	$mg.L^{-1}$
BOD5	biological oxygen demand for 5-days	
Cd	Cadmium	
C_e	Bulk phase concentration	$mg.L^{-1}$
C_o	Initial concentration	$mg.L^{-1}$
CO	Carbon monoxide	
Co	Cobalt	
CO2	Carbon Dioxide	
COD	chemical oxygen demand	$mg.L^{-1}$
Cr	Chromium	
C_t	Concentration of the solution at time t	$mg.L^{-1}$
Cu	Copper	
DOE	Department of Environment	
F/M ratio	food-microorganism ratio	
FC	Ferric chloride	
FS	Ferric sulphate	
g	gram	
GAC	Granular activated carbon	
GCMS	Gas Chromatography Mass Spectrophotometer	
HCl	Hydrochloric acid	
hr	hour	
HRT	hydraulic retention time	hr
ICP	Inter couple Plasma	
IUPAC	International Union of Pure and Applied Chemistry	
K_F	Freundlich adsorption capacity	mg/g
kg/mol	kilogram per mol	
K_j	Adsorption capacity	$L.g^{-1}$
K_L	Langmuir constant	$L.g^{-1}$

© COPYRIGHT UPM

L	litre	
l/g	litre per gram	
l/mg	litre per miligram	
m	Adsorbent mass	g
mg	miligram	
mg/L	miligram per litre	
min	minute	
min	minute	
mL	mililitre	
MLSS	Mixed liqour suspended solids	$mg.L^{-1}$
n	Surface heterogeneity	
N	normality	
NA	Not available	
NaOH	Sodium Hydroxide	
NTU	Nephelometric Turbidity Unit	
O_2	Oxygen	
PAC	powdered activated carbon	
PtCo	Platinum Cobalt	
q_e	Solid phase concentration at equilibrium	mg/g
$q_{e,calc}$	Predicted solid phase concentration at equilibrium	mg/g
$q_{e,exp}$	Solid phase concentration at equilibrium obtained from experiment	mg/g
q_t	Solid phase concentration at time t	mg/g
R_L	Dimensionless separation factor	
rpm	rotation per minute	
SBR	Sequencing batch reactor	
SS	Suspended solids	
t	Time	minute
TDS	Total dissolved solids	$mg.L^{-1}$
TSS	Total suspended solids	$mg.L^{-1}$
V	Volume of solution	mL
VSS	volatile suspended solids	$mg.L^{-1}$
α_L	Energy of adsorption	$dm^3.mg^{-1}$
β	Heterogeneity factor	

© COPYRIGHT UPM

CHAPTER 1

INTRODUCTION

1.1 Background of studies

Recently, a lot of researchers focused on natural fibres in finding new materials to produce environmental friendly and renewable products. There are numbers of researches have been done on various types of natural fibres such as jute, sisal, hemp and kenaf due to capability of these plants to meet the requirement as eco-friendly products. Among natural fibres, kenaf has its own reputation as an alternative material in industry and research field. Kenaf has been recognized as one of the most important fibres in product development like composites, pulp/paper, particle boards etc.

Bast-fibres that found in the kenaf plant are playing an important role as a raw material for plant-based or bio-composite products. Nevertheless, bast-fibres cannot be used directly as a raw material because it needs to be separated into individual fibre. This individual fibre can be obtained through retting process.

Retting process can be defined as a slow degradation process that can take up a few days to complete. There are various types of retting, for an example using chemical, dew- or water-retting. Commonly water-retting procedure is selected because it is simple and often produced a good quality of fibre. However, large amount of water in fibre separation (retting) process is required to obtain the fibres. Typically water that has been used in the process will be released to the watercourse without any treatments. The condition of wastewater that turbid and produces odour makes it unacceptable by public. This problem can be resolved with an appropriate treatment process.

For that reason in this research study, wastewater is characterized and the treatment process was designed to treat the wastewater. Therefore, coagulation process, sequencing batch reactor (SBR) and adsorption process were proposed to treat the wastewater. These processes are well-known for their effectiveness in treating wastewater either from municipal or industrial.

1.2 Problem statement

i. Generation of wastewater from kenaf water-retting process

At present, industrial sector are producing fibres in large quantity through water-retting process, hence, the process generating enormous amount of wastewater from the separation process. Generation of wastewater from kenaf retting process in Malaysia is unknown due to lack of information. Nevertheless, according to Mondal & Kaviraj (2008) as reported by Huda et al. (2012) for 10,000kg of jute,

© COPYRIGHT UPM

approximately 432m^3 of water is used in water-retting process. Since kenaf and jute are from one family known as *Malvaceae* so the retting process is similar. In the future, amount of wastewater will be increased tremendously when the amount of fibre production will be greater than before as kenaf become one of the commodities in Malaysia. An effective wastewater treatment process is necessitated to protect the environment, to fulfil the standard required by authority and also to help to recover water resource. However, cost of operation and land area might be the main obstacles for small industry and farmers to treat the wastewater properly.

ii. Presence of foreign matter and compound from the water-retting process to aquatic environment

Solids either suspended or dissolved can be found due to presence of fibres and other component during the retting process. These solids have caused the wastewater become cloudy. Organic substances also can be related to increasing turbidity in the wastewater. A material such as lignin was diffused into the water during the retting process. Therefore, high turbidity which consists of suspended particles, colloids and substances in the wastewater will induce interfere an aquatic ecosystem when the wastewater release into the ecosystem without any treatment due its potential to deplete oxygen (O_2) in the water.

The existence of colour is often related to the presence of certain substance in the wastewater. Generally, colour in the wastewater is unacceptable by the public. Unlike man-made coloured wastewater, it is quite difficult to get rid of the colour from the wastewater without knowing type of compound that responsible for its existence. Furthermore, if the wastewater is released at the point for water intake, it will affect quality of water which will increase the cost of water treatment.

iii. Reclaim and reuse treated wastewater for irrigation

Clean water is an important resource for human and become main attention recently due to declination of water source around the world. The reduction source occurred mainly due to water pollution caused by human activities. Therefore, recycle and reuse program was introduced to optimize an application of treated wastewater for other application such as watering public park, field or farm. However, reuse the wastewater for farming application it is depend on the origin of wastewater, quality of effluent and also whether it is for edible crops or not.

© COPYRIGHT UPM

1.3 Objective of studies

The detailed research objectives are listed below.

i. to evaluate the performance of various coagulants in coagulation/flocculation process in treating kenaf-retting wastewater

ii. to evaluate the performance of biological treatment, Sequencing Batch Reactor (SBR) in treating kenaf-retting wastewater

iii. to evaluate the performance of adsorption process in the treatment of kenaf-retting wastewater.

iv. to evaluate performance of integrated treatment process by combining coagulation, SBR and adsorption process as one unit treatment to treat kenaf-retting wastewater

1.4 Scope of studies

There are various types of treatment process consist of physical, chemical and biological were selected and investigated in this study; coagulation, adsorption and sequencing batch reactor (SBR) process and also combination of these three methods in as one treatment unit. These processes are well-known for its good performance in treating municipal or industrial wastewater. The effluent was also investigated for its potential to reuse and reclaim for other activities. The scopes can be summarized as follows;

i. Analyze the characteristic and behaviour of wastewater

There were few or none previous study on characteristic of kenaf-retting wastewater has been reported. For that reason, characteristic and behaviour study of this wastewater is important before any treatment can be done. Therefore, several analyses were implemented to fulfil the intent. American Public Health Association (APHA) standard procedure has been used to serve as guideline to analyze the kenaf-retting wastewater.

ii. Evaluate performance of selected coagulant and its optimum condition to treat the wastewater

Due to existence of suspended solids (SS) and colloids in the wastewater, thus coagulation process was selected to treat the wastewater. Coagulation is managed to remove any particulate and substances in the wastewater by using several types of selected coagulants that consists of chemical and natural coagulants. Optimum condition for every type of coagulant was determined in terms of coagulant dosage and pH of wastewater sample.

© COPYRIGHT UPM

iii. Acclimatization of activated sludge from other source in the wastewater

Activated sludge (AS) from sewerage treatment plant was used as a seeding for SBR since it is difficult to find microbes in the wastewater. Diversity of microorganisms live in the sludge makes it easy to receive different kinds of substrate and pollutants. Acclimatization process was run to introduce the AS with the new wastewater and performance of microorganisms was monitored. Batch method was took place in the acclimatization process, which wastewater sample was introduced to AS for certain period of time and then withdrawn the sample. After that the process was continue introduced new samples until the AS reaches its stabilization. Acclimatized sludge was cultivated and isolated for microbe's species identification. After the AS was acclimatized with the wastewater, the AS is ready to be used as inoculums in biological treatment process.

iv. to examine the effectiveness of sequencing batch reactor (SBR)

Wastewater produced from water-retting process contains high organic compound and unpleasant odour. Biological treatment like sequencing batch reactor (SBR) has capability to treat the wastewater with a lot of advantage such as capability to receive high shock of loading rate and eliminate odour. Acclimatized AS was used as inoculums in the SBR process. Main parameters were exploited in the study such as hydraulic retention time (HRT) and food to microorganism (F/M) ratio.

v. to explore the potential and the efficiency of adsorption process

Adsorption process was considered in this study due to its efficiencies in treating innumerable types of wastewater. Granular charcoal activated carbon was picked as an adsorbent in this study. Batch experiment was implemented in the process such as equilibrium study, effect of adsorbent dosage and pH of sample.

vi. to measure performance and effectiveness of integrated system to treat the wastewater

Coagulation process as a pre-treatment process, combining with SBR that integrated with activated carbon was implemented in this study. Optimum condition employed in the experiment was obtained from previous experiment – coagulation, SBR and adsorption.

© COPYRIGHT UPM

REFERENCES

Abdessemed, D., Nezzal, G., & Aim, R. Ben. (2000). Coagulation—adsorption—ultrafiltration for wastewater treatment and reuse. *Desalination*, 131(October), 307–314.

Abdulmoniem, M. S. & Zaid, I. A. (2011). An In-vitro antimicrobial activity of Moringa Oleifera L. seed extracts against different groups of microorganisms. *Australian Journal of Basic and Applied Sciences.* 129-134.

Abidin, Z. et al. (2011). A preliminary study on Jatropha Curcas as coagulant in wastewater treatment. *Environ. Technol*. 32(9): 971-977.

Abidin, Z. Z., Mohd Shamsudin, N. S., Madehi, N., & Sobri, S. (2013). Optimisation of a method to extract the active coagulant agent from Jatropha curcas seeds for use in turbidity removal. *Industrial Crops and Products*. 41: 319–323.

Achten, W. et al. (2007). Jatropha biodiesel fueling sustainability. *Biofuels, Bioproducts and Biorefining*. 1(4): 283-291.

Adamson, A. & Gast, A. (1997). *Physical Chemistry of Surfaces*. Sixth ed. ed. New York: Wiley-Interscience.

AECOM, M. &. E. I. a. et al. (2007). *Water reuse: Issuses, Technologies, and application*. New York: McGraw Hill Professional.

Ahmad, A, Wong, S., Teng, T., & Zuhairi, a. (2008). Improvement of alum and PACl coagulation by polyacrylamides (PAMs) for the treatment of pulp and paper mill wastewater. *Chemical Engineering Journal*. 137(3): 510–517.

Ahmad, A. L., & Puasa, S. W. (2007). Reactive dyes decolourization from an aqueous solution by combined coagulation/micellar-enhanced ultrafiltration process. *Chemical Engineering Journal*. 132(1-3): 257–265.

Ahmed, A. M. (1993). *Modelling of biological wastewater treatment in SBR*. King Fadh University of Petroleum and Minerals, Saudi Arabia.

Aksu, Z., & Tezer, S. (2000). Equilibrium and kinetic modelling of biosorption of Remazol Black B by Rhizopus arrhizus in a batch system: effect of temperature. *Process Biochemistry*. 36(5): 431–439.

Aldegs, Y., Elbarghouthi, M., Elsheikh, a, & Walker, G. (2008). Effect of solution pH, ionic strength, and temperature on adsorption behavior of reactive dyes on activated carbon. *Dyes and Pigments*: 77(1), 16–23.

Alexander, B., Mishra, S., & Lampke, T. (2005). *Plant Fibers as Reinforcement Green Composites*. In L. K. Mohanty, Amar; Misra, Manjusri; T. Drzal (Ed.), Natural Fibers, Biopolymers, and Biocomposites (p. 896). CRC Press.

Alexopoulou, E., Christou, M., Mardikis, M., & Chatziathanassiou, A. (2000). Growth and yields of kenaf varieties in central Greece. *Industrial Crops and*

© COPYRIGHT UPM

Products. 11(2-3): 163–172.

Allen, S., McKay, G. & Porter, J. (2004). Adsorption isotherm model for basic dyeadsorption by peat in single and binary component systems. *J. Colloid Interface Sci.*280: 322-333.

AlMubaddal, F., AlRumaihi, K., & Ajbar, A. (2009). Performance optimization of coagulation/flocculation in the treatment of wastewater from a polyvinyl chloride plant. *Journal of Hazardous Materials.* 161(1): 431–438.

Amuda, O. S., & Alade, a. (2006). Coagulation/flocculation process in the treatment of abattoir wastewater. *Desalination.* 196(1-3): 22–31.

APHA, A. P. H. A. (2005). *Standard methods for the examinations for water and wastewater.* Washington DC: APHA.

Aritkhodzhaev, K. (1995). Pectin from green kenaf bast. *Chemistry of Natural* Compounds. 31(2): 159–162.

Ayoub, G. M., Hamzeh, A., & Semerjian, L. (2011). Post treatment of tannery wastewater using lime/bittern coagulation and activated carbon adsorption. *Desalination.* 273(2-3): 359–365.

Bansal, R. & Goya, M. (2005). *Activated carbon adsorption*. Florida, USA: CRC Press.

Bennet, T. A. (2007). *Evaluation of bench-scale sequencing batch reactor swine waste treatment under continuous and cyclic operation*. North Carolina State University, North Carolina, USA.

Beychok, M. R. (1967). *Aqueous wastes from petroleum and petrochemical plants*. New York: John Wiley & Sons, Inc.

Bhatia, S., Othman, Z., & Ahmad, A. L. (2007). Pretreatment of palm oil mill effluent (POME) using Moringa oleifera seeds as natural coagulant. *Journal of Hazardous Materials.* 145(1-2): 120–6.

Bhatia, S., Zalina, O. & Abdul Latif, A. (2007). Coagulation-flocculation process for POME treatment using Moringa oleifera seeds extract. *Chemical Engineering Journal*. 133: 205-212.

Boulinguiez, B., Cloirec, P. L. & Wolber, D. (2008). Revisiting the determination of Langmuir parameters application to tetrahydrothiophene adsorption onto activated carbon. *Langmuir* .24: 6420-6424.

Bramer, H. C. & Hoak, R. D. (1967). *Water reclamation. In: Water reuse*. (pp. 92-95) New York: American Institute of Chemical Engineers.

Button, D. & Robertson, B. (1985). Effect of toulene exposure time and concentration on induction of high affinity values for toulene oxidation by bacteria of estuarine seawater samples. *Mar. Ecol. Prog. Ser*. 26: 53-65.

© COPYRIGHT UPM

Cecen, F. & Aktas, O. (2012). *Activated Carbon for Water and Wastewater Treatment*. Weiham: Wiley-VCH Verlag & Co.

Chen, W., & Liu, J. (2011). The possibility and applicability of coagulation-MBR hybrid system in reclamation of dairy wastewater. *Desalination*. 285: 226–231.

Chern, J. M., & Wu, C. Y. (2001). Desorption of dye from activated carbon beds: effects of temperature, pH, and alcohol. *Water Research.* 35(17): 4159–65.

Clark, R. M. & Jr., B. W. L. (1989). *Granular Activated Carbon*. Michigan: Lewis Publisher, Inc.

Cooper, J. C. & Hanger, D. G. (1967). *Water reclamation with Granular Activated Carbon. In: Water Reuse*. (pp. 185-192). New York: American Institute of Chemical Engineers.

Coulson, J. & Richarson, J. (1991). *Chemical Engineering. In: Particle Technology and Separation Processes*. Fourth Edition ed. Headington Hill Hall, Oxford: Pergamon Press.

Department of Statistics Malaysia, 2013. Department of Statistics Malaysia. [Online]

Dialynas, E., & Diamadopoulos, E. (2008). Integration of immersed membrane ultrafiltration with coagulation and activated carbon adsorption for advanced treatment of municipal wastewater. *Desalination*. 230(1-3): 113–127.

Dosta, J., Rovira, J., Galí, a, Macé, S., & Mata-Alvarez, J. (2008). Integration of a Coagulation/Flocculation step in a biological sequencing batch reactor for COD and nitrogen removal of supernatant of anaerobically digested piggery wastewater. *Bioresource Technology*. 99(13):5722–30.

Douglas, M., Shamsuzzaman, F. & Knaebel, K. (1994). *Pressure Swing Adsorption*. New York: VCH Publishers Inc.

Eichner, C., Erb, R., Timmis, K. & Wagner-Dobler, I. (1999). Thermal gradient gel electrophoresis analysis of bio-protection from pollutant shocks in the activated sludge microbial community. *Appl Environ Microbiol*. 65:102-109.

El Bestawy, E., Helmy, S., Hussein, H., & Fahmy, M. (2013). Optimization and/or acclimatization of activated sludge process under heavy metals stress. World *Journal of Microbiology & Biotechnology*. 29(4):693–705.

El-Gohary, F., & Tawfik, A. (2009). Decolorization and COD reduction of disperse and reactive dyes wastewater using chemical-coagulation followed by sequential batch reactor (SBR) process. *Desalination.* 249(3): 1159–1164.

Fink, W. (1984). *Identifizierung, Reindarstellung und strukturaufklarung flockungsaktiver wirkstoffe aus hoheren planzen zur wasserreinigung*. s.l.:Univ. Heidelberg.

Foo, K. & Hameed, B. (2010). Insights into the modeling of adsorption isotherms

© COPYRIGHT UPM

systems. *Chemical Engineering Journal*. 156: 2-10.

Fournier, J., Codaccioni, P. & Soulas, G., 1981. Soil adaptation to 2,4-D degradation in relation to the application rates and the metabolic behaviour of the degrading microflora. *Chemosphere.* 10: 977-984.

Gassen, H. G., Gassenschmidt, U., D., J. K. & Tauscher, B. (1991). Chemical Properties of flocculating active proteins from Moringa Oleifera. *Biol. Chem. Hoppe-Seyler*. 372: 659.

Gerardi, M. H. (2006). *Wastewater Bacteria* (p. 208). New Jersey: John Wiley & Sons.

Gosset, S. & Dentel, J. (1988). Mechanisms of coagulation with aluminum salts. *J. Am. Water Work Assoc.*80 187-198.

Guida, M., Mattei, M., Rocca, C. Della, Melluso, G., & Meriç, S. (2007). Optimization of alum-coagulation/flocculation for COD and TSS removal from five municipal wastewater. *Desalination.* 211(1-3): 113–127.

Gunay, A., Arslankaya, E. & Tosun, I. (2007). Lead removal from aqueous solution by natural and pretreated clinoptilolite: adsorption equilibrium and kinetics. *J. Hazard. Mater*. 146: 362-371.

Guo, W., Vigneswaran, S., Ngo, H. & Xing, W. (2007). Experimental investigation on acclimated wastewater for membrane bioreactors. *Desalination.* 207: 383-391.

Haigler, C. (1985). *The functions and biogenesis of native cellulose, in cellulose chemistry and its application*. West Sussex, England: Ellis Horwood, Chichester.

Hajiabadi, H. (2009). Effect Of Sludge Retention Time On Treating High Load Synthetic Wastewater Using Aerobic Sequencing Batch Reactors. *Iranian Journal of Environ. Health Sci. Eng.* 6(4): 217–222.

Hall, K., Eagleton, L., Acrivos, A. & Vermeulen, T. (1966). Pore and solid diffusion kinetics in fixed bed adsorption under constant pattern conditions. *Ind. Eng. Chem. Fundam.* 5: 212-217.

He, S., Xue, G., Kong, H., & Li, X. (2007). Improving the performance of sequencing batch reactor (SBR) by the addition of zeolites powder. *Journal of Hazardous Materials*. 142(1-2): 493–9.

Higuchi, T. (1980). *Lignin biodegradation: microbiology, chemistry, and potential applications*. (T. K. Kirk, T. Higuchi, & H. Chang, Eds.) (Vol. 1, p. 256). Florida: CRC Press.

Huda, A. H. N., Tajuddin, R. M., Ahmad, Z., & Nazrin, O. M. (2012). Determination of optimum debark time in retting process of kenaf fibre production. *International Sustainabilty and Civil Engineering Journal.* 1(2): 14–18.

© COPYRIGHT UPM

Igbinosa, O., Igbinosa, E. & Aiyegoro, O. (2009). Antimicrobial activity and phytochemical screening of stem bark extracts from Jatropha curcas (Linn). *African Journal of Pharmacy and Pharmacology*. 3(2): 58-62.

Inglezakis, V. & Poulopoulos, S. (2006). *Adsorption, ion exchange and catalysis: Design of Operations and Environmental Applications*. Elsevier Science & Technology.

Irvine, R. & Ketchum Jr., L. (1989). Sequencing batch reactors for biological wastewater treatment. *CRC Critical Reviews in Environmental Control.* 18(4): 225-294.

Jahn, S. (1988). Using Moringa seeds as coagulants in developing countries. *J. Am. Wat. Wks. Assoc*.80: 43-50.

Jahn, S. (1991). The traditional domestication of a multipurpose tree Moringa Stenopetala in Ethiopian Rift Valley. *Ambio*. 20: 244-247.

Jongschaap, R. et al. *The water footprint of bio energy from Jatropha curcas*. Proceedings of the National Academy of Sciences of the United States of America, 1 September, 106(35), 2009.

Junkins, R., Deeny, K. & Eckhoff, T. (1983). *The activated sludge process: Fundamentals of Operation*. Pennsylvania: Ann ArborScience Publisher.

Kaldor, A., Karlgren, C. & Verwest, H. (1990). Kenaf - a fast growing fiber source for papermaking. *TAPPI.* 73: 205-208.

Kapoor, A. & Yang, R. (1989). Correlation of equilibrium adsorption data of condensable vapours on porous adsorbents. *Gas Sep. Purif*. 3: 187-192.

Kulikowska, D., Klimiuk, E., & Drzewicki, A. (2007). BOD_5 and COD removal and sludge production in SBR working with or without anoxic phase. *Bioresource Technology*. 98(7): 1426–32.

Lee, B., Choo, K., Chang, D., & Choi, S. (2009). Optimizing the coagulant dose to control membrane fouling in combined coagulation/ultrafiltration systems for textile wastewater reclamation. *Chemical Engineering Journal*. 155(1-2): 101–107.

Lee, J.-W., Choi, S.-P., Thiruvenkatachari, R., Shim, W.-G., & Moon, H. (2006). Submerged microfiltration membrane coupled with alum coagulation/powdered activated carbon adsorption for complete decolorization of reactive dyes. *Water Research*. 40(3): 435–44.

Lembaga Kenaf dan Tembakau Negara. (2009). Pengeluaran Kenaf 2009. Retrieved April 16, 2013, from http://www.lktn.gov.my/page.php?102

Lewis, D., Kollig, H. & Hodson, R. (1986). Nutrient limitation and adaptation of microbial populations to chemical transformations. *Appl. Environ. Microbiol.* 51: 598-603.

© COPYRIGHT UPM

Li, A., Li, X., & Yu, H. (2011). Effect of the food-to-microorganism (F/M) ratio on the formation and size of aerobic sludge granules. *Process Biochemistry*. 46(12): 2269–2276.

Li, Y., Liu, Y., & Xu, H. (2008). Is sludge retention time a decisive factor for aerobic granulation in SBR? *Bioresource Technology*. 99(16): 7672–7.

Lim, P.-E., Lim, S.-P., Seng, C.-E., & Noor, A. M. (2010). Treatment of landfill leachate in sequencing batch reactor supplemented with activated rice husk as adsorbent. *Chemical Engineering Journal*. 159(1-3): 123–128.

Limousin, G. et al., 2007. Sorption Isotherms: a review on physical bases, modeling and measurement. *Appl. Geochem*. 249-275.

Limousin, G., Gaudet, J.-P., Charlet, L., Szenknect, S., Barthès, V., & Krimissa, M. (2007). Sorption isotherms: A review on physical bases, modeling and measurement. *Applied Geochemistry*. 22(2): 249–275.

Lin, S. H., & Cheng, K. W. (2001). A new sequencing batch reactor for treatment of municipal sewage wastewater for agricultural reuse. *Desalination*. 133(1): 41–51.

Lin, S. H., & Jiang, C. D. (2003). Fenton oxidation and sequencing batch reactor (SBR) treatments of high-strength semiconductor wastewater. *Desalination*. 154(2): 107–116.

LTKN, 2014. Lembaga Kenaf dan Tembakau Negara. [Online]

Ma, J., & Liu, W. (2002). Effectiveness and mechanism of potassium ferrate (VI) preoxidation for algae removal by coagulation. *Water Research*. 36(4): 871–878.

Makkar, H., Becker, K., Sporer, F. & Wink, M. (1997). Studies on nutritive potential and toxic constituents of different provenances of Jatropha curcas. J. *Agric. Food. Chem.* 45: 3152-3157.

Mane, V., Mall, I. & Srivastava, V. (2007). Kinetic and equilibrium isotherm studies for the adsorptive removal of Brilliant Green dye from aqueous solution by rice husk ash. *J. Environ. Manage*. 84: 390-400.

Marañón, E. (2010). Colour, turbidity and COD removal from old landfill leachate by coagulation-flocculation treatment. *Waste Management* & Research. 28(8): 731–737.

McCabe, W., Smith, J. & Harriot, P. (1993). *Unit operation of chemical engineering*. 5th ed. New York: McGraw-Hill.

Metcalf & Eddy, Inc. (1991). *Wastewater Engineering: treatment, disposal & reuse*. 3 ed. Singapore: McGraw-Hill Inc.

Mignoni, G. (1994). *Il kenaf, non solo una nuova materia prima cellulosica*. ISMEA,

© COPYRIGHT UPM

Roma.

Mohammed, M. (1989). *Characterization and treatment of a petrochemical wastewater for reuse*. King Fadh University of Petroleum and Minerals, Saudi Arabia.

Mondal, D. K. & Kaviraj, A. (2008). Ecotoxicological effects of jute retting on the survival two freshwater fish and two invertebrates. *Ecotoxicology*. 17: 207-211.

Mor, S., Ravindra, K., & Bishnoi, N. R. (2007). Adsorption of chromium from aqueous solution by activated alumina and activated charcoal. *Bioresource Technology*. 98(4): 954–7.

Moreno, G. & Buitron, G. (2004). Influence of the origin of the inoculum and the acclimation strategy on the degradation of 4-chlorophenol. *Bioresource technology*. 94: 215-218.

Morrison III, W. H., Akin, D. E., Archibald, D. D., Dodd, R. B., & Raymer, P. L. (1999). Chemical and instrumental characterization of maturing kenaf core and bast. *Industrial Crops and Products*. 10(1): 21–34.

Morrison, W. H., Akin, D. E., Ramaswamy, G., & Baldwin, B. (1996). Evaluating Chemically Retted Kenaf Using Chemical, Histochemical, and Microspectrophotometric Analyses. *Textile Research Journal*. 66(10): 651–656.

Moussavi, G., & Khosravi, R. (2010). Removal of cyanide from wastewater by adsorption onto pistachio hull wastes: parametric experiments, kinetics and equilibrium analysis. *Journal of Hazardous Materials*. 183(1-3): 724–30.

Muyibi, S. & Evison, L. (1996). Coagulation of turbid water and softening of hard water with Moringa Oleifera seeds. *Int. J. Environ. Stud*. 49: 247-259.

Muyibi, S. & Okuofu, C. (1995). Coagulation of low turbidity surface water with Moringa oleifera seeds. *Int. J. Environ. Stud*. 48: 263-273.

Ndabigengesere, A. & Narasiah, K. (1998). Quality of water treated by coagulation using Moringa Oleifera seeds. *Water Res*. 781-791.

Ndabigengesere, A., Narasiah, K. S. & Talbot, B. G., 1995. Active agents and mechanism of coagulation of turbid waters using Moringa oleifera. *Wat. Res*. 29(2): 703-710.

Ng, H. (2002). *Performance of a membrane reactor and completely mixed activated sludge system at short solid retention times*, Berkeley: University of California, California, USA.

Ng, J., Cheung, W. & McKay, G. (2002). Equilibrium studies of the sorption of Cu(II) ions onto chitosan. *J. Colloid Interface Sci*.255: 64-74.

Nicholas, P. & Paul, N. (1993). *Carbon adsorption for Pollution Control*. Englewood Cliffs, New Jersey: PTR Prentice-Hall Inc.

© COPYRIGHT UPM

Nieschlag, H., Nelson, G., Wolff, I. & R.E. Perdue, J. (1960). A search for new fiber crops. *TAPPI*. 43: 193-201.

Nishimura, N., Izumi, A., & Kuroda, K. (2002). Structural characterization of kenaf lignin: differences among kenaf varieties. *Industrial Crops and Products.* 15(2): 115–122.

Norulaini, N., & Zuhair, A. (2001). Chemical Coagulation Of Settleable Solid-Free Palm Oil Mill Effluent (POME) For Organic Load Reduction. *Journal of Industrial* . 10(1): 55–72.

Ogawa, T., Idaka, E., & Yatome, C. (1981). Acclimation of activated sludge to dye. *Bulletin of Environmental Contamination and Toxicology.* 26(1), pp 31–37.

Özbelge, T. a., Özbelge, H. Ö., & Altınten, P. (2007). Effect of acclimatization of microorganisms to heavy metals on the performance of activated sludge process. *Journal of Hazardous Materials*. 142(1-2): 332–339.

Paliwal, R., Sharma, V. & Pracheta (2011). A Review on Horse Radish Tree (Moringa Oleifera): a multipurpose tree with high Economic and Commercial Importance. *Asian Journal of Biotechnology*. 3(4): 317-328.

Perez-Marin, A. et al., 2007. Removal of cadmium from aqueous solutions by adsorption onto orange waste. *J. Hazard. Mater*. B139: 122-131.

Popinigis, F. (1985). Fisiologia da semente. Brasilia: Agiplan.

Prasad, R. & Srivastava, S., 2009. Sorption of distillery spent washonto fly ash: kinetic and mass transfer studies. *Chem. Eng. J*. 146(1): 90-97.

Ramaswamy, G. N., Ruff, C. G., & Boyd, C. R. (1994). Effect of Bacterial and Chemical Retting on Kenaf Fiber Quality. *Textile Research Journal*. 64(5): 305–308.

Reza, M. & Seyedeh, M. B. (2011). Removal of orange 7 dye from wastewater used by natural absorbent of Moringa oleifera seeds. *American Journal of Environmental Engineering.* 1(1): 1-9.

Richmond, M. (1968). Enzymic adaptation in bacteria: its biochemical and genetic basis. *Essays Biochem*. 4: 105-154.

Rittmann, B. (1987). A critical evaluation of soluble microbial formation in biological processes. *Water Sci. Technol*. 19: 517-528.

Samudro, G. & Mangkoedihardjo, S. (2010). Review on BOD, COD and BOD/COD ratio: a triangle zone for toxic, biodegradable and stable level. *International Journal of Academic Research.* 2(4): 235-239.

Scmidt, E., Hellwig, M. & Knackmuss, H. (1983). Degradation of chlorophenols by a defined mixed microbial community. *Appl. Environ. Microbiol*. 46: 1038-1044.

© COPYRIGHT UPM

Sinsabaugh, R., Hoehn, R., Knocke, W. & Linlins, A. (1986). Removal of dissolved organic carbon by coagulation with iron sulfate. *J. Am. Wat. Wks. Assoc*. 78(5): 74-82.

Sips, R. (1948). Combined form of Langmuir and Freundlich equations. *J. Chem. Phys*. 16: 490-498.

Sirianuntapiboon, S., & Sansak, J. (2008). Treatability studies with granular activated carbon (GAC) and sequencing batch reactor (SBR) system for textile wastewater containing direct dyes. *Journal of Hazardous Materials*. 159(2-3): 404–11.

Skoulikides, T. (1989). *Physical chemistry I* 1.2. Athens, Greece: Symetria Editions.

Šostar-Turk, S., PetriniÄ‡, I., & SimoniÄ•, M. (2005). Laundry wastewater treatment using coagulation and membrane filtration. *Resources, Conservation and Recycling*. 44(2): 185–196.

Spain, J., Pritchard, P. H. & Bourquin, A. (1980). Effects of adaptation on biodegradation rates in sediment/water cores from estuarine and freshwater environments. *Appl. Environ. Microbiol*. 40: 726-734.

Stephenson, J., R. & Duff, S. J. (1996). Coagulation and precipitation of a mechanical pulping effluent-I: Removal of carbon, colour, and turbidity. *Wat. Res*. 30(4): 781-792.

Stephenson, T., Lester, J. & Perry, R., 1984. Acclimatisation to nitrilotriacetic acid in the activated sludge process. *Chemosphere*. 13: 1033-1040.

Suzuki, M. (1990). *Adsorption Engineering*. Tokyo, Japan: Elsevier.

Tebbutt, T. (1997). *Principles of water quality control*. 5 ed. s.l.:Butterworth-Heinemann.

Torstensson, N., Stark, J. & Goransson, B. (1975). The effect of repeated applications of 2,4-D and MCPA on their breakdown in soil. *Weed Res*.15: 159-154.

Toth, J. (1971). State equations of the solid gas interface layer. *Acta. Chem. Acad. Hung*. 69: 311-317.

Valverde, K. C., Moraes, L. C. K., Bongiovani, M. C., Camacho, F. P., & Bergamasco, R. (2013). Coagulation diagram using the Moringa oleifera Lam and the aluminium sulphate, aiming the removal of color and turbidity of water. *Acta Scientiarum. Technology*. 35(3): 485–489.

Vashon, R., Jones, W. & Payne, A. (1982). The effect of water hardness on nitrilotriaceate removal and microbial acclimation in activated sludge. *Water Res*.16: 1429-1432.

Ventullo, R. & Larson, R. (1986). Adaptation of aquatic communities to quaternary

© COPYRIGHT UPM

ammonium compounds. *Appl. Environ. Microbiol*. 51: 356-361.

Verma, S., Prasad, B. & Mishra, I. M. (2010). Pretreatment of petrochemical wastewater by coagulation and flocculation and sludge characteristic. *Journal of Hazardous Material.* 178: 1055-1064.

Vijayaraghavan, K., Padmesh, T., Palanivelu, K. & Velan, M. (2006). Biosorption of Nickel (II) into Sargassum Wightii: application of two-parameter and three parameter isotherm models. *J. Hazard. Mater.* B133: 304-308.

Waber, W. & Morris, J. (1963). Kinetic of adsorption on carbon solution. *J. Sanit. Eng. Div. Am. Soc. Civ. Eng*. 89: 31-59.

Walker, R. & Newman, A. (1956). Microbial decomposition of 2,4-dichlorophenoxyacetic acid. *Appl. Microbiol.* 4: 201-206.

Wang, Z. et al. (2002). Landfill leachate treatment by a coagulation-photooxidation process. *J. Hazardous Mater*. 95: 153-159.

Wanner, J. (1992). Comparison of biocenoses from continuous and sequencing batch reactors. *Water Science and Technology*. 25(6): 239-249.

Warren, L., Julian, C. & Harriot, P. (1982). *Unit Operation of Chemical Engineering*. s.l.:McGraw-Hill International Edition.

Watson, H. (1993). A comparison of the effects of two methods of acclimation on aerobic biodegradability. *Environmental toxicology and chemistry*. 12: 2023-2030.

Webber III, C., & Bledsoe, V. (2002). Kenaf yield components and plant composition. *Trends in New Crops and New Uses*, pp. 348–357.

Weber, W. (1972). *Physicochemical Processes for Water Quality Control.* New York, USA: Wiley Interscience.

White, G. et al. (1970). *Cultural and harvesting methods for Kenaf.* Washington D.C.: USDA Prod. Res. Rpt.

Wiggins, B. A., Jones, S. H. & Alexander, M. (1987). Explanations for the Acclimation Period Preceding the Mineralization of Organic Chemicals in the Aquatic Environment. *Applied and Environmental Microbiology.* 791-796.

Wilderer, P., Irvine, R. & Goronszy, M. (2001). *Sequencing Batch Reactor Technology.* London: IWA Publishing.

Yonge, D. & Keinath, T. (1986). The effects of non-ideal competition on multi-component adsorption equilibria. *J. Water Pollut. Control Fed*. 58: 77-81.

Yonge, D., Keinath, T., Poznanska, K. & Jiang, Z. (1985). Single-solute irreversible adsorption on granular activated carbon. *Environ. Sci. Technol*. 19: 690-694.

Yu, H., & Yu, C. (2007). Study on microbe retting of kenaf fiber. *Enzyme and*

© COPYRIGHT UPM

Microbial Technology. 40(7): 1806–1809.

Yu, H., & Yu, C. (2010). Influence of various retting methods on properties of kenaf fiber. *Journal of the Textile Institute*. 101(5): 452–456.

Zhang, J. et al., 2005. The active component in the flax-retting system of the zygomycete rhizopus oryzae sb is a family 28 polygalacturonase. *J. Ind. Microbial. Biotechnol*. 32: 431-438.

Zhou, Y., Liang, Z., & Wang, Y. (2008). Decolorization and COD removal of secondary yeast wastewater effluents by coagulation using aluminum sulfate. *Desalination.* 225(1-3): 301–311.

Zhou, Y., Xing, X.-H., Liu, Z., Cui, L., Yu, A., Feng, Q., & Yang, H. (2008). Enhanced coagulation of ferric chloride aided by tannic acid for phosphorus removal from wastewater. *Chemosphere.* 72(2): 290–8.

© COPYRIGHT UPM