



UNIVERSITI PUTRA MALAYSIA

***OPTIMAL LOCATION AND SIZE OF DISTRIBUTED GENERATION
TO REDUCE POWER LOSSES AND IMPROVE VOLTAGE PROFILES
USING DIFFERENTIAL EVOLUTION OPTIMIZATION METHOD***

AHMED SAHIB HAMMADI

FK 2016 126



**OPTIMAL LOCATION AND SIZE OF DISTRIBUTED GENERATION
TO REDUCE POWER LOSSES AND IMPROVE VOLTAGE PROFILES
USING DIFFERENTIAL EVOLUTION OPTIMIZATION METHOD**

By

AHMED SAHIB HAMMADI

**Thesis Submitted to the School of Graduate Studies, Universiti Putra
Malaysia, in Fulfillment of the Requirements for the Degree of
Master of Science**

October 2016

COPYRIGHT

All material contained within the thesis, including without limitation text, logos, icons, photographs and all other artwork, is copyright material of Universiti Putra Malaysia unless otherwise stated. Use may be made of any material contained within the thesis for non-commercial purposes from the copyright holder. Commercial use of material may only be made with the express, prior, written permission of Universiti Putra Malaysia.

Copyright © Universiti Putra Malaysia



DEDICATION

I dedicate this thesis to my father and my mother, loving wife, Qamar, my sons, Zain Alabdeen, Abdollah and Yusur, for continually evaluating and inspiring me to work hard in my studies; my brothers, Dr. Ayad, Dr. Haydar, Dr. Alaa and Eng. Walled and my sisters, Dr. Suhad, Awrad and Eng. Mehad and their spouses and children for their encouragement and prayers for me, without forgetting my in-laws, and particularly Eng. Zainabmy and my best friends in my country. I thank Almighty Allah every day for blessing me with you and I love you all very much.



Abstract of thesis presented to the Senate of Universiti Putra Malaysia in fulfillment of the requirement for the Degree of Master of Science

OPTIMAL LOCATION AND SIZE OF DISTRIBUTED GENERATION TO REDUCE POWER LOSSES AND IMPROVE VOLTAGE PROFILES USING DIFFERENTIAL EVOLUTION OPTIMIZATION METHOD

By

AHMED SAHIB HAMMADI

October 2016

Chairman : Associate Professor Noor Izzri Abdul Wahab, PhD
Faculty : Engineering

There are numerous advantages that can be obtained when Distributed Generation (DG) is integrated into the distribution systems. These advantages include improving the voltage profiles and reducing the power losses of the distribution system. Such advantages can be accomplished and confirmed if the DG units are optimally located and sized in the distribution systems. In fact, there are several algorithms used for optimizing the size and finding the best location to install DG units in the power system. Some existing algorithms need to be improved while others, need to add a new parameter for improving the performance of optimization methods and making it more effective and efficient. This research aimed to reduce both total real and reactive power losses and improve voltage profiles of the distribution system by proposing a differential evolution (DE) algorithm to optimize DG size and location by taking into consideration different types of DG units. The multi-objective function, which represents the summation of product five indices by corresponding weights, was utilized to identify the candidate buses to reduce the search space of the algorithm. The suggested algorithm of DE was tested using IEEE 30 bus test system and IEEE 57 bus test system taking into consideration three types of DG units. The results obtained by using the DE method were compared with those obtained by genetic algorithm (GA) method. It was observed that the DE method gives a better result in terms of improving the voltage profile and reducing real and reactive power losses compared to GA method. In the IEEE 30 bus test system, the percentages of reduction in the real power losses obtained by the DE method were 20.58 %, 22.08 % and 20.40 % compared with 15.03 %, 16.81 % and 19.66 % obtained by the GA method for type 1, type 2 and type 3 respectively, while the percentages of reduction in the reactive power losses were 23.28 %, 19.20 % and 23.14 % by using the DE method compared with 17.01 %, 14.41 % and 22.49 % by using the GA method for type 1, type 2 and type 3 respectively. The voltage profile of the system also improved after optimizing DG sizes and locations using the DE method. However, in the IEEE

57 bus test system, the percentages of reduction in the real power losses were 17.08 %, 21.53 % and 20.20 % by DE method compared with 16.72 %, 15.91 % and 16.86 % by the GA method for type 1, type 2 and type 3, while the percentages of reduction in the reactive power loss were 9.64 %, 11.67 % and 9.42 % by DE method compared with 9.32 %, 10.81 % and 9.08 % by the GA method for three types of DG units respectively.



Abstrak tesis yang dikemukakan kepada Senat Universiti Putra Malaysia
sebagai memenuhi keperluan untuk Ijazah Master Sains

**LOKASI DEN SAIZ OPTIMUM PENJANA TERAGIT UNTUK
MENINGKATKAN KEHILANGAN KUASA DAN MEMPERBAIKI PROFIL
VOLTAN DENGAN MENGGUNAKAN KAEDAH EVOLUSI
PENGOPTIMUMAN PENGKAMIRAN**

Oleh

AHMED SAHIB HAMMADI

Oktober 2016

Pengerusi : Profesor Madya Noor Izzri Abdul Wahab, PhD
Fakulti : Kejuruteraan

Terdapat banyak kebaikan yang boleh diperolehi apabila Distribution Generation (DG) disepadukan ke dalam sistem pengedaran. Kebaikan yang paling utama adalah menambah baik penjaan profil voltan dan mengurangkan kehilangan kuasa sistem pengagihan. Banyak kebaikan boleh dicapai dan disahkan jika unit DG diletak secara optimum dan ditempatkan dengan sistematik dalam sistem pengedaran. Malah, terdapat beberapa algoritma yang digunakan untuk mengoptimumkan saiz dan mencari lokasi yang lebih baik untuk memasang unit DG dalam sistem kuasa. Beberapa algoritma yang sedia ada perlu diperbaiki dan diubahsuai manakala yang lain perlu dinaik tarafkan dan ditambahkan dengan parameter baru untuk meningkatkan prestasi kaedah pengoptimuman dan menjadikannya lebih berkesan dan cekap. Kajian ini bertujuan untuk mengurangkan kedua-dua jumlah kehilangan kuasa sebenar dan reaktif dan meningkatkan profil voltan sistem pengagihan dengan mencadangkan algoritma pengkamiran evolusi (DE) bagi mengoptimumkan saiz DG dan lokasi dengan mengambil kira jenis unit DG. Fungsi pelbagai objektif, yang mewakili penjumlahan produk lima indeks mengikut wajaran sama telah digunakan untuk mengenal pasti kaedah 'buses' untuk mengurangkan ruang carian algoritma. Algoritma DE yang dicadangkan telah diuji menggunakan IEEE 30 'bus' sistem ujian dan sistem IEEE 57 ujian 'bus' yang mengambil kira tiga jenis unit DG. Keputusan yang diperolehi dengan menggunakan kaedah DE itu kemudiannya dibandingkan dengan keputusan diperolehi daripada kaedah algoritma genetik (GA). Kajian ini terbukti bahawa kaedah DE dapat memberikan hasil yang lebih baik dari segi meningkatkan profil voltan dan mengurangkan kehilangan kuasa sebenar dan reaktif berbanding kaedah GA. Dalam IEEE 30 'bus' sistem ujian, peratusan pengurangan kehilangan kuasa sebenar yang diperolehi dengan kaedah DE tersebut ialah 20.58%, 22.08% dan 20.40% berbanding dengan 15.03%, 16.81% dan 19.66% yang diperolehi dengan kaedah GA untuk jenis 1, jenis 2 dan jenis 3 masing-masing. Manakala peratusan pengurangan

kehilangan kuasa reaktif adalah 23.28%, 19.20% dan 23.14% dengan menggunakan kaedah DE berbanding dengan 17.01%, 14.41% dan 22.49% dengan menggunakan kaedah GA untuk jenis 1, jenis 2 dan jenis 3 masing-masing. Profil voltan sistem juga bertambah baik selepas mengoptimumkan saiz DG dan lokasi menggunakan kaedah DE tersebut. Walau bagaimanapun, dalam IEEE 57 'bus' sistem ujian, peratusan pengurangan kehilangan kuasa sebenar adalah 17.08%, 21.53% dan 20.20% dengan kaedah DE berbanding dengan 16.72%, 15.91% dan 16.86% dengan menggunakan kaedah GA untuk jenis 1, jenis 2 dan jenis 3. Manakala peratusan pengurangan kehilangan kuasa reaktif adalah 9.64%, 11.67% dan 9.42% dengan mengaplikasi kaedah DE berbanding dengan 9.32%, 10.81% dan 9.08% dengan kaedah GA bagi tiga jenis unit DG masing-masing.



ACKNOWLEDGEMENTS

One of the most important achievements in my life is the completion of my master's degree at Universiti Putra Malaysia (UPM), one of Malaysia's and the region's premier research universities. This matters study would not have been achieved without the help and blessing of Almighty Allah so I would like to thank him for all he has given me.

I am also deeply grateful to my supervisor and guide, **Dr. Noor Izzri Abdul Wahab** for his understanding, guidance, continuous intellectual support, and patience throughout the research work. He was very generous in sharing his knowledge, his time and provided constant encouragement for the duration of my study period.

I extend my thanks to my committee member, **Dr. Mohammad Lutfi** for his suggestions and for reviewing my thesis.

I would like to recognize the financial support of the Government of Iraq through the Ministry of Higher Education and Scientific Research and the University of Karbalaa. Great thankfulness goes with it for giving me the opportunity to complete my study.

My special thanks go to my family, especially to my beloved parents, my loving wife and my sons, who have been indispensable and an important source of inspiration and motivation.

I certify that a Thesis Examination Committee has met on 17 October 2016 to conduct the final examination of Ahmed Sahib Hammadi on his thesis entitled "Optimal Location and Size of Distributed Generation to Reduce Power Losses and Improve Voltage Profiles using Differential Evolution Optimization Method" in accordance with the Universities and University Colleges Act 1971 and the Constitution of the Universiti Putra Malaysia [P.U.(A) 106] 15 March 1998. The Committee recommends that the student be awarded the Master of Science.

Members of the Thesis Examination Committee were as follows:

Suhaidi bin Shafie, PhD


Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Nashiren Farzilah binti Mailah, PhD

Senior Lecturer
Faculty of Engineering
Universiti Putra Malaysia
(Internal Examiner)

Vigna Kumaran a/l Ramachandaramurthy, PhD

Professor Ir.
Universiti Tenaga Nasional
Malaysia
(External Examiner)



NOR AINI AB. SHUKOR, PhD

Professor and Deputy Dean
School of Graduate Studies
Universiti Putra Malaysia

Date: 22 November 2016

This thesis was submitted to the Senate of the Universiti Putra Malaysia and has been accepted as fulfillment of the requirement for the degree of Master of Science. The members of the Supervisory Committee were as follows:

Noor Izzri Abdul Wahab, PhD

Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Mohammad Lutfi bin Othman, PhD

Senior Lecturer
Faculty of Engineering
Universiti Putra Malaysia
(Member)

BUJANG BIN KIM HUAT, PhD

Professor and Dean
School of Graduate Studies
Universiti Putra Malaysia

Date:

Declaration by graduate student

I hereby confirm that:

- this thesis is my original work;
- quotations, illustrations and citations have been duly referenced;
- this thesis has not been submitted previously or concurrently for any other degree at any institutions;
- intellectual property from the thesis and copyright of thesis are fully-owned by Universiti Putra Malaysia, as according to the Universiti Putra Malaysia (Research) Rules 2012;
- written permission must be obtained from supervisor and the office of Deputy Vice-Chancellor (Research and innovation) before thesis is published (in the form of written, printed or in electronic form) including books, journals, modules, proceedings, popular writings, seminar papers, manuscripts, posters, reports, lecture notes, learning modules or any other materials as stated in the Universiti Putra Malaysia (Research) Rules 2012;
- there is no plagiarism or data falsification/fabrication in the thesis, and scholarly integrity is upheld as according to the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) and the Universiti Putra Malaysia (Research) Rules 2012. The thesis has undergone plagiarism detection software

Signature: _____ Date: _____

Name and Matric No.: Ahmed Sahib Hammadi / GS 41272

Declaration by Members of Supervisory Committee

This is to confirm that:

- the research conducted and the writing of this thesis was under our supervision;
- supervision responsibilities as stated in the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) were adhered to.

Signature: _____

Name of Chairman
of Supervisory
Committee:

Associate Professor Dr. Noor Izzri Abdul Wahab

Signature: _____

Name of Member
of Supervisory
Committee:

Dr. Mohammad Lutfi bin Othman

TABLE OF CONTENTS

		Page
ABSTRACT		i
ABSTRAK		iii
ACKNOWLEDGEMENTS		v
APPROVAL		vi
DECLARATION		viii
LIST OF TABLES		xiii
LIST OF FIGURES		xv
LIST OF ABBREVIATIONS		xvii
CHAPTER		
1	INTRODUCTION	1
	1.1 Background	1
	1.2 Problem Statement	2
	1.3 Research Objectives	3
	1.4 The Scope of Work	3
	1.5 Organization of the Thesis	4
2	LITERATURE REVIEW	5
	2.1 Introduction	5
	2.2 Distributed Generation	5
	2.2.1 Distributed Generation Benefits	8
	2.2.2 Distributed Generation Injection Model	9
	2.2.3 Optimum Location of Distributed Generation	9
	2.2.4 Optimum Size of Distributed Generation	10
	2.2.5 Effect of DG on the Performs of Distribution System	10
	2.2.5.1 Impacts of DG on the Voltage Profile	11
	2.2.5.2 Impacts of DG on the Power Losses	12
	2.2.5.3 Impacts of DG on the Short circuit level	13
	2.3 Multi-Objective Function for Optimal DG Location and Size	14
	2.3.1 Multi-Objective Optimization Methods	14
	2.4 Optimization Approaches for DG Location and Size	16
	2.4.1 Conventional Techniques for Optimization DG	17
	2.4.2 Artificial Intelligence Techniques for DG Optimization	18
	2.4.2.1 Fuzzy Logic for DG Optimization	19
	2.4.2.2 Neural Network Techniques for DG Optimization	20
	2.4.2.3 Evolutionary Computation Techniques for DG Optimization	20

	2.4.3	Hybrid Optimization Techniques	23
	2.5	Summary	25
3		METHODOLOGY	26
	3.1	Introduction	26
	3.2	Overall Flowchart	26
	3.3	Power Flow Analysis	29
	3.4	Objective Function Parameters	32
	3.4.1	Real Power Loss Reduction Index	32
	3.4.2	Reactive Power Loss Reduction Index	32
	3.4.3	Voltage Deviation Index	33
	3.4.4	Line Loading Capacity Index	33
	3.4.5	Short Circuit Index	33
	3.5	Multi-objective Function Formulation	34
	3.6	Operational Constraints	35
	3.6.1	Equality Constraints	35
	3.6.2	Inequality Constraints	36
	3.7	Genetic Algorithm Technique	37
	3.7.1	Parameters of GA for DG allocation	38
	3.7.1.1	Coding Planned	38
	3.7.1.2	Initialization	38
	3.7.1.3	Reproduction	38
	3.7.1.4	Crossover	39
	3.7.1.5	Mutation	40
	3.7.1.6	Elitism	40
	3.7.2	Implementation Steps of GA for DG Allocation	41
	3.8	Differential Evolution Techniques	43
	3.8.1	Parameters of DE for DG Allocation	44
	3.8.1.1	Initialization	44
	3.8.1.2	Mutation	45
	3.8.1.3	Crossover	45
	3.8.1.4	Selection	46
	3.8.2	Implementation Steps of DE for DG Allocation	46
	3.9	Differences between DE and GA Methods	49
	3.10	Summary	49
4		RESULTS AND DISCUSSION	50
	4.1	Introduction	50
	4.2	Test Systems Description	50
	4.2.1	IEEE 30-bus Test System	50
	4.2.2	IEEE 57 bus Test System	51
	4.3	Determine the Corresponding Weights Values for Indices	53
	4.4	Cases Studies and Optimization Parameters	54
	4.5	Results Considering 30-Bus Test System	55
	4.5.1	Results Considering Base Case	55
	4.5.2	Results Considering Type 1	57

4.5.2.1	Voltage Profile of System with Type 1 DG	59
4.5.3	Results Considering Type 2 DG	60
4.5.3.1	Voltage Profile of System with Type 2 DG	63
4.5.4	Results Considering Type 3 DG	64
4.5.4.1	Voltage Profile of System with Type 3 DG	67
4.6	Comparison of power losses and voltage profile of 30-bus test system	68
4.7	Results Considering 57-Bus Test System	70
4.7.1	Results Considering Base Case	71
4.7.2	Results Considering Type 1 DG	72
4.7.3	Results Considering Type 2 DG	74
4.7.4	Results Considering Type 3 DG	76
4.8	Comparison of the Power Losses of 57-Bus System	78
4.9	Comparison of the Voltage Profiles of 57-Bus System	80
4.10	Summary	82
5	CONCLUSION AND RECOMMENDATIONS FOR FUTURE WORK	83
5.1	Conclusion	83
5.2	Recommendations for Future Work	84
	REFERENCES	86
	APPENDICES	95
	BIODATA OF STUDENT	105
	LIST OF PUBLICATIONS	106

LIST OF TABLES

Table		Page
2.1	Distributed generation relative size	7
2.2	The general model of DG used in the power system analysis	9
4.1	Set of weights with corresponding fitness values	54
4.2	Parameters of GA and DE methods	55
4.3	Voltage profile of Base case for 30-bus system	56
4.4	Optimal size with associated fitness values for type 1 DG unit	57
4.5	Comparison of power losses for 30-bus system with Type 1 DG	58
4.6	Optimal location details of 30-bus system with Type 1 DG unit	58
4.7	Voltage profile of 30-bus system with Type 1 DG unit	59
4.8	Optimal size with associated fitness values of Type 2 DG	61
4.9	Comparison of power losses of 30-bus system with Type 2 DG	62
4.10	Optimal location details of 30-bus system with Type 2 DG unit	62
4.11	Voltage profile of 30-bus system with Type 2 DG unit	63
4.12	Optimal size with associated fitness values of Type 3 DG	65
4.13	Comparison of power losses for 30-bus system with Type 3 DG	66
4.14	Optimal location details of 30-bus system with Type 3 DG unit	66
4.15	Voltage profile of 30-bus system with Type 3 DG unit	67
4.16	Power losses comparison of 30-bus system with 3 types of DG	68
4.17	Voltage profile of 57-bus system without DG	72
4.18	Optimal size with associated fitness values of Type 1 DG	73

4.19	Comparison of power losses of 57-bus system with Type 1 DG	74
4.20	Optimal location details of 57-bus system with Type 1 DG unit	74
4.21	Optimal size with associated fitness values of Type 2 DG	75
4.22	A comparison of Results obtained using Type 2 DG	76
4.23	Optimal location details of 57-bus system with Type 2 DG unit	76
4.24	Optimal size with associated fitness value of Type 3 DG	77
4.25	Comparison of power losses of 57-bus system with Type 3 DG	78
4.26	Optimal location details of 57-bus system with Type 3 DG unit	78
4.27	Totally real and reactive power losses of 57-bus system with different types of DG unit	79
4.28	Lowest Bus Voltages for different types of DG	80
4.29	Highest Bus Voltages for different types of DG	81

LIST OF FIGURES

Table		Page
2.1	Traditional electric power systems	6
2.2	Benefits of DG units	8
2.3	Power flow of the power systems (A) without DG, (B) with DG units	11
2.4	Contributions of DG units in the fault current of the system	13
2.5	Optimization techniques used to find an optimal DG allocation	17
3.1	Overall Flow Chart of methodology	28
3.2	Flowchart of Newton Raphson load flow method.	31
3.3	Block diagram of basic GA	37
3.4	Chromosome length with two and three optimization variable	38
3.5	Crossover operations	39
3.6	Flowchart of DG allocation with basic genetic algorithm	42
3.7	Block diagram of DE algorithm	43
3.8	Flowchart of DG allocation with DE method	48
4.1	Single line representation of IEEE 30-bus system	51
4.2	Single line representation of IEEE 57-bus system	52
4.3	Voltage Profile of Base Case for 30-bus Test System	56
4.4	Voltage Profile of 30 Bus Systems with Type 1 DG at Bus 21	60
4.5	Voltage profile of 30 bus system with Type 2 DG at bus 28	64
4.6	Voltage Profile of 30 Bus System with Type 3 DG at Bus 23	68
4.7	A Comparison of real power losses of 30-bus system with different types of DG.	69
4.8	A Comparison of reactive power losses of 30-bus system with different types of DG	69

4.9	Comparison of Voltage profiles with different types of DG	70
4.10	Voltage profiles of 57-bus system without DG	71
4.11	A Comparison of real power losses of 57-bus system with three Types of DG	79
4.12	A Comparison of reactive power losses of 57-bus system with three Types of DG	80
4.13	The Lowest Bus Voltages for Different Types of DG	81
4.14	The Highest Bus Voltages for Different Types of DG	82



LIST OF ABBREVIATIONS

ABC	Artificial Bee Colony
ACO	Ant Colony Optimization
AI	Artificial Intelligence
BA	Bat Algorithm
BFO	Bacterial Forging Optimization
CIGRE	International Council On Large Electricity System
CS	Clonal Selection
DE	Differential Evolution
DG	Distributed Generation
EPRI	Electric Power Research Institute
FA	Firefly Algorithm
GA	Genetic Algorithm
HPE	Harmonic Power Flow
IEA	International Energy Agency
IEEE	Institute Of Electrical And Electronics Engineers
LLCI	Line Loading Capacity Index
MOF	Multi Objective Function
MOO	Multi Objective Optimization
NN	Neural Network
OPF	Operation Power Factor
PEM	Point Estimate Method
PSO	Particle Swarm Optimization
PV	Photovoltaic
PLRI	Real Power Loss Reduction Index

QLRI	Reactive Power Loss Reduction Index
SCI	Short Circuit Index
VDI	Voltage Deviation Index



© COPYRIGHT UPM

CHAPTER 1

INTRODUCTION

1.1 Background

A crucial role of an electric power system is to generate electricity to meet customer demands, with an acceptable level of reliability in an economical manner. The main functional areas in an electric power system are power generation level, transmission line level, and distribution system level. The main function of the power generation plants is to ensure enough capacity is available to meet customer demand at any time. Usually, transmission line and distribution systems need to be stable and reliable to ensure the electricity can be delivered to the consumers where it is needed and when it is needed (Singh *et al.*, 2015).

For many years, electricity distribution networks were used and designed to supply electrical energy to customers; no generation was present on the customer side or on the distribution systems and distribution systems must supply electricity to the customer at an appropriate voltage rating. In the distribution levels, the ratio of X/R is lower compared to transmission levels that cause a drop in voltage magnitude and high power losses through radial distribution lines. Approximately 13% of the total power generated is wasted at the distribution level as real power losses (Kavitha *et al.*, 2014).

Nowadays, due to major changes in the electricity market in terms of the environmental policies, technological evolution and also the expansion in power markets, the new concept of allowing the electricity to be generated in small capacity generation is increasingly being added to the distribution systems of the power network (Torres *et al.*, 2014). The generating of electricity energy at the customer site or through the distribution networks is known as Distributed Generation (DG). These new technologies utilize both unconventional and conventional sources of energy. Often, it may be operated by the utility or the customer. The following reasons have brought this technology to the attention of the electricity companies (Payasi *et al.*, 2011):

- Availability of small unit generating plants.
- Ease of finding places for smaller generation units.
- Competition or deregulation policy.
- Provision of diverse energy sources.
- National power requirements.
- Lower capital costs and short building times.
- Reduced transmission costs because the generation is sited closer to the load.

The operation of DG units may be considered random depending on the customer load. The location of DG units in the distribution system and amount of power delivered from it can increase or decrease the efficiency and reliability of the system and have an effect on its operation. Technical and safety problems may be created by huge supplied power from the DG units. Depending on its size and location, DG may cause voltage oscillations, interfere with voltage-control processes, increase fault currents, increase or diminish losses. Additionally, it can reverse the direction of power flow, etc.

If the DG unit is installed at a non-optimal location in the distribution system, the amount of power may change that lead to an increase in the power losses and undesired in the voltage profiles. Therefore, suitable position and rating of the DG unit is very critical in determining system performance (Kamdar and Karady, 2014).

Basically, allocation of DG unit is a complex combinatorial optimization problem which requires synchronous optimization of several objectives such as decreasing of total active and reactive power losses, improving voltage deviation of buses and reducing the short circuit level to maximize the reliability of the network. The multi-objective optimization pattern offers an attractive option to address the complex optimization issues like optimal DG sizing and placement. Besides, it is important to measure the success of DG implementation in terms of economic feasibility and it is also important to ensure that deployment of DG units in power system improves the technical parameters of the system (Adefarati and Bansal, 2016).

Thus, many optimization techniques have been employed to solve different multi-objective optimization problems. Artificial intelligence (AI) methods have been used to solve complex DG unit problems as they can provide global or near global solutions. Artificial intelligence techniques include mainly Genetic Algorithm (GA) method, Particle Swarm Optimization (PSO) method, Artificial Bee Colony (ABC) method, Ant Colony Optimization (ACO) method, Bacterial Foraging Optimization (BFO) method, Clonal Selection (CS) method, and Firefly Algorithms (FA) method. The main advantage of the AI techniques is that they are relatively versatile for applying various qualitative constraints (Mohandas et al., 2015).

1.2 Problem Statement

Day after day, power electricity demands are growing very fast and the electricity demands in a power utility service vary as a function of location depending on the types and number of consumers in each locality. The main tasks of the electricity companies is to generate electricity from new sources such as renewable energy sources or distributed generation units to overcome the new demand of energy consumption and delivering the power into the distribution system (Dahal and Salehfar, 2016). Despite the numerous benefits that are

offered by the integration of the DG unit, the technical problems increase when the new generation is added at an unsuitable location in the power distribution network (Karimyan *et al.*, 2014). An unsuitable location with a non-optimal size of DG units may lead to increase of total active and reactive power losses together with adverse effect on voltage magnitude. The increase or decrease in the power flow could cause overtaking of the boundary in some of the lines, and integration of DG units may increase the short circuit current of the system depending on size, location and type of DG units.

Several researches have proposed artificial intelligence techniques (AI) for determining the optimal sizing and the best location of DG units to improve the voltage profile of buses and reduce power losses of the distribution system.

Recently, the Differential Evolution (DE) technique has attracted the attention of researchers because it provides a fast speed of convergence, ease of implementation, and higher accuracy in finding the optimal solution (Jiang *et al.*, 2013). The DE will be employed in this research with multi-objective functions in order to determine optimal allocation of DG units in terms of reduction of total power losses and improvement of the network's voltage profile.

1.3 Research Objectives

The present study aims to find the optimal size and location of different types of DG units to reduce power losses and improve voltage profile of the distribution system.

The specific objectives of this study are:

- 1) To formulate a multi-objective function for solving the optimal DG placement and sizing problem by considering various indices like real and reactive power loss reduction index, voltage deviation index, line loading capacity index, and short circuit index.
- 2) To propose a Differential Evolution (DE) technique for optimizing DG size and location in the distribution system.
- 3) To investigate the effect of penetration three types of DG unit (type1, type2 and type3) on the power losses and the voltage profiles of power system and validate the results with those obtained by genetic algorithm (GA).

1.4 The Scope of Work

The current research focuses on finding the best location and optimal size of different DG unit models which can improve the stability of distribution networks and maximize the benefits of significant penetration. Technical issues that arise when connecting the DG unit to distribution systems are taken into consideration.

The technical challenges presented in this research are minimization of losses, improving voltage profile, and reducing the short circuit level, also taking into consideration the line loading capacity. The technique presented in this work involves determining the optimal plan for integration of DG unit by using a DE optimization algorithm, then comparing the results with those obtained from the application of genetic algorithm. The limitations and technical constraints in power system operations are considered to ensure a good result. The algorithm is tested on both medium size (IEEE 30-bus) and large test systems (IEEE 57-bus) to demonstrate the extensiveness and applicability of the technique.

1.5 Organization of the Thesis

The thesis is organized as follows:

Chapter 1 provides information about distributed generation (DG) and its effects on power systems. Also, it gives an overview on the research background and statement of the research problem with regard to the importance of optimal sizing and the best placement of DG units to ensure voltage stability exists in the network at all times. The objectives of the study as well as the scope of work are also presented in this chapter.

Chapter 2 reviews previous studies in three sections: the first section is a summarized introduction to the chapter, follow by a description and discussion of the distributed generation and its impact on the power networks, while, the multi-objective evolutionary Algorithm is discussed in the second section. In the last section, the highlights on optimization approaches for location and sizing of DG are presented.

Chapter 3 describes the methodology and development of the proposed algorithm for best placement and optimal sizing of DG units in the distribution system. Some theoretical backgrounds of corresponding artificial intelligence (AI) techniques are introduced here. The GA and selected AI technique (DE) are combined in the overall optimization algorithm.

Chapter 4 shows the implementation of the proposed optimization technique in two widely-used test systems. Test results are analyzed and discussed to verify the applicability of the proposed technique.

Chapter 5 presents the conclusions and recommendations for future work.

REFERENCES

- Abbagana, M., Bakare, G. and Mustapha, I. (Eds.) (2011). *Optimal Placement and Sizing of a Distributed Generator in a power distribution System using Differential Evolution*. Paper presented at the Proceedings of the 1 st International Technology, Education and Environment Conference.
- Abedini, M. and Saremi, H. (2012). A Hybrid of GA and PSO for Optimal DG Location and Sizing in Distribution Systems with Load Uncertainty. *J. Basic. Appl. Sci. Res*, 2(5): 5103-5118.
- Ackermann, T., Andersson, G. and Söder, L. (2001). Distributed generation: a definition. *Electric Power Systems Research*, 57(3): 195-204.
- Adefarati, T. and Bansal, R. (2016). Integration of renewable distributed generators into the distribution system: a review. *IET Renewable Power Generation*.
- AlRashidi, M. and AlHajri, M. (Eds.) (2011). *Proper planning of multiple distributed generation sources using heuristic approach*. Paper presented at the Modeling, Simulation and Applied Optimization (ICMSAO), 2011 4th International Conference on.
- Alsac, O. and Stott, B. (1974). Optimal load flow with steady-state security. *IEEE transactions on power apparatus and systems*(3): 745-751
- Aman, M., Jasmon, G., Bakar, A. and Mokhlis, H. (2012). Optimum capacitor placement and sizing for distribution system based on an improved voltage stability index. *International Review of Electrical Engineering-Iree*, 7(3): 4622-4630.
- Aman, M., Jasmon, G., Solangi, K., Bakar, A. and Mokhlis, H. (2013). Optimum simultaneous DG and capacitor placement on the basis of minimization of power losses. *International Journal of Computer and Electrical Engineering*, 5(5): 516.
- Amanifar, O. (Eds.) (2011). *Optimal distributed generation placement and sizing for loss and THD reduction and voltage profile improvement in distribution systems using particle swarm optimization and sensitivity analysis*. Paper presented at the Electrical Power Distribution Networks (EPDC), 2011 16th Conference on.
- Arafa, M., Sallam, E. A. and Fahmy, M. (Eds.) (2014). *An enhanced differential evolution optimization algorithm*. Paper presented at the Digital Information and Communication Technology and it's Applications (DICTAP), 2014 Fourth International Conference on.

- Babu, P. S. and Mohan, R. M. (Eds.) (2015). *Optimal performance enhancement of DG for loss reduction using Fuzzy and Harmony Search Algorithm*. Paper presented at the Electrical, Electronics, Signals, Communication and Optimization (EESCO), 2015 International Conference on.
- Barker, P. P. and De Mello, R. W. (Eds.) (2000). *Determining the impact of distributed generation on power systems. I. Radial distribution systems*. Paper presented at the Power Engineering Society Summer Meeting, 2000. IEEE.
- Bhuyan, S., Hazarika, S. and Bardalai, A. (Eds.) (2014). *Power flow analysis on IEEE 57 bus system using MATLAB*. Paper presented at the International Journal of Engineering Research and Technology.
- Boyerahmadi, S. (2013). Evaluation of power loss reduction with the place of shunt capacitors and distributed generation power plant in the radial distribution systems using genetic algorithms. *American Journal of Advanced Scientific Research (AJASR)*, 1(6).
- Brunette, E. S., Flemmer, R. C. and Flemmer, C. L. (Eds.) (2009). *A review of artificial intelligence*. Paper presented at the ICARA.
- Busam, S., Hota, S., Kumar, G. N. and Naidu, R. S. K. (Eds.) (2015). *Multiobjective optimization of radial distribution system with multiple distributed generation units using genetic algorithm*. Paper presented at the Electrical, Electronics, Signals, Communication and Optimization (EESCO), 2015 International Conference on.
- Chakraborty, U. K. (2008). *Advances in differential evolution* (Vol. 143): Springer.
- Commission, F. E. R. (2007). The potential benefits of distributed generation and rate-related issues that may impede their expansion. *USDOE,(Ed.)*.
- Dahal, S. and Salehfar, H. (2016). Impact of distributed generators in the power loss and voltage profile of three phase unbalanced distribution network. *International Journal of Electrical Power & Energy Systems*, 77: 256-262.
- El-Ela, A. A., Allam, S. M. and Shatla, M. (2010). Maximal optimal benefits of distributed generation using genetic algorithms. *Electric Power Systems Research*, 80(7): 869-877.
- El-Zonkoly, A. (2011). Optimal placement of multi-distributed generation units including different load models using particle swarm optimization. *Swarm and Evolutionary Computation*, 1(1): 50-59.
- Elnashar, M. M., El Shatshat, R. and Salama, M. M. (2010). Optimum siting and sizing of a large distributed generator in a mesh connected system. *Electric Power Systems Research*, 80(6): 690-697.

- Ganguly, S. and Samajpati, D. (2015). Distributed generation allocation on radial distribution networks under uncertainties of load and generation using genetic algorithm. *IEEE Transactions on Sustainable Energy*, 6(3): 688-697.
- Georgilakis, P. S. and Hatziargyriou, N. D. (2013). Optimal distributed generation placement in power distribution networks: models, methods, and future research. *IEEE Transactions on Power Systems*, 28(3): 3420-3428.
- Ghosh, S., Ghoshal, S. P. and Ghosh, S. (2010). Optimal sizing and placement of distributed generation in a network system. *International Journal of Electrical Power & Energy Systems*, 32(8): 849-856.
- Glover, J. D., Sarma, M. S. and Overbye, T. (2012). *Power System Analysis & Design, SI Version*: Cengage Learning.
- Gopiya-Naik, S., Khatod, D. and Sharma, M. (Eds.) (2012). *Optimal allocation of distributed generation in distribution system for loss reduction*. Paper presented at the Proc. IACSIT Coimbatore Conferences.
- Grigg, C., Wong, P., Albrecht, P., Allan, R., Bhavaraju, M., Billinton, R., . . . Kuruganty, S. (1999). The IEEE reliability test system-1996. A report prepared by the reliability test system task force of the application of probability methods subcommittee. *IEEE Transactions on Power Systems*, 14(3): 1010-1020.
- Haidar, A. (2011). Optimal location of distributed generation using intelligent optimization.
- Harini, M. and Reddy, M. D. (Eds.) (2015). *Optimal location and sizing of distributed generation units for maximum loss reduction using Teaching Learning Based Optimization through Matlab GUI*. Paper presented at the Electrical, Electronics, Signals, Communication and Optimization (EESCO), 2015 International Conference on.
- Heydari, M., Hosseini, S. and Gholamian, S. (2013). Optimal Placement and Sizing of Capacitor and Distributed Generation with Harmonic and Resonance Considerations Using Discrete Particle Swarm Optimization. *International Journal of Intelligent Systems and Applications*, 5(7): 42.
- Isac, S. J., Kumar, K. S. and Kumar, P. V. (Eds.) (2013). *Optimal capacitor placement in radial distribution system to minimize the loss using fuzzy logic control*. Paper presented at the Smart Structures and Systems (ICSSS), 2013 IEEE International Conference on.
- Jaganathan, S. and Palaniswami, S. (2014). Control of voltage profile with optimal control and placement of distributed generation using the refined bacterial foraging algorithm. *Journal of Vibration and Control*, 20(13): 2006-2018.

- Jagtap, K. M. and Khatod, D. K. (2016). Loss allocation in radial distribution networks with various distributed generation and load models. *International Journal of Electrical Power & Energy Systems*, 75: 173-186.
- Jamian, J. J., Mustafa, M. W., Mokhlis, H. and Baharudin, M. (2012). Implimentation of evolutionary particle swarm optimization in distributed generation sizing. *International Journal of Electrical and Computer Engineering (IJECE)*, 2(1): 137-146.
- Jiang, L. L., Maskell, D. L. and Patra, J. C. (2013). Parameter estimation of solar cells and modules using an improved adaptive differential evolution algorithm. *Applied Energy*, 112: 185-193.
- Kamdar, K. and Karady, G. G. (Eds.) (2014). *Optimal capacity and location assessment of natural gas fired distributed generation in residential areas*. Paper presented at the Power Systems Conference (PSC), 2014 Clemson University.
- Kansal, S., Kumar, V. and Tyagi, B. (2013). Optimal placement of different type of DG sources in distribution networks. *International Journal of Electrical Power & Energy Systems*, 53: 752-760.
- Kansal, S., Sai, B., Tyagi, B. and Kumar, V. (2011). Optimal placement of distributed generation in distribution networks. *International Journal of Engineering, Science and Technology*, 3(3).
- Karimi, M., Shayeghi, H., Banki, T., Farhadi, P. and Ghadimi, N. (2012). Solving Optimal Capacitor Allocation Problem using DE Algorithm in Practical Distribution Networks. *Przegląd Elektrotechniczny*, 88(7a): 90-93.
- Karimyan, P., Gharehpetian, G., Abedi, M. and Gavili, A. (2014). Long term scheduling for optimal allocation and sizing of DG unit considering load variations and DG type. *International Journal of Electrical Power & Energy Systems*, 54: 277-287.
- Kauhaniemi, K. and Kumpulainen, L. (Eds.) (2004). *Impact of distributed generation on the protection of distribution networks*. Paper presented at the Developments in Power System Protection, 2004. Eighth IEE International Conference on.
- Kavitha, D., Renuga, P. and Priya, S. M. (Eds.) (2014). *Optimal placement and location of distributed generators in distorted distribution system*. Paper presented at the Circuit, Power and Computing Technologies (ICCPCT), 2014 International Conference on.
- Keane, A., Ochoa, L. F., Vittal, E., Dent, C. J. and Harrison, G. P. (2011). Enhanced utilization of voltage control resources with distributed generation. *IEEE Transactions on Power Systems*, 26(1): 252-260.

- Khanjanzadeh, A., Arabi, M., Sedighzadeh, M. and Rezazadeh, A. (2011). Distributed Generation Allocation to Improve Steady State Voltage Stability of Distribution Networks Using Particle Swarm Optimization and Genetic Algorithm. *Canadian Journal on Electrical and Electronics Engineering*, 2(6): 250-254.
- Khorrarn-Nia, R., Baziar, A. and Kavousi-Fard, A. (2013). A novel stochastic framework for the optimal placement and sizing of distribution static compensator.
- King, R. T. A., Rughooputh, H. C. and Deb, K. (Eds.) (2011). *Solving the multiobjective environmental/economic dispatch problem with prohibited operating zones using NSGA-II*. Paper presented at the Communications, Computers and Signal Processing (PacRim), 2011 IEEE Pacific Rim Conference On.
- Kontis, E., Dimos, K., Papadopoulos, T., Papadopoulos, P. and Papagiannis, G. K. (Eds.) (2014). *Comparison of static and dynamic calculations of short circuit currents in distributed generation networks*. Paper presented at the Power Engineering Conference (UPEC), 2014 49th International Universities.
- Kumar, A. and Kumar, N. Optimal DG Placement using Multi Objective Firefly Optimization with Eco-Technical Considerations.
- Kumar, S., Mandal, D. P. K. and Chakraborty, N. (Eds.) (2014). *Optimal allocation of multiple DG units in radial distribution system using modified differential evolution technique*. Paper presented at the Control, Instrumentation, Energy and Communication (CIEC), 2014 International Conference on.
- Kumaraswamy, I., Tarakalyani, S. and Prasanth, B. V. (2014). Optimal Location of Distributed Generation on Radial Distribution System for Loss Reduction and Voltage Profile Improvement.
- Lalitha, M. P., Reddy, N. S. and Reddy, V. V. (2010). Optimal DG Placement for maximum loss reduction in radial distribution system using ABC Algorithm. *International journal of reviews in computing*, 3: 44-52.
- Magadam, R. B. and Kulkarni, D. (Eds.) (2015). *Power loss reduction by optimal location of DG using fuzzy logic*. Paper presented at the Smart Technologies and Management for Computing, Communication, Controls, Energy and Materials (ICSTM), 2015 International Conference on.
- Mancer, N., Mahdad, B. and Srairi, K. (2012). Multi objective optimal reactive power flow based STATCOM using three variant of PSO. *International Journal of Energy Engineering*, 2(2): 1-7.

- Mehdi, N. (2012). Pso-based optimal placement of Dgs in distribution systems considering voltage stability and short circuit level improvement. *Journal of basic and applied scientific research*, 2(1): 703-709.
- Mohan, B. and Ramesh, M. (Eds.) (2012). *Optimal DG placement under Standard Market Design using GA*. Paper presented at the Emerging Trends in Electrical Engineering and Energy Management (ICETEEEM), 2012 International Conference on.
- Mohandas, N., Balamurugan, R. and Lakshminarasimman, L. (2015). Optimal location and sizing of real power DG units to improve the voltage stability in the distribution system using ABC algorithm united with chaos. *International Journal of Electrical Power & Energy Systems*, 66: 41-52.
- Moradi, M. H. and Abedini, M. (2012). A combination of genetic algorithm and particle swarm optimization for optimal DG location and sizing in distribution systems. *International Journal of Electrical Power & Energy Systems*, 34(1): 66-74.
- Murthy, K. R., Karayat, M., Das, P., Shankar, A. R. and Rao, G. S. (2013). Loss less distribution using optimal capacitor and type-3 DG placement. *International Journal of Engineering Trends in Electrical and Electronics (IJETEE-ISSN: 2320-9569) Vol, 3: 57-60*.
- Musa, H. and Adamu, S. (Eds.) (2013). *Distributed Generation placement and sizing using newly improved PSO for radial distribution systems*. Paper presented at the 2nd International Conference on Energy Systems and Technologies.
- Ng, S. and Lee, Y. (2000). Variable dimension Newton-Raphson method. *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications*, 47(6): 809-817.
- Payasi, R. P., Singh, A. K. and Singh, D. (2011). Review of distributed generation planning: objectives, constraints, and algorithms. *International Journal of Engineering, Science and Technology*, 3(3).
- Paz, M. C. R., Ferraz, R. G., Bretas, A. S. and Leborgne, R. C. (2010). System unbalance and fault impedance effect on faulted distribution networks. *Computers & Mathematics with Applications*, 60(4): 1105-1114.
- Peikherfeh, M., Seifi, H. and Sheikh-El-Eslami, M. (Eds.) (2011). *Optimal dispatch of distributed energy resources included in a virtual power plant for participating in a day-ahead market*. Paper presented at the Clean Electrical Power (ICCEP), 2011 International Conference on.
- Pinto, T., Morais, H., Oliveira, P., Vale, Z., Praça, I. and Ramos, C. (2011). A new approach for multi-agent coalition formation and management in the scope of electricity markets. *Energy*, 36(8): 5004-5015.

- Pisică, I., Postolache, P. and Edvall, M. M. (2010). Optimal Planning of Distributed Generation via Nonlinear Optimization and Genetic Algorithms *Handbook of Power Systems I* (pp. 451-482): Springer.
- Prakash, P. and Khatod, D. K. (2016). Optimal sizing and siting techniques for distributed generation in distribution systems: A review. *Renewable and Sustainable Energy Reviews*, 57: 111-130.
- Prasanna, H. M., Kumar, M. L. and Ananthapadmanabha, T. (Eds.) (2014). *Genetic algorithm based optimal allocation of a distributed generator in a radial distribution feeder*. Paper presented at the Circuit, Power and Computing Technologies (ICCPCT), 2014 International Conference on.
- Price, K. and Storn, R. (1997). Differential evolution: a simple evolution strategy for fast optimization. *Dr. Dobb's journal*, 22(4): 18-24.
- Rao, G. S. and Obulesh, Y. (Eds.) (2015). *ABC and ANN based minimization of power loss for distribution system stability*. Paper presented at the Industrial Electronics and Applications (ICIEA), 2015 IEEE 10th Conference on.
- Rawat, S. S. and Das, D. (Eds.) (2015). *Optimum placement and sizing of DGs using analytical method for different types of loads*. Paper presented at the 2015 Annual IEEE India Conference (INDICON).
- Reddy, G. N. and Kumar, G. P. (Eds.) (2013). *Best Location of Distributed Generation on Distribution Networks Using GA*. Paper presented at the International Journal of Engineering Research and Technology.
- Reddy, S. C., Prasad, P. and Laxmi, A. J. (2012). Power Quality Improvement of Distribution System by Optimal Placement and Power Generation of DGs using GA and NN. *European Journal of Scientific Research ISSN: 326-336*.
- Saadat, H. (1999). *Power system analysis*: WCB/McGraw-Hill.
- Sedighizadeh, M., Dakhem, M., Sarvi, M. and Kordkheili, H. H. (2014). Optimal reconfiguration and capacitor placement for power loss reduction of distribution system using improved binary particle swarm optimization. *International Journal of Energy and Environmental Engineering*, 5(1): 1-11.
- Seifinajmi, E. and Sakhavat Saghi, M. N. (2014). Optimal Placement of DGs in Radial Distribution Systems Considering Power Quality Improvement and Reduce Losses. *Bull. Env. Pharmacol. Life Sci*, 3: 37-41.
- Shukla, T., Singh, S. and Naik, K. (2010). Allocation of optimal distributed generation using GA for minimum system losses in radial distribution networks. *International Journal of Engineering, Science and Technology*, 2(3): 94-106.

- Singh, B., Mukherjee, V. and Tiwari, P. (2015). A survey on impact assessment of DG and FACTS controllers in power systems. *Renewable and Sustainable Energy Reviews*, 42: 846-882.
- Singh, B., Mukherjee, V. and Tiwari, P. (2016). Genetic algorithm for impact assessment of optimally placed distributed generations with different load models from minimum total MVA intake viewpoint of main substation. *Renewable and Sustainable Energy Reviews*, 57: 1611-1636.
- Singh, D., Singh, D. and Verma, K. (2009). Multiobjective optimization for DG planning with load models. *IEEE Transactions on Power Systems*, 24(1): 427-436.
- Sirish, T., Rao, G. S. and Murthy, K. R. (2013). Optimal Capacitor and DG Placement for Loss Less Distribution on 69-Bus System using KVS–Direct Search Algorithm. *International Journal of Engineering Trends in Electrical and Electronics (IJETEE-ISSN: 2320-9569)*, 3(1): 31-34.
- Soroudi, A. and Ehsan, M. (2011). Application of a modified NSGA method for multi-objective static distributed generation planning. *Arabian Journal for Science and Engineering*, 36(5): 809-825.
- Stankovic, A. M. and Aydin, T. (2000). Analysis of asymmetrical faults in power systems using dynamic phasors. *IEEE Transactions on Power Systems*, 15(3): 1062-1068.
- Storn, R. and Price, K. (1995). *Differential evolution—a simple and efficient adaptive scheme for global optimization over continuous spaces* (Vol. 3): ICSI Berkeley.
- Subbaraj, P. and Rajnarayanan, P. (2010). Hybrid particle swarm optimization based optimal reactive power dispatch. *International Journal of Computer Applications*, 1(5): 65-70.
- Sulaiman, M. H., Mustafa, M. W., Azmi, A., Aliman, O. and Rahim, S. A. (Eds.) (2012). *Optimal allocation and sizing of distributed generation in distribution system via firefly algorithm*. Paper presented at the Power Engineering and Optimization Conference (PEDCO) Melaka, Malaysia, 2012 IEEE International.
- Tan, W., Hassan, M. and Majid, M. (Eds.) (2012). *Multi population genetic algorithm for allocation and sizing of distributed generation*. Paper presented at the Power Engineering and Optimization Conference (PEDCO) Melaka, Malaysia, 2012 IEEE International.
- Tan, W. S., Hassan, M. Y., Rahman, H. A., Abdullah, P. and Hussin, F. (2013). Multi-distributed generation planning using hybrid particle swarm optimisation-gravitational search algorithm including voltage rise issue. *IET Generation, Transmission & Distribution*, 7(9): 929-942.

- Torres, S. P., de Araujo, R. A., Castro, C. A. and Pissolato, J. (Eds.) (2014). *Security constrained transmission expansion planning for smart transmission grids based on the AC network model*. Paper presented at the Transmission & Distribution Conference and Exposition-Latin America (PES T&D-LA), 2014 IEEE PES.
- Valipour, K., Dehghan, E. and Shariatkah, M. (2013). Optimal placement of capacitor banks and distributed generation for losses reduction and voltage THD improvement in distribution networks based on BBO algorithm. *International Research Journal of Applied and Basic Sciences*, 4(7): 1663-1670.
- Vatankhah, M. and Hosseini, S. (2012). PSO based voltage profile improvement by optimizing the size and location of DGS. *International Journal on Technical and Physical Problems of Engineering (IJTPE)*(11): 135-139.
- Wang, L., Ng, A. H. and Deb, K. (2011). *Multi-objective evolutionary optimisation for product design and manufacturing*: Springer.
- Wang, M. and Zhong, J. (Eds.) (2011). *A novel method for distributed generation and capacitor optimal placement considering voltage profiles*. Paper presented at the 2011 IEEE Power and Energy Society General Meeting.
- Yang, X.-S. (Eds.) (2009). *Firefly algorithms for multimodal optimization*. Paper presented at the International Symposium on Stochastic Algorithms.

BIODATA OF STUDENT

Ahmed Sahib Hammadi Tuky was born 1974 in Al Hindiya. He received her early education at School Ibn Senaa from 1981-1986 during primary School, and at Al Hindiya school from 1987-1991 during secondary school. He was then accepted to further studies in College of Engineering in the University of Technology, Baghdad, Iraq from 1992-1997. After that, he was accepted to Higher Diploma in the University of Technology, Baghdad, Iraq from 2000-2001. He has worked in different places, such as: From 2002 to 2003 working as an electrical engineer in Sanaa, Yemen. From 2006 to 2010 he was working as an electrical engineer in the Karbala University, Iraq. From 2010 to 2014 he was working as a head of electrical department in the same university. Then he continues his master study in the department of electrical and electronic in the UPM under supervision Dr. Noor Izzri from 2014-2016. During his studies for masters research, he had produced five papers related to his field of research.

LIST OF PUBLICATIONS

- Ahmed Sahib Hammadi, Noor Izzri bin Abdul Wahab, Mahmud Khalid.2015. Artificial Intelligence Techniques used for Optimum Allocation and Sizing of Distributed Generations (DG) in Distribution System: A Review. *International Conference on Electrical & Electronic Technology, UPM*. (Accepted).
- Ahmed Sahib Hammadi,.Noor Izzri ^a.2016. Optimal Location and Size of Distributed Generation to reduce power losses based on Differential Evolution Technique. *International Conference on Electrical & Electronic Technology,UPM*. (Accepted).
- Ahmed Sahib Hammadi, Noor Izzri Abdul Wahab, Mohammad Lutfi Othman, Effect of Distributed Generation Model to Reduce Power Losses and Improve Voltage Profile of Distribution System, *World Research & Innovation Convention on Engineering & Technology 2016*, Langkawi, Kedah, Malaysia, 24-25 October 2016 (Accepted).
- Noor Izzri Abdul Wahab, Ahmed Sahib Hammadi, Mohammad Lutfi Othman, Optimal Location and Sizing of Distributed Generation to Improve Distribution System Performs based on Optimization Technique, *World Research & Innovation Convention on Engineering & Technology 2016*, Langkawi, Kedah, Malaysia, 24-25 October 2016. (Accepted).
- Ahmed Sahib Hammadi ^a, Noor Izzri ^b, Muhamed Lutfe^b.2016. Optimal Location and Sizing of Distributed Generation to reduce power losses and Improve Voltage Profile of distribution system based on Differential Evolution Technique. *International Transactions on Electrical Energy System*. (Submitted).



UNIVERSITI PUTRA MALAYSIA

STATUS CONFIRMATION FOR THESIS / PROJECT REPORT AND COPYRIGHT

ACADEMIC SESSION: _____

TITLE OF THESIS / PROJECT REPORT:

OPTIMAL LOCATION AND SIZE OF DISTRIBUTED GENERATION TO REDUCE POWER LOSSES AND IMPROVE VOLTAGE PROFILES USING DIFFERENTIAL EVOLUTION OPTIMIZATION METHOD

NAME OF STUDENT : AHMED SAHIB HAMMADI

I acknowledge that the copyright and other intellectual property in the thesis/project report belonged to Universiti Putra Malaysia and I agree to allow this thesis/project report to be placed at the library under the following terms:

1. This thesis/project report is the property of Universiti Putra Malaysia.
2. The library of Universiti Putra Malaysia has the right to make copies for educational purposes only.
3. The library of Universiti Putra Malaysia is allowed to make copies of this thesis for academic exchange.

I declare that this thesis is classified as :

*Please tick (v)

CONFIDENTIAL

(Contain confidential information under Official Secret Act 1972).

RESTRICTED

(Contains restricted information as specified by the organization/institution where research was done).

OPEN ACCESS

I agree that my thesis/project report to be published as hard copy or online open access.

This thesis is submitted for :

PATENT

Embargo from _____ until _____
(date) (date)

Approved by:

(Signature of Student)
New IC No/ Passport No.:

Date :

(Signature of Chairman of Supervisory Committee)
Name:

Date :

[Note : If the thesis is CONFIDENTIAL or RESTRICTED, please attach with the letter from the organization/institution with period and reasons for confidentially or restricted.]