



UNIVERSITI PUTRA MALAYSIA

***DEVELOPMENT OF TOP-OIL TEMPERATURE THERMAL MODELS FOR
TRANSFORMER***

MUHAMMAD HAKIRIN ROSLAN

FK 2018 48



**DEVELOPMENT OF TOP-OIL TEMPERATURE THERMAL MODELS FOR
TRANSFORMER**

By

MUHAMMAD HAKIRIN BIN ROSLAN

**Thesis Submitted to the School of Graduate Studies, Universiti Putra Malaysia, in
Fulfilment of the Requirements for the Degree of Master of Science**

November 2017

All material contained within the thesis, including without limitation text, logos, icons, photographs and all other artwork, is copyright material of Universiti Putra Malaysia unless otherwise stated. Use may be made of any material contained within the thesis for non-commercial purposes from the copyright holder. Commercial use of material may only be made with the express, prior, written permission of Universiti Putra Malaysia.

Copyright © Universiti Putra Malaysia



Abstract of thesis presented to the Senate of Universiti Putra Malaysia in fulfilment of the requirement for the degree of Master of Science

DEVELOPMENT OF TOP-OIL TEMPERATURE THERMAL MODELS FOR TRANSFORMER

By

MUHAMMAD HAKIRIN BIN ROSLAN

November 2017

Chair: Norhafiz Azis, PhD
Faculty: Engineering

Hot-Spot Temperature (HST) is defined as the highest temperature inside a transformer and can be determined based on the numerical network thermal model. In this approach, Top-Oil Temperature (TOT) is among the crucial components to obtain reliable HST. Currently, there are two loading guides that utilize the numerical network thermal model in order to obtain the TOT which are IEC 60076-7 and IEEE C57.91-1995. Other types of TOT numerical network thermal model are based on the thermal-electrical analogy method. There are several improvements that can be applied to existing TOT models such as reducing the complexity of the models and increasing the accuracy which is the main motivation of this study. The main aim of this research is to provide alternative approaches to obtain the TOT of transformers. Two TOT thermal models were proposed in this study named as Thermal Model 1 (TM1) and Thermal Model 2 (TM2). These models were developed based on the proposed concept of pathway of energy transfer. TM1 was developed based on redefinition of nonlinear thermal resistance through approximation of convection coefficient, h . Meanwhile, TM2 was developed based on the concept of nonlinearity of thermal resistance of which the oil time constant was embedded in the model in order to improve the accuracy. The performance of the TM1 and TM2 were evaluated based on measured TOT with constant loadings from 7 transformers with either ONAN or ONAF cooling modes. Both TM1 and TM2 were also tested on a transformer with step loading. The performances of TM1 and TM2 were analyzed through comparison with previous Thermal-Electrical (namely as TE1 and TE2), Exponential (IEC 60076-7) and Clause 7 (IEEE C57.91-1995) TOT thermal models. Under constant loading, both TM1 and TM2 perform relatively well compare to TE1 and TE2 models. The performance of TM1 and TM2 are even better than Exponential and Clause 7 models to represent the measured TOT. The highest maximum and Root Mean Square (RMS) errors for TM1 are 6.66 °C and 2.76 °C while TM2 has the highest maximum and RMS errors of 6.24 °C and 2.58 °C respectively. Both TM1 and TM2 could represent the measured TOT quite well under step loading. The simulated TOT for TM1 and TM2 are quite close to TE1 and close to measured TOT. The highest maximum and RMS errors for both TM1 and TM2 are 5.77 °C and 2.02 °C respectively.

It can be summarized that both TM1 and TM2 can be used as an alternative approach to determine the TOT with less input parameter and reasonable accuracy as compared to previous TOT thermal models.



Abstrak tesis yang dikemukakan kepada Senat Universiti Putra Malaysia sebagai memenuhi keperluan untuk ijazah Master Sains

PEMBANGUNAN TERMA MODEL SUHU MINYAK ATAS UNTUK ALAT-UBAH

Oleh

MUHAMMAD HAKIRIN BIN ROSLAN

November 2017

Pengerusi: Norhafiz Azis, PhD

Fakulti: Kejuruteraan

Suhu Titik Panas (STP) didefinisikan sebagai suhu paling tinggi di dalam alat-ubah dan boleh ditentukan dengan menggunakan rangkaian terma model. Di dalam pendekatan ini, Suhu Minyak Atas (SMA) antara komponen penting untuk menentukan STP yang boleh dipercayai. Pada masa kini, terdapat dua panduan beban yang menggunakan terma model untuk menentukan SMA iaitu IEC 60076-7 and IEEE C57.91-1995. Terma model yang lain untuk SMA adalah berdasarkan kaedah terma-elektikal analogi. Terdapat beberapa peningkatan yang boleh digunakan terhadap model SMA yang sedia ada seperti mengurangkan kesukaran terma model SMA dan meningkatkan ketepatan dimana adalah motivasi utama kajian ini. Tujuan utama kajian ini adalah untuk menyediakan pendekatan lain dalam menentukan SMA bagi alat-ubah. Dua terma model SMA telah dicadangkan dalam kajian ini dan dinamakan sebagai TM1 dan TM2. Terma model ini dibangunkan berlandaskan konsep laluan pemindahan tenaga. TM1 dibangunkan berdasarkan definisi baru rintangan terma melalui penghampiran pekali konveksi, h . Sementara itu, TM2 dibangunkan berlandaskan konsep ketidaklurusan rintangan terma yang mana masa pemalar minyak tertanam di dalam model dimana untuk meningkatkan ketepatan. Prestasi TM1 dan TM2 di nilai berdasarkan pengukuran SMA semasa ujian suhu naik dengan beban malar daripada 7 alat-ubah sama ada ONAN atau ONAF mod penyejukan. TM1 dan TM2 juga di uji dengan alat-ubah dengan beban dinamik. Prestasi TM1 dan TM2 di analisis melalui perbandingan dengan model terma-elektikal terdahulu (dinamakan sebagai TE1 dan TE2), Exponen (IEC 60076-7) and Klaus 7 (IEEE C57.91-1995) terma model SMA. Di bawah beban malar, TM1 dan TM2 menunjukkan prestasi dengan baik berbanding model TE1 dan TE2. Prestasi TM1 dan TM2 juga adalah lebih baik daripada model Exponen dan Klaus 7 dalam mewakili pengukuran SMA. Untuk 7 alat-ubah, ralat maksimum dan Punca Min Kuasa Dua (PMKD) bagi TM1 ialah 6.66°C dan 2.76°C . Sebaliknya, TM2 mempunyai ralat maksimum dan PMKD pada 6.24°C dan 2.58°C . Kedua-dua TM1 dan TM2 boleh mewakili pengukuran SMA dengan baik di bawah beban dinamik. Simulasi SMA untuk TM1 dan TM2 agak dekat dengan TE1 dan hampir dengan pengukuran SMA. Ralat maksimum dan PMKD bagi TM1 dan TM2 masing-masing adalah 5.77°C dan 2.02°C . Ia dapat diringkaskan bahawa kedua-

dua TM1 dan TM2 boleh digunakan sebagai pendekatan alternatif untuk menentukan SMA dengan kurang masukan parameter dan ketepatan yang munasabah berbanding dengan terma model SMA sebelumnya.



ACKNOWLEDGEMENTS

First and foremost, I would like to express my sincere and firm gratitude to honourable supervisor, Dr. Norhafiz Azis for his great effort in guiding me towards successfully accomplishing this project. My full appreciation also goes to my co-supervisors Prof. Ir. Dr. Mohd Zainal Abidin Ab. Kadir and Assoc. Prof. Dr. Jasronita Jasni for their guiding the steps and ideas, patience, encouragements, and supports in many ways. In addition, a great deal, appreciated goes to all staffs and colleagues from the Center of Electromagnetic and Lightning Protection Research (CELP) and Department of Electrical and Electronic Engineering for all their support during my work. My grateful thanks to Universiti Pertahanan Nasional Malaysia and Kementerian Pelajaran Malaysia for providing scholarship as financial assistance. Last but not least, I would like to dedicate many thanks and love to my parents, Roslan A. Hamid and Asmah Jaafar for their supporting and encouraging in moral and spiritual support from time to time which has motivated me to complete my Master degree.

I certify that a Thesis Examination Committee has met on 15 November 2017 to conduct the final examination of Muhammad Hakirin bin Roslan on his thesis entitled "Development of Top-Oil Temperature Thermal Models for Transformer" in accordance with the Universities and University Colleges Act 1971 and the Constitution of the Universiti Putra Malaysia [P.U.(A) 106] 15 March 1998. The Committee recommends that the student be awarded the Master of Science.

Members of the Thesis Examination Committee were as follows:

Wan Zuha bin Wan Hasan, PhD

Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Mohammad Lutfi bin Othman, PhD

Associate Professor Ir.
Faculty of Engineering
Universiti Putra Malaysia
(Internal Examiner)

Zuhaina Zakaria, PhD

Associate Professor
Universiti Teknologi MARA
Malaysia
(External Examiner)



NOR AINI AB. SHUKOR, PhD

Professor and Deputy Dean
School of Graduate Studies
Universiti Putra Malaysia

Date: 27 February 2018

This thesis was submitted to the Senate of Universiti Putra Malaysia and has been accepted as fulfilment of the requirement for the degree of Master of Science. The members of the Supervisory Committee were as follows:

Norhafiz Azis, PhD

Senior Lecturer
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Mohd Zainal Abidin Ab. Kadir, PhD

Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

Jasronita Jasni, PhD

Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

ROBIAH BINTI YUNUS, PhD

Professor and Dean
School of Graduate Studies
Universiti Putra Malaysia

Date:

Declaration by graduate student

I hereby confirm that:

- this thesis is my original work;
- quotations, illustrations and citations have been duly referenced;
- this thesis has not been submitted previously or concurrently for any other degree at any other institutions;
- intellectual property from the thesis and copyright of thesis are fully-owned by Universiti Putra Malaysia, as according to the Universiti Putra Malaysia (Research) Rules 2012;
- written permission must be obtained from supervisor and the office of Deputy Vice-Chancellor (Research and Innovation) before thesis is published (in the form of written, printed or in electronic form) including books, journals, modules, proceedings, popular writings, seminar papers, manuscripts, posters, reports, lecture notes, learning modules or any other materials as stated in the Universiti Putra Malaysia (Research) Rules 2012;
- there is no plagiarism or data falsification/fabrication in the thesis, and scholarly integrity is upheld as according to the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) and the Universiti Putra Malaysia (Research) Rules 2012. The thesis has undergone plagiarism detection software.

Signature: _____ Date: _____

Name and Matric No.: Muhammad Hakirin Bin Roslan, GS45157

Declaration by Members of Supervisory Committee

This is to confirm that:

- the research conducted and the writing of this thesis was under our supervision;
- supervision responsibilities as stated in the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) are adhered to.

Signature: _____
Name of Chairman of
Supervisory
Committee: Norhafiz Azis

Signature: _____
Name of Member of
Supervisory
Committee: Mohd Zainal Abidin Ab. Kadir

Signature: _____
Name of Member of
Supervisory
Committee: Jasronita Jasni

TABLE OF CONTENTS

	Page
ABSTRACT	i
ABSTRAK	iii
ACKNOWLEDGEMENTS	v
APPROVAL	vi
DECLARATION	viii
LIST OF TABLES	xii
LIST OF FIGURES	xiii
LIST OF ABBREVIATIONS	xvi
LIST OF SYMBOLS	xvii
CHAPTER	
1	
INTRODUCTION	
1.1 Research overview	1
1.2 Problem statement	2
1.3 Research aim and objectives	3
1.4 Scope of work	3
1.5 Thesis outline	4
2	
LITERATURE REVIEW	
2.1 Introduction	5
2.2 Structures of Transformers	5
2.3 Types of Stresses in Transformers	8
2.4 Transformer Heat Source	9
2.5 Transformer cooling system	10
2.6 Transformer Thermal Profile	12
2.7 Transformer HST and TOT determination	13
2.8 Proposed technique	26
2.9 Summary	27
3	
METHODOLOGY	
3.1 Introduction	28
3.2 Thermal-Electrical Analogy Circuit	29
3.3 TOT Thermal Model 1 (TM1)	32
3.4 TOT Thermal Model 2 (TM2)	35
3.5 Comparison with Previous Thermal- Electrical and Standard Models	37
3.6 Input Data	38
3.7 Constant n for TE1, TE2, TM1 and TM2 models	39
3.8 Summary	41

4	RESULTS AND DISCUSSION	
4.1	Introduction	43
4.2	Analysis of TM1 performance	43
4.3	Analysis of TM2 performance	51
4.4	Discussions	59
4.5	Summary	61
5	CONCLUSION AND RECOMMENDATIONS	
5.1	Conclusion	62
5.2	Contribution of the research	63
5.3	Recommendations for future works	63
	REFERENCES	64
	BIODATA OF STUDENT	69
	LIST OF PUBLICATIONS	70

LIST OF TABLES

Table		Page
2.1	Transformer cooling modes	10
2.2	Guaranteed temperatures rises for oils and windings	13
2.3	Recommended constant value for Exponential model	18
2.4	Recommended constant values for Clause 7 model	21
2.5	Thermal-electrical analogy parameter	22
3.1	Input parameter for TOT thermal model	39
3.2	Input parameter for TOT thermal model for step loading	39
3.3	Constant n used for TE1 model	40
3.4	Constant n used for TE2 model	40
3.5	Constant n used for TM1 model	41
3.6	Constant n used for TM2 model	41
4.1	Maximum error of Simulated TOT thermal models	60
4.2	RMS error of Simulated TOT thermal models	61

LIST OF FIGURES

Figure		Page
2.1	Transformer's structure and its layout	6
2.2	Circular core design utilizing layer type winding	6
2.3	Disc type winding	7
2.4	Helical type winding	7
2.5	Spiral type winding	8
2.6	Classification of transformer losses	9
2.7	ONAN cooling mode	10
2.8	ONAF cooling mode	11
2.9	OFAF cooling mode	11
2.10	(a) Directed oil flow in the winding (b) ODAF cooling mode	12
2.11	Thermal diagram of transformer	12
2.12	Direct measurement of HST by using fibre optic sensor	14
2.13	Fibre optic sensor in contact with conductor	14
2.14	Fibre optic sensor in contact with spacer	14
2.15	Fibre optic sensor in contact with wall connection of tank	15
2.16	(a) Transformer model (b) Flux density in transformer components	16
2.17	Location of HST	16
2.18	(a) Electrical RC and (b) thermal circuits	22
2.19	Simplified TOT thermal equivalent circuit for indoor transformer	26
3.1	Flowchart of the overall work flow	28
3.2	Heat flow inside transformers	29
3.3	Pathway of energy in transformers	30
3.4	Thermal resistance equivalent circuit	30
3.5	Thermal resistance equivalent circuit with heat source	30
3.6	Thermal resistance equivalent circuit with heat source and without thermal resistance of tank/radiator	31
3.7	Thermal resistance equivalent circuit with lumped capacitance	31
3.8	Thermal-electrical analogy circuit : (a) Hot-spot temperature (b) Top-oil temperature	32
3.9	Thermal-Electrical analogy circuit with presence of heat transfer rate, q	36
4.1	Simulated TOT based on TM1 and other thermal models for TX1	44
4.2	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX1	44
4.3	Simulated TOT based on TM1 and other thermal models for TX2	45
4.4	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX2	45
4.5	Simulated TOT based on TM1 and other thermal models for TX3	46

4.6	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX3	46
4.7	Simulated TOT based on TM1 and other thermal models for TX4	47
4.8	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX4	47
4.9	Simulated TOT based on TM1 and other thermal models for TX5	48
4.10	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX5	48
4.11	Simulated TOT based on TM1 and other thermal models for TX6	49
4.12	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX6	49
4.13	Simulated TOT based on TM1 and other thermal models for TX7	50
4.14	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX7	50
4.15	Simulated TOT based on TM1 and other thermal models for TX8	51
4.16	Simulated corresponding errors of TOT based on TM1 and other thermal models for TX8	51
4.17	Simulated TOT based on TM2 and other thermal models for TX1	52
4.18	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX1	52
4.19	Simulated TOT based on TM2 and other thermal models for TX2	53
4.20	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX2	53
4.21	Simulated TOT based on TM2 and other thermal models for TX3	54
4.22	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX3	54
4.23	Simulated TOT based on TM2 and other thermal models for TX4	55
4.24	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX4	55
4.25	Simulated TOT based on TM2 and other thermal models for TX5	56
4.26	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX5	56
4.27	Simulated TOT based on TM2 and other thermal models for TX6	57
4.28	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX6	57
4.29	Simulated TOT based on TM2 and other thermal models for TX7	58
4.30	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX7	58

4.31	Simulated TOT based on TM2 and other thermal models for TX8	59
4.32	Simulated corresponding errors of TOT based on TM2 and other thermal models for TX7	59



LIST OF ABBREVIATIONS

AC	Alternating current
AT	Ambient Temperature
BOT	Bottom Oil Temperature
DC	Direct current
FEM	Finite Element Method
HST	Hot-Spot Temperature
HV	High voltage
IEC	International Electrotechnical Commission
IEEE	Institute of Electrical and Electronics Engineer
LV	Low voltage
RC	Resistance capacitance
RMS	Root mean square
TE	Thermal-Electrical
TOT	Top-Oil Temperature
TM	Thermal model
TX	Transformer
ON	Oil Natural
OF	Oil Force
OD	Oil Directed
ONAN	Oil Natural-Air Natural
OFAF	Oil Force-Air Force
ONAF	Oil Natural-Air Force
ODAF	Oil Directed-Air Force
2D	Two dimensional

LIST OF SYMBOLS

A	Area
C	Constant
C_{indoor}	The indoor thermal capacitance
C_{oil}	The oil thermal capacitance
C_{th}	Thermal capacitance
C_{el}	Electrical capacitance
dt	The step time
$d\theta_{oil}$	The TOT that changes with step time
$d\theta_{ven-out}$	The ventilation temperature changes with step time
$d\theta_{hs}$	The HST changes with step time
f_1	The relative increase of the TOT rise
f_2	The relative increase of the HST rise
f_3	The relative decrease of the TOT rise
g_r	Oil gradient
h	Convection coefficient
H	Hotspot factor
I	Current
I_{rated}	Rated current
K	Load factor
K_U	The ratio of ultimate load to rated load
K_i	The ratio of initial load to rated load
k_{11}	Thermal model constant
k_{21}	Thermal model constant
k_{22}	Thermal model constant
m	The winding exponent
m_A	Weight of core and coil
m_{oil}	Transformer oil in liters
m_T	Weight of tank and fittings
n	The oil exponent/constant
P_{LL}	Load losses
P_{dc}	Losses due to dc winding resistance (IR losses)
P_{EL}	Winding eddy losses
P_{OSL}	Stray losses in others structural part
P_{SL}	Total stray losses
$P_{cu,pu}(\theta_{hs})$	The load losses dependence on temperature which can be seen in Equation (2.28)
$P_{cu,dc,pu}$	The dc losses in per unit value
$P_{cu,eddy,pu}$	The eddy losses in per unit value
$P_{l,pu}$	The load losses dependence on temperature that is calculated by Equation (2.30)
$P_{dc,pu}$	The dc losses in per unit value
$P_{a,pu}$	The additional losses (eddy and stray losses)
q	Heat source
q_1	The conduction through copper of the winding
q_2	The conduction through the insulation paper
q_3	The convection from insulation paper to the oil
q_4	The convection from the oil to the tank

q_5	The conduction through the tank/radiator of transformers
q_{fe}	The no load losses
q_{cu}	The load losses
q_{cabin}	The cabin losses
q_{in}	Input heat source
q_{oil}	Heat transfer rate of oil
q_{out}	Output heat source
R	Ratio of the load losses at rated current to no load losses
$R_{th,rated}$	Thermal resistance at rated
$R_{th,R}$	The oil thermal resistance at rated
$R_{tank/radiator}$	The thermal resistance of tank/radiator
t	Time
v	Voltage
x	Oil exponent
y	Winding exponent
θ	Temperature
θ_{∞}	The environment temperature
θ_h	The HST
θ_0	The TOT obtained from Equation (2.11)
$\theta_{ven-out}$	The ventilation temperature
θ_{oil}	The TOT
$\theta_{oil,measured}$	The measured TOT
$\theta_{oil,simulated}$	The simulated TOT
θ_a	The AT
θ_H	The HST
θ_A	The AT
θ_e	The temperature at which losses are estimated calculated by Equation (2.31)
θ_{hs}	The HST
$\theta_{e,rated}$	The rated mean HST
θ_k	The temperature factor for the loss correction
θ_s	The surface temperature
$\theta_{hs,lv}$	The high voltage winding HST
$\theta_{hs,hv}$	The high voltage winding HST
θ_{boil}	The BOT
$\theta_{ven-out}$	The ventilation temperature
$\Delta\theta_{oi}$	Initial TOT rise
$\Delta\theta_{or}$	TOT rise at rated load
$\Delta\theta_{hi}$	Initial HST rise
$\Delta\theta_h$	The HST rise obtained from Equation (2.11)
$\Delta\theta_{h1}$	HST rise calculated based on the Equation (2.14)
$\Delta\theta_{h2}$	HST rise calculated based on the Equation (2.15)
$\Delta\theta_{hr}$	The HST rise at rated load
$\Delta\theta_{oil}$	The TOT rise
$\Delta\theta_{TO}$	The TOT rise over AT calculated using Equation (2.18)
$\Delta\theta_H$	The winding HST rise over TOT calculated using Equation (2.19).
$\Delta\theta_{TO,U}$	The ultimate TOT rise over AT calculated using the Equation (2.20)

$\Delta\theta_{TO,i}$	The initial TOT rise over AT calculated using the Equation (2.21)
$\Delta\theta_{H,U}$	The ultimate winding HST rise over TOT calculated using the Equation (2.22)
$\Delta\theta_{H,i}$	The initial winding HST rise over TOT calculated using the Equation (2.23)
$\Delta\theta_{TO,R}$	The TOT rise over AT at rated load
$\Delta\theta_{H,R}$	The winding HST rise over TOT at rated load
$\Delta\theta_{BO}$	The BOT rise over AT
$\Delta\theta_{WO/BO}$	The temperature rise of oil at winding HST location over BOT
$\Delta\theta_{H/WO}$	The winding HST rise over oil next to HST location
$\Delta\theta_{oil,rated}$	The TOT rise at rated load
$\Delta\theta_{boil,rated}$	The BOT rise at rated load
$\Delta\theta_{hs-boil,rated}$	The HST to BOT rise at rated load
$\Delta\theta_{hs,rated}$	The HST rise at rated load
Δt	Time interval
τ_{oil}	The oil time constant
τ_{boil}	The BOT time constant
τ_o	The oil time constant
τ_w	The winding time constant
τ_{wdg}	The winding time constant
τ_{wdg-b}	The winding time constant
μ_{pu}	The oil viscosity in per unit value

CHAPTER 1

INTRODUCTION

1.1 Research Overview

Transformers are among the important equipment in the power system network. It usually consists of windings, cores, oils, papers, pressboard and a tank. The main function of transformers is to control the level of voltages of the networks [1]. It is critical to ensure transformers maintain operational at all times since its failure could be costly. Transformers asset management are normally carried out by utilities in order to ensure that the abnormal condition of transformers can be detected and mitigated as early as possible [2]. In addition, the scheme can ensure the reliability of the power system network can be maintain at acceptable level at all times [3, 4].

The components of transformers asset management include condition monitoring or assessment, maintenance plans or aging, health index and end-of-life evaluation [5]. Condition monitoring or assessment focuses on the application or development of the equipment or method that can be used to monitor the condition parameters in transformers. In recent years, a numbers of researches were carried out on the condition monitoring or assessment areas [6-10]. Among the common study is on the data analysis of condition parameters which can be used to evaluate the overall condition of transformers [5]. Among the condition parameters that can affect the lifetime of transformers is the Hot-Spot Temperature (HST) [11].

The components of the HST are Ambient Temperature (AT), Top-Oil Temperature (TOT) rise over AT, and HST rise over TOT [12]. Transformers with high HST can lead to advanced degradation of oils and winding. Under abnormal conditions, HST can lead to faults in transformers such as flashover between windings [13]. HST can be determined based on thermal study either through direct measurement or network thermal model [5]. Direct measurement can be carried out by means of fibre optic sensor. It is normally placed at a pre-determined location near to the topmost winding of transformers. It is the most accurate method to determine the HST; however, it is not widely available for application in all transformers due to the high cost and complexity of the fibre optic installation. Network thermal model can provide an approximation for the HST of transformers which can be carried out by either using the Finite Element Method (FEM) or numerical equation. Thermal modelling based on FEM can be carried out through physical modelling using software such as ANSYS and COMSOL [14]. On the other hand, thermal modelling based on numerical equation can be carried out based on the temperature rise report and design information of transformers. Currently, there are 2 loading guides that utilize the numerical equations to model the TOT and HST of transformers which are the IEC 60076-7 and IEEE C57.91-1995 [12, 15]. IEC 60076-7 has 2 numerical equation thermal models that consist of the Exponential and Differential models. Both models are capable to determine the TOT and HST under steady state and

dynamic conditions respectively. There are also 2 numerical equation thermal models for IEEE C57.91-1995 known as the Clause 7 and Annex G models.

Apart from the loading guides models, a numbers of studies were also carried out on the development of alternative HST and TOT thermal models based on thermal-electrical analogy method [16-20]. Swift model proposed the concept of heat transfer equivalent circuit analogy to RC circuit based on thermal-electrical analogy method [16, 21]. Dejan Susa model extended the application of thermal-electrical analogy method through inclusion of nonlinear thermal resistance which was defined by using the Nusselt, Prandtl and Grashof numbers [17]. Other study used the same concept of thermal-electrical method to obtain the input parameters such as the TOT rise at rated, oil time constant and constant n based on Levenberg-Marquardt method utilizing the in-service measured data [18]. The thermal-electrical analogy method was also applied to obtain the outdoor and indoor TOT thermal models [19, 20] The thermal-electrical circuit for outdoor was the same as in [16-18] while the thermal-electrical circuit for indoor cases required a considerable amount of thermal resistances information such as windings, oil, core, tank, cooling air, ventilation holes, walls and ceiling. The heat generated in distribution cabinet is also taken into account in the indoors of the thermal-electrical circuit. In this study, alternative approaches to determine TOT are proposed based on thermal-electrical analogy method where a new concept of heat pathway of energy is proposed.

1.2 Problem Statement

TOT is one of crucial components of the HST in the numerical equations thermal models. The accuracy of the HST depends on the TOT; hence, making it important to develop a reliable TOT thermal models. Currently, there are 2 loading guides that use the numerical equations thermal models to determine the TOT known as IEC 60076-7 and IEEE C57.91-1995 loading guides. However, there are several issues for the existing network thermal model provided by these loading guides which are stated as follows.

1. The rise and fall curves of the TOT for Exponential model in IEC 60076-7 are difficult to be controlled and are not suitable for dynamic loading. In addition, both Exponential and Differential models have multiple constants which may not suitable for different types of transformers designs. For Differential model, the initial TOT is obtained based on equation where a number of assumptions are made which might lead to inaccuracy to the final TOT.
2. Clause 7 model in IEEE C57.91-1995 is quite simple which leads to inaccuracy in modelling the TOT. On the other hand, Annex G model is quite complicated and requires parameters that may not be readily available for most of transformers.

Apart from the IEC 60076-7 and IEEE C57.91-1995, there are other approaches that can be used to determine the TOT of transformers based on the thermal-electrical analogy method and among the common models are the Swift and Dejan Susa approaches. These models are in the form of differential equation and can provide TOT that are closer to measured TOT. However, there are few issues with these models which are listed as follows.

1. The concept of heat transfer theory to derive the thermal-electrical analogy circuit is not well defined in the Swift model. Furthermore, the input data such as TOT rise at rated load, oil time constant and constant n are determined based on parameter estimation method. This method required in-service measured TOT in order to estimate the input parameters which may not be available for all transformers.
2. Dejan Susa model requires the oil viscosity and variation of load loss information which increases the complexity of the equation.

Considering these issues, a study is needed in order to develop alternative thermal models which require less input parameters as well as that can generate results that are close to the measured values.

1.3 Research aim and objectives

The aim of this research is to develop an alternatives TOT thermal models for transformers. The objectives are as follows.

1. To develop the thermal-electrical analogy circuit based on the concept of the pathway of energy.
2. To propose alternative numerical equation for TOT thermal model based on the approximation of convection coefficient, h (Thermal Model 1 – TM1) which does not require the information on the viscosity.
3. To propose alternative numerical equation for TOT thermal model based on the concept of nonlinearity of thermal resistance (Thermal Model 2 – TM2) which reduce the complexity of the previous TOT equation.

1.4 Scope of work

The scope and limitations of this research work are as follows:

1. This research focuses only on the determination of TOT thermal model based on numerical equations.
2. The data used in this research and simulation is obtained from heat run test reports of distribution transformers with voltage level of 33 kV and power ratings between 300 kVA and 90 MVA and IEC 60076-7 report of a transformer with voltage level 250 kV and power rating of 250 MVA. The heat run test is the type test carried out to verify the guaranteed temperature rises and consists of 3 consecutive steps. The first step is transformer subjected to the sum of the load and no-load losses until TOT is established. The second step is continue with test current reduced to rated current for 1 hour. The last step is the shutdown stage.

1.5 Thesis outline

This thesis consists of five chapters: introduction; literature review; methodology; results and discussion; and conclusions and recommendations for future work.

Chapter 1 Introduction

This chapter presents the research overview, problem statement, research aim and objectives and also the scope of work of the study.

Chapter 2 Literature Review

This chapter provides a literature review of related fields to this study which includes an overview of transformer structures, transformer stresses, heat source, transformer cooling system and thermal profile. Also, the methods to determine transformer HST and TOT were also reviewed and discussed in this chapter.

Chapter 3 Methodology

This chapter presents the development of TOT thermal models. It is developed based on fundamentals of heat transfer theory and thermal-electrical analogy. There are 2 TOT thermal models namely as TM1 and TM2 that have been developed and presented in this chapter.

Chapter 4 Results and Discussion

This chapter discusses the performance of TM1 and TM2 which were developed in Chapter 3. The TM1 and TM2 were evaluated based on measured TOT during temperature rise test for 7 transformers. In addition, the TM1 and TM2 were also tested on the step loading of a 250 MVA transformer with ONAF cooling mode. The performance of these models were analysed through comparison with existing Thermal-Electrical, Exponential (IEC 60076-7) and Clause 7 (IEEE C57.91-1995) models.

Chapter 5 Conclusion and Recommendations

This chapter summarizes and concludes the findings of this research. The contributions of the study also included in this chapter. Recommendation of future study on network thermal model by numerical equation can also be discovered at the end of this chapter.

REFERENCES

- [1] J. Winders, *Power transformers: principles and applications*: CRC Press, 2002.
- [2] T. CIGRÉ, 445 "Guide for Transformer Maintenance" CIGRE Working Group A2. 34., 2011.
- [3] Y. Z. Y. Ghazali, M. A. Talib, and H. A. Rosli, "TNB experience in condition assessment and life management of distribution power transformers," *International Conference and Exhibition on Electricity Distribution-Part 1*, 2009, pp. 1-4.
- [4] M. Arshad, S. M. Islam, and A. Khaliq, "Power transformer asset management," *International Conference on Power System Technology*, 2004, pp. 1395-1398.
- [5] A. E. Abu-Elanien and M. Salama, "Asset management techniques for transformers," *Electric power systems research*, vol. 80, pp. 456-464, 2010.
- [6] G. Cliteur and J. Wetzter, "Condition assessment of power transmission and distribution components," *International Conference and Exhibition on Electricity Distribution Part 1: Contributions*, vol.1, pp. 5, 2001.
- [7] S. D. McArthur, S. M. Strachan, and G. Jahn, "The design of a multi-agent transformer condition monitoring system," *IEEE Transactions on Power Systems*, vol. 19, pp. 1845-1852, 2004.
- [8] X. Zhang and E. Gockenbach, "Asset-management of transformers based on condition monitoring and standard diagnosis [feature article]," *IEEE Electrical Insulation Magazine*, vol. 24, pp. 26-40, 2008.
- [9] M. Arshad and S. M. Islam, "Significance of cellulose power transformer condition assessment," *IEEE Transactions on Dielectrics and Electrical Insulation*, vol. 18, 2011.
- [10] M. De Nigris, R. Passaglia, R. Berti, L. Bergonzi, and R. Maggi, "Application of modern techniques for the condition assessment of power transformers," *Cigré Session*, 2004, pp. A2-207.
- [11] R. Mathew, "Asset management of transformer based on loss of Life calculation," *International Conference on Power Systems*, 2016, pp. 1-5.
- [12] IEC60076-7 "Power Transformer-Part 7: Loading Guide for Oil-Immersed Power Transformers", 2009.
- [13] S. C. Tripathy and E. Lakervi, "Evaluation of transformer overloading capability," *International Transactions on Electrical Energy Systems*, vol. 15, pp. 455-464, 2005.
- [14] S. Taheri, A. Gholami, I. Fofana, and H. Taheri, "Modeling and simulation of transformer loading capability and hot spot temperature under harmonic conditions," *Electric Power Systems Research*, vol. 86, pp. 68-75, 2012.
- [15] IEEE C57.91-1995 "IEEE Guide for Loading Mineral-Oil-Immersed Transformers," 1996.
- [16] G. Swift, T. S. Molinski, and W. Lehn, "A fundamental approach to transformer thermal modeling. I. Theory and equivalent circuit," *IEEE Transactions on Power Delivery*, vol. 16, pp. 171-175, 2001.
- [17] D. Susa, M. Lehtonen, and H. Nordman, "Dynamic thermal modelling of power transformers," *IEEE Transactions on Power Delivery*, vol. 20, pp. 197-204, 2005.
- [18] C. Weigen, P. Chong, and Y. Yuxin, "Power transformer top-oil temperature model based on thermal-electric analogy theory," *European Transactions on Electrical Power*, vol. 19, pp. 341-354, 2009.

- [19] A. Mamizadeh and I. Iskender, "Analyzing and comparing thermal models of indoor and outdoor oil-immersed power transformers," *IEEE Bucharest PowerTech*, 2009, pp. 1-8.
- [20] I. Iskender and A. Mamizadeh, "An improved nonlinear thermal model for MV/LV prefabricated oil-immersed power transformer substations," *Electrical Engineering*, vol. 93, pp. 9-22, 2011.
- [21] G. Swift, T. S. Molinski, R. Bray, and R. Menzies, "A fundamental approach to transformer thermal modeling. II. Field verification," *IEEE Transactions on Power Delivery*, vol. 16, pp. 176-180, 2001.
- [22] J. H. Harlow, *Electric power transformer engineering*: CRC press, 2004.
- [23] S. V. Kulkarni and S. Khaparde, *Transformer engineering: design and practice* vol. 25: CRC Press, 2004.
- [24] D. Harris, "The Design and Performance of Circular Disc, Helical and Layer Windings for Power Transformer Applications," *Minnesota Power System Conference*, 2009, pp. 1-12.
- [25] D. Susa, " Doctoral Dissertation: Dynamic Thermal Modelling of Power Transformers," *Electrical and Communications Engineering, Helsinki University of Technology*, 2005.
- [26] F. Torriano, M. Chaaban, and P. Picher, "Numerical study of parameters affecting the temperature distribution in a disc-type transformer winding," *Applied Thermal Engineering*, vol. 30, pp. 2034-2044, 2010.
- [27] G. Kömürköz, İ. Özkol, and N. Güzelbeyoğlu, "Temperature Distribution in The Disc-Type Coil of Transformer Winding," *International Conference on Electrical and Electronics Engineering*, 2001, pp. 64-65.
- [28] A. C. Franklin and D. P. Franklin, *The J & P transformer book: a practical technology of the power transformer*: Elsevier, 2016.
- [29] S. T. Jan, R. Afzal, and A. Z. Khan, "Transformer Failures, Causes & Impact," in *Civil and Mechanical Engineering*, 2015.
- [30] J. Perez, "Fundamental principles of transformer thermal loading and protection," *Annual Conference for Protective Relay Engineers*, 2010, pp. 1-14.
- [31] R. M. Del Vecchio, B. Poulin, M.-E. F. Feeney, P. T. Feghali, D. M. Shah, R. Ahuja, et al., *Transformer design principles: with applications to core-form power transformers*: CRC press, 2001.
- [32] D. Susa and H. Nordman, "IEC 60076-7 loading guide thermal model constants estimation," *International Transactions on Electrical Energy Systems*, vol. 23, pp. 946-960, 2013.
- [33] IEC60076-2 "Power Transformers-Part2: Temperature Rise," 1993.
- [34] A. L. Ribeiro, N. Eira, J. Sousa, P. Guerreiro, and J. Salcedo, "Multipoint fiber-optic hot-spot sensing network integrated into high power transformer for continuous monitoring," *IEEE Sensors Journal*, vol. 8, pp. 1264-1267, 2008.
- [35] G. Betta, A. Pietrosanto, and A. Scaglione, "An enhanced fiber optic temperature sensor system for power transformer monitoring," *IEEE Conference Proceedings of Instrumentation and Measurement Technology*, 2000, pp. 153-158.
- [36] D. Bailey and E. Wright, *Practical fiber optics*: Newnes, 2003.
- [37] W. McNutt, J. McIver, G. Leibinger, D. Fallon, and K. Wickersheim, "Direct Measurement of Transformer Winding Hot Spot Temperature," *IEEE transactions on power apparatus and systems*, pp. 1155-1162, 1984.

- [38] D. Feng, "Thesis Doctor of Philosophy: Life expectancy investigation of transmission power transformers," *School of Electrical and Electronic Engineering, University of Manchester*, 2013.
- [39] J. Glodio, "Field experience with multipoint internal temperature measurements of converter transformers," *International Conference of Doble Clients*, 2004.
- [40] J. Bérubé, J. Aubin, and W. McDermid, "Transformer winding hot spot temperature determination," *Fifth Annual Weidmann ACTI Technical Conference*, 2006, pp. 1-10.
- [41] T. Molinski and P. Eng, "Minimizing the Life Cycle Cost of Power Transformers," *CIGRE Colloquium, June*, 2001.
- [42] V. G. M. Annamdas, "Review on developments in fiber optical sensors and applications," *International Journal of Materials Engineering*, vol. 1, pp. 1-16, 2011.
- [43] D. K. Mahanta and S. Laskar, "Transformer Condition Monitoring using Fiber Optic Sensors: A Review," *ADBU Journal of Engineering Technology*, vol. 4, 2016.
- [44] D. Susa and M. Lehtonen, "Dynamic thermal modeling of power transformers: further Development-part I," *IEEE Transactions on Power Delivery*, vol. 21, pp. 1961-1970, 2006.
- [45] D. Susa and M. Lehtonen, "Dynamic thermal modeling of power transformers: Further development-Part II," *IEEE Transactions on Power Delivery*, vol. 21, pp. 1971-1980, 2006.
- [46] Y. Cui, H. Ma, T. Saha, C. Ekanayake, and D. Martin, "Moisture-Dependent Thermal Modelling of Power Transformer," *IEEE Transactions on Power Delivery*, vol. 31, pp. 2140-2150, 2016.
- [47] W. Tang, Q. Wu, and Z. Richardson, "Equivalent heat circuit based power transformer thermal model," *IEEE Proceedings-Electric Power Applications*, vol. 149, pp. 87-92, 2002.
- [48] W. Tang, Q. Wu, and Z. Richardson, "A simplified transformer thermal model based on thermal-electric analogy," *IEEE Transactions on Power Delivery*, vol. 19, pp. 1112-1119, 2004.
- [49] Z. Radakovic and K. Feser, "A new method for the calculation of the hot-spot temperature in power transformers with ONAN cooling," *IEEE Transactions on Power Delivery*, vol. 18, pp. 1284-1292, 2003.
- [50] D. Susa and H. Nordman, "A simple model for calculating transformer hot-spot temperature," *IEEE transactions on power delivery*, vol. 24, pp. 1257-1265, 2009.
- [51] X. Su, W. Chen, C. Pan, Q. Zhou, and L. Teng, "A simple thermal model of transformer hot spot temperature based on thermal-electrical analogy," *International Conference on High Voltage Engineering and Application*, 2012, pp. 492-495.
- [52] W. Ben-gang, F. Chen-zhao, L. Hong-lei, L. Ke-jun, and L. Yong-liang, "The improved thermal-circuit model for hot-spot temperature calculation of oil-immersed power transformers," *Conference of Information Technology, Networking, Electronic and Automation Control*, 2016, pp. 809-813.
- [53] Z. Radakovic and S. Tenbohlen, "Thermal model of oil power transformers with a tap changer," *Turkish Journal of Electrical Engineering & Computer Sciences*, vol. 24, pp. 3293-3308, 2016.

- [54] S. Taheri, A. Vahedi, A. Gholami, and H. Taheri, "Estimation of hot spot temperature in distribution transformer considering core design using FEM," *International Conference of Power and Energy*, 2008, pp. 1408-1413.
- [55] S. Taheri, H. Taheri, I. Fofana, H. Hemmatjou, and A. Gholami, "Effect of power system harmonics on transformer loading capability and hot spot temperature," *IEEE Canadian Conference on Electrical & Computer Engineering*, 2012, pp. 1-4.
- [56] G. Chitaliya and S. Joshi, "Determination of temperature rise in a dry type transformer using finite element analysis," *IEEE Annual India Conference*, 2016, pp. 1-6.
- [57] Y. Zhang, Y. Xin, T. Qian, X. Lin, W. Tang, and Q. Wu, "2-D coupled fluid-thermal analysis of oil-immersed power transformers based on finite element method," *Innovative Smart Grid Technologies-Asia (ISGT-Asia)*, 2016, pp. 1060-1064.
- [58] J. Faiz, M. Sharifian, and A. Fakhri, "Two-dimensional finite element thermal modeling of an oil-immersed transformer," *International Transactions on Electrical Energy Systems*, vol. 18, pp. 577-594, 2008.
- [59] A. S. Reddy and M. Vijaykumar, "Hottest Spot And Life Evaluation of Power Transformer Design Using Finite Element Method," *Journal of Theoretical & Applied Information Technology*, vol. 4, 2008.
- [60] S. Firouzifar and J. Mahoudi, "Assessment of Power Transformer cooler with FEMLAB," *Scandinavian Conference on Simulation and Modeling*, 2007, pp. 159-165.
- [61] G. Chitaliya and S. Joshi, "Finite Element Method for Designing and Analysis of the Transformer—A Retrospective," 2013.
- [62] S. A. Gholamian, "Life Estimation of Distribution Transformers Under Non-Linear Loads Using Calculated Loss by 2D-FEM," *Journal of Electrical Systems*, vol. 7, pp. 12-24, 2011.
- [63] M. Q. B. A. NASIB, "Thesis Bachelor of Electrical Engineering: Estimation of Core Loss in Transformer by Using Finite Element Method," *Electrical and Electronics Engineering, Universiti Malaysia Pahang*, 2012.
- [64] M. T. Askari, M. A. A. Kadir, and M. Izadi, "On the trend of improvement of thermal model for calculating the TOT and HST," *Przegląd Elektrotechniczny*, vol. 88, pp. 297-301, 2012.
- [65] A. A. Elmoudi, "Doctoral Dissertation: Evaluation of power system harmonic effects on transformers: Hot spot calculation and loss of life estimation," *Electrical and Communications Engineering, Helsinki University of Technology*, 2006.
- [66] M. Isha and Z. Wang, "Transformer hotspot temperature calculation using IEEE loading guide," *International Conference on Condition Monitoring and Diagnosis*, 2008, pp. 1017-1020.
- [67] D. Susa, M. Lehtonen, and H. Nordman, "Dynamic thermal modeling of distribution transformers," *IEEE Transactions on Power Delivery*, vol. 20, pp. 1919-1929, 2005.
- [68] J. Aubin and Y. Langhame, "Effect of oil viscosity on transformer loading capability at low ambient temperatures," *IEEE Transactions on Power Delivery*, vol. 7, pp. 516-524, 1992.

- [69] L. W. Pierce, "An investigation of the thermal performance of an oil filled transformer winding," *IEEE Transactions on Power Delivery*, vol. 7, pp. 1347-1358, 1992.
- [70] T. L. Bergman, F. P. Incropera, and A. S. Lavine, *Fundamentals of heat and mass transfer*: John Wiley & Sons, 2011.
- [71] F. Incropera and D. DeWitt, "Fundamentals of Heat and Mass Transfer, Wiley, New York, 1996."



LIST OF PUBLICATIONS

Journals

M. H. Roslan, N. Azis, J. Jasni and Z. Ibrahim, "Top-oil Temperature Model for Transformers based on Nonlinear Thermal Resistance, Lumped Capacitance and Thermal-electrical Analogy," *Pertanika Journal Science & Technology*, 2017. **(Published)**

M. H. Roslan, N. Azis, M. Z. A. Ab Kadir, J. Jasni, Z. Ibrahim, A. Ahmad, "A Simplified Top-Oil Temperature Model for Transformers based on the Pathway of Energy Transfer Concept and the Thermal-Electrical Analogy," *Energies*, 2017. **(Published)**

Conference proceedings

M.H Roslan, N. Azis, M.Z.A. Ab Kadir, J. Jasni, M.T Ishak, "Development of an Improved Thermal Model for Transformers," *MyHVnet Colloquium*, Vol. 1, January 2016. **(Published in UTM Handbook) (Author)**



UNIVERSITI PUTRA MALAYSIA

STATUS CONFIRMATION FOR THESIS / PROJECT REPORT AND COPYRIGHT

ACADEMIC SESSION : FIRST SEMESTER 2017/2018

TITLE OF THESIS / PROJECT REPORT :

DEVELOPMENT OF TOP-OIL TEMPERATURE THERMAL MODELS FOR
TRANSFORMER

NAME OF STUDENT : MUHAMMAD HAKIRIN BIN ROSLAN

I acknowledge that the copyright and other intellectual property in the thesis/project report belonged to Universiti Putra Malaysia and I agree to allow this thesis/project report to be placed at the library under the following terms:

1. This thesis/project report is the property of Universiti Putra Malaysia.
2. The library of Universiti Putra Malaysia has the right to make copies for educational purposes only.
3. The library of Universiti Putra Malaysia is allowed to make copies of this thesis for academic exchange.

I declare that this thesis is classified as :

*Please tick (v)

CONFIDENTIAL

(Contain confidential information under Official Secret Act 1972).

RESTRICTED

(Contains restricted information as specified by the organization/institution where research was done).

OPEN ACCESS

I agree that my thesis/project report to be published as hard copy or online open access.

This thesis is submitted for :

PATENT

Embargo from _____ until _____
(date) (date)

Approved by:

(Signature of Student)

New IC No/ Passport No.: 890509-06-5649

Date :

(Signature of Chairman of Supervisory Committee)

Name: NORHAFIZ BIN AZIS

Date :

[Note : If the thesis is CONFIDENTIAL or RESTRICTED, please attach with the letter from the organization/institution with period and reasons for confidentially or restricted.]