

UNIVERSITI PUTRA MALAYSIA

OPTIMAL LOCATION AND SIZE ESTIMATION OF DISTRIBUTED GENERATORS BY EMPLOYING GROUPING PARTICLE SWARM OPTIMIZATION AND GROUPING GENETIC ALGORITHM

ZAHRAA ABDULKAREEM MOHAMMED

FK 2018 52



OPTIMAL LOCATION AND SIZE ESTIMATION OF DISTRIBUTED GENERATORS BY EMPLOYING GROUPING PARTICLE SWARM OPTIMIZATION AND GROUPING GENETIC ALGORITHM



ZAHRAA ABDULKAREEM MOHAMMED

Thesis Submitted to the School of Graduate Studies, Universiti Putra Malaysia, in Fulfilment of the Requirements for the Degree of Master of Science

December 2017

COPYRIGHT

All material contained within the thesis, including without limitation text, logos, icons, photographs and all other artwork, is copyright material of Universiti Putra Malaysia unless otherwise stated. Use may be made of any material contained within the thesis for non-commercial purposes from the copyright holder. Commercial use of material may only be made with the express, prior, written permission of Universiti Putra Malaysia.

Copyright © Universiti Putra Malaysia



DEDICATION

This thesis is dedicated to my precious father, my beloved mother, my brother and sisters for continually evaluating and inspiring me to work hard in my studies. I thank almighty Allah every day for blessing me with you and I love you all very much.



Abstract of thesis presented to the senate of Universiti Putra Malaysia in Fulfillment of the requirements for the degree of Master of Science

OPTIMAL LOCATION AND SIZE ESTIMATION OF DISTRIBUTED GENERATORS BY EMPLOYING GROUPING PARTICLE SWARM OPTIMIZATION AND GROUPING GENETIC ALGORITHM

By

ZAHRAA ABDULKAREEM MOHAMMED



Faculty : Engineering

Distributed Generators is being implemented in the distribution network to improve the performance of the network by reducing the real and reactive power losses, while improving voltage profile during the operation. These advantages could be confirmed and accomplished if optimal size distribution generation units are installed at the optimal location in the distribution network. Otherwise, the problem of generation may increase when the DG is located in non-optimal location and size which can lead to increase the real and reactive power losses and high voltage deviation. Therefore, there are various algorithms that could be applied in order to integrate distribution generation units into the distribution network. These algorithms can be enhanced to increase their efficient and effective. This work is aimed to decrease the total real and reactive power losses while enhancing the voltage profile of the distribution network with less computation time by proposing two new artificial intelligence algorithms, i.e. grouping particle swarm optimization algorithm and grouping genetic algorithm. These two algorithms are compared to their original artificial intelligence algorithms, i.e. particle swarm optimization algorithm and genetic algorithm. These algorithms are used to obtain the optimal size of distributed generators units to be installed at optimal locations, which are obtained using loss sensitivity factor. Multi-objective function is the summation of three indices that are considered in these algorithms, i.e. real power loss index (PLI), reactive power loss index (QLI), and cumulative voltage index (CVD), and implemented on an IEEE 30-bus test system. This is to test the performance of the four artificial intelligence algorithms by taking into consideration the installation of 5 distributed generators units in the bus test system. It was observed that the grouping particle swarm optimization algorithm has achieved high reduction of total real and reactive power losses, by installing five distributed generators, when compared to the base case. It was observed that the voltage profile was improved with the shortest computation times demonstrated in determining the optimal size (global



optimal) for the multi DG units that were installed in the IEEE 30-bus test system comparing to all the four artificial intelligence algorithms that were employed in this work. Also, it is found that case of installing four distributed generators units is not much difference from case of five distributed generators which is make it optimum to be installed in the IEEE 30-bus test system in terms of reducing the real and reactive power losses. This also relates to the stability of the voltage.



Abstrak tesis yang dikemukakan kepada Senat Universiti Putra Malaysia sebagai memenuhi keperluan untuk ijazah Master Sains

ANGGARAN LOKASI DAN SAIZ OPTIMUM BAGI PENJANA TERAGIH DENGAN MENGGUNAKAN ALGORITMA PENGELOMPOKAN PENGOPTIMUM KERUMUNAN ZARAH DAN PENGELOMPOKAN ALGORITMA GENETIK

Oleh

ZAHRAA ABDULKAREEM MOHAMMED

Disember 2017

Pengerusi : Wan Fatinhamamah Wan Ahmad, PhD Fakulti : Engineering

Penjana Teragih dilaksanakan dalam rangkaian agihan untuk memperbaiki prestasi rangkaian dengan mengurangkan kehilangan kuasa sebenar nyata dan reaktif di samping meningkatkan profil voltan semasa operasi. Kelebihan-kelebihan ini boleh dicapai jika unit penjana teragih dipasang dengan saiz yang optimum pada lokasi yang optimum dalam rangkaian agihan. Jika tidak, masalah pengjanaan akan meningkat apabila DG diletakkan pada tempat dan saiz yang tidak optimum yang mana boleh menyebabkan kuasa nyata dan reaktif serta sisihan tinggi voltan. Maka, terdapat pelbagai algoritma yang boleh diaplikasikan untuk menyatukan unit-unit penjana teragih ke dalam rangkaian agihan. Algoritma-algoritma ini boleh ditambah-baik untuk meningkatkan kecekapan dan keberkesanan mereka. Kerja ini menyasar untuk mengurangkan hasil kehilangan kuasa nyata dan reaktif sambil menambah-baik profil oltan rangkaian agihan dengan kurang masa komputasi dengan mencadangkan dua kecerdasan buatan baru iaitu algoritma Pengelompokan pengoptimum kerumunan zarah dan Pengelompokan algoritma genetik. Kedua-dua algoritma ini dibandingkan dengan algoritma-algoritma kecerdasan buatan asal mereka iaitu algoritma pengoptimum kerumunan zarah and algoritma genetik. Algoritma-algoritma ini digunakan untuk memperoleh saiz optimum unit-unit DG untuk dipasang di lokasilokasi optimum yang diperoleh menggunakan faktor kehilangan kepekaan. Fungsi objektif pelbagai iaitu jumlahan tiga indeks yang diambil kira dalam tiga algoritma ini iaitu indeks kehilangan kuasa sebenar IKKS, indeks kehilangan kuasa reaktif IKKR, dan indeks voltan bertoko IVB dilaksanakan pada sistem ujian 30-bas IEEE. Kajian ini bertujuan menguji prestasi keempat-empat algoritma kecerdasan buatan dengan mengambil kira pemasangan 5 unit-unit PT di dalam system ujian bas. Pemerhatian menunjukkan algoritma pengoptimum kawanan zarah telah, mengurangkan kehilangan kuasa nyata dan reaktif dengan pemasangan 5 DG, apabila dibandingkan



dengan Kes Asas, Pemerhatian menunjukkan profil voltan yang lebih baik dengan komputasi masa terpendek dalam menentukan saiz optimum (optimal bagi keseluruhan) untuk penjana teragih yang telah dipasang dengan jumlah yang banyak di sistem ujian 30-bas IEEE berbanding kesemua algoritma kecerdasan buatan yang telah digunakan dalam kerja ini. Selain itu, kajian juga menunjukkan pemasangan 4 unit DG adalah tidak berbeza dengan pemasangan 5 unit DG yang mana adalah optimum untuk dipasang di sistem ujian 30-bas IEEE dari sudut mengurangkan kehilangan kuasa sebenar dan reaktif. Ini juga memberi kesan kepada kestabilan voltan.



ACKNOWLEDGEMENTS

I would like to express my deepest thanks and gratitude to my supervisor Dr.Wan Fatinhamamah Wan Ahmad for her guidance, suggestions, and encouragement throughout this work. I have benefited from her deep knowledge and instructions on this research. Without her support and help, this work would not have been finished.

I would like to convey thanks and gratitude to my co-supervisor Assoc. Prof Dr. Jasronita Jasni and Assoc. Prof Dr. Noor Izzri Abdul Wahab for their valuable comments and guidances.

I would like to extend my thanks to all the academic and administrative staff of Centre for Electromagnetic and Lightning Protection Research (CELP) for their help. Thanks and gratitude are extended to all my friends and colleagues for their support.

I am deeply grateful to my father Abdulkareem for his valuable help and great support that he provided during my study. Also, I would like to express my deepest thanks and gratitude to my mother Maha for her unconditional love, encouragement, and support throughout my whole life.

Special thanks to Dr. Aqeel, Dr. Nadheer, and Dr. Dhiaa for their engorgement and help without forgetting Dr. Siba and Dr. Anwer for their support and caring.

This thesis was submitted to the Senate of Universiti Putra Malaysia and has been accepted as fulfilment of the requirement for the degree of Master of Science. The members of the Supervisory Committee were as follows:

Wan Fatinhamamah Wan Ahmad, PhD

Senior Lecturer Faculty of Engineering Universiti Putra Malaysia (Chairman)

Jasronita Jasni, PhD

Associate Professor Ir. Faculty of Engineering Universiti Putra Malaysia (Member)

Noor Izzri Abdul Wahab, PhD

Associate Professor Faculty of Engineering Universiti Putra Malaysia (Member)

ROBIAH BINTI YUNUS, PhD Professor and Dean

School of Graduate Studies Universiti Putra Malaysia

Date:

Declaration by graduate student

I hereby confirm that:

- this thesis is my original work;
- quotations, illustrations and citations have been duly referenced;
- this thesis has not been submitted previously or concurrently for any other degree at any other institutions;
- intellectual property from the thesis and copyright of thesis are fully-owned by Universiti Putra Malaysia, as according to the Universiti Putra Malaysia (Research) Rules 2012;
- written permission must be obtained from supervisor and the office of Deputy Vice-Chancellor (Research and Innovation) before thesis is published (in the form of written, printed or in electronic form) including books, journals, modules, proceedings, popular writings, seminar papers, manuscripts, posters, reports, lecture notes, learning modules or any other materials as stated in the Universiti Putra Malaysia (Research) Rules 2012;
- there is no plagiarism or data falsification/fabrication in the thesis, and scholarly integrity is upheld as according to the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) and the Universiti Putra Malaysia (Research) Rules 2012. The thesis has undergone plagiarism detection software.

Signature:

Date: ____

Name and Matric No.: ZAHRAA ABDULKAREEM MOHAMMED, GS45021

Declaration by Members of Supervisory Committee

This is to confirm that:

- the research conducted and the writing of this thesis was under our supervision;
- Supervision responsibilities as stated in the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) were adhered to.



TABLE OF CONTENTS

Page

ABST ABST ACKI APPE DECI LIST LIST	TRACT <i>RAK</i> NOWL ROVAL LARAT OF TA OF FIG	EDGEMENTS Z TION BLES GURES	i iii v vi viii xiii xiii
CHA	OF AD PTER		ΧV
1	INTR	ODUCTION	1
-	1.1	Background	1
	1.2	Problem Statement	2
	1.3	Research Objectives	2
	1.4	Research Scope and Limitations	3
	1.5	Thesis Organization	3
2	LITE	RATURE REVIEW	4
	2.1	Overview	4
	2.2	Distributed Generation	5
	2.3	Optimization Techniques	9
		2.3.1 Multi-Objective Function for DG Optimal Location and	
		Size	10
		2.3.2 Conventional Techniques for Optimization of DG	12
		2.3.3 Artificial Intelligence Algorithms for DG Optimization	13
		2.3.4 Hybrid Optimization Techniques	19
3	MET	HODOLOGY	20
	3.1	Introduction	20
	3.2	Load Flow Analysis	22
	3.3	System Constraints	25
	3.4	Multi Objective Function	26
	3.5	Loss Sensitivity Factor for Optimal Location of DG Units in	
		Distribution Network.	28
	3.6	DG Size using Artificial Intelligent Algorithms	30
	3.7	Particle Swarm Optimization Algorithm for Finding DG Optimal	- 1
	2.0		31
	5.8	Proposed Grouping Partial Swam Optimization for Finding DG	25
	2.0	Opumal Size	33 27
	3.9 3.10	Broposed Grouping Constinuing DG Optimal Size	3/ 20
	3.10 2.11	Summery	39 ⊿1
	3.11	Summary	41

4	RESULTS AND DISCUSSIONS		
	4.1	Introduction	43
	4.2	Test System	43
	4.3	Base Case for IEEE 30-Bus Test System	45
	4.4	Optimal Location of DG units Using LSF	46
	4.5	Optimal Size of DG Units Case 1	48
	4.6	Optimal Size of DG Units Case 2	52
	4.7	Optimal Size of DG Units Case 3	56
	4.8	Optimal Size of DG Units Case 4	60
	4.9	Optimal Size of DG Units Case 5	61
	4.10	Summery	68
5	CON	CLUSION AND RECOMMENDATIONS	71
	5.1	Conclusion	71
	5.2	Contribution	72
	5.3	Recommendations for Future Work	72
REFERENCES APPENDICES BIODATA OF STUDENT LIST OF PUBLICATIONS			73 81 89 90
			20

C

LIST OF TABLES

Table		Page
4.1	Characteristics of the IEEE-30 bus test system	44
4.2	Voltage profile for base case of an IEEE 30-bus test system considered in this study	47
4.3	Five highest reduction of real power losses using LSF for optimal DG locations in IEEE 30-bus test system, compared to the base case ($P_{L_{(Base Case)}}$ =17.528 MW)	46
4.4 (a)	Total real power losses and their reduction compared to the Base Case $(P_{L_{(Base Case)}} = 17.528 \text{ MW})$, for Case 1, with one DG installed at bus 3	49
4.4 (b)	Total reactive power losses and their reduction compared to the Base Case, $Q_{L_{(Base Case)}} = 68.88881$ MVar, for Case 1, with one DG installed at bus 3	49
4.4 (c)	Determination of optimal size of DG unit installed in IEEE 30- bus test system, for Case 1, with one DG installed at bus 3	50
4.4 (d)	MOF value when one DG unit is installed in an IEEE 30-bus test system, for Case 1	50
4.5 (a)	Total real power losses and their reduction compared to the base case ($P_{L_{(Base Case)}}$ =17.528 MW), for Case 2, with two DG installed at buses 3, and 6	53
4.5 (b)	Total reactive power losses and their reduction compared to the base case, $Q_{L_{(Base Case)}} = 68.88881$ MVar,for Case 2, with two DG installed at buses 3, and 6	53
4.5 (c)	Determination of optimal size of DG unit installed in IEEE30- bus test system, for Case 2, with two DG installed at buses 3, and 6	53
4.5 (d)	MOF value when two DG unit is installed in an IEEE 30-bus test system for Case 2	54
4.6 (a)	Table 4.5(a) Total real power losses and their reduction compared to the base case ($P_{L(Base Case)}$ =17.528 MW), for Case 3, with three DG installed at buses 3, 6, and 25	57

4.6 (b) Total reactive power losses and their reduction compared to the base case, $Q_{L_{(Base Case)}} = 68.88881$ MVar, for Case 3, with three DG installed at buses 3, 6, and 25	58
4.6 (c) Determination of optimal size of DG unit installed in IEEE 30- bus test system, for Case 3, with three DG installed at buses 3, 6, and 25	58
4.6 (d) MOF value when three DG unit is installed in an IEEE 30-bus test system for Case 3	58
4.7 (a) Total real power losses and their reduction compared to the base case $(P_{L_{(Base \ Case)}}=17.528 \text{ MW})$, for Case 4, with four DG installed at buses 3, 6, 25, and 28	61
4.7 (b) Total reactive power losses and their reduction compared to the base case, $Q_{L_{(Base Case)}} = 68.88881$ MVar, for Case 4, with four DG installed at buses 3, 6, 25, and 28	62
4.7 (c) Determination of optimal size of DG unit installed in IEEE 30- bus test system, for Case 4, with four DG installed at buses 3, 6, 25, and 28	62
4.7 (d) MOF value when four DG unit is installed in an IEEE 30-bus test system for Case 4	62
4.8 (a) Total real power losses and their reduction compared to the base case $(P_{L_{(Base Case)}}=17.528 \text{ MW})$, for Case 5, with five DG installed at buses 3, 6, 25, 28, and 27	65
4.8 (b) Total reactive power losses and their reduction compared to the base case, $Q_{L_{(Base Case)}} = 68.88881$ MVar, for Case 5, with five DG units installed at buses 3, 6, 25, 28, and 27	66
4.8 (c) Determination of optimal size of DG unit installed in IEEE 30-bus test system, for Case 5, with five DG installed at Buses 3, 6, 25, 28, and 27	66
4.8 (d) MOF value when five DG unit is installed in an IEEE 30-bus test s system for Case 5	66
4.9	Summary of IEEE 30-bus test system for Cases 1 to 5, with one to five DG units installed, respectively	69

LIST OF FIGURES

Figure		Page
2.1	Typical electrical power system	5
2.2	Classifications of different DG's size	6
2.3	Optimization techniques to find optimal location and size for DG units	10
3.1	Overall Flowchart Methodology	21
3.2	Flowchart of Newton-Raphson Load Flow Method	24
3.3	Flowchart of LSF to allocate multiple DG units	31
3.4	New steps for position and speed	33
3.5	Flowchart of PSO algorithm	34
3.6	Flowchart of GrPSO algorithm	36
3.7	Crossover process	38
3.8	Flowchart of GA algorithm	39
3.9	Flowchart of GrGA algorithm	41
4.1	Single Line Diagram of IEEE30-bus test system	44
4.2	Voltage profile of the IEEE 30-bus test system for Base Case	45
4.3	Voltage profile of the IEEE 30-bus test system for Case 1, with 1 DG unit installed at Bus 3	51
4.4	Voltage profile of the IEEE 30-bus test system for Case 2, with 2DG unit installed at Buses 3 and 6	55
4.5	Voltage profile of the IEEE 30-bus test system for Case 3, with 3 DG unit installed at Buses 3, 6, and 25	59
4.6	Voltage profile of the IEEE 30-bus test system for Case 4, with 4 DG unit installed at Buses 3, 6, 25, and 28	63
4.7	Voltage profile of the IEEE 30-bus test system for Case 5, with 5 DG unit installed at Buses 3, 6, 25, 28, and 27	67

LIST OF ABBREVIATIONS

ABC	Artificial Bee Colony
ASC	Ant Search Colony
ANN	Artificial Neural Network
CVD	Cumulative Voltage Deviation
DE	Differential Evaluation
DG	Distributed Generation
FA	Firefly Algorithm
GA	Genetic Algorithm
GrGA	Grouping Genetic Algorithm
GrPSO	Grouping Particle Swarm Optimization Algorithm
KCL	Kirchoff Current Low
LSF	Losses Sensitivity Factor Method
MATLAB	Matrix Laboratory
MOF	Multi Objective Function
OPF	Optimal Power Flow
PLI	Real Power Losses Index
QLI	The Reactive Power Loss Index
REPSO	Ranked Evolutionary Partial Swarm Optimization

CHAPTER 1

INTRODUCTION

1.1 Background

Producing stable electricity is considered a crucial role of an electrical power system depending on the customer demands. Hence, its reliability is the must important part. The electrical power network consists of three main parts which are power generation station, transmission system, and distribution networks. The major function of a power generation station is to supply enough power to provide electricity due to customers' demands at any time. Generally, it is necessary that the transmission system and distribution network be reliable and stable to ensure safe delivery of the electricity to the customers [1]. For a long time, there is no generation in the distribution network as the distribution networks were designed and used only to provide power to the customers with the optimal voltage level that is set at the distribution stations. In the distribution network, the ratio of X/R is lower than their value at transmission system which results in power losses and drop in the voltage level [2]. Recently, the new structure of distribution networks allows adding small size generation to provide energy directly to the customers because of the high change in the power strategy regarding the growth in electricity markets, technological evaluation, and environmental policies [3]. Generating the power from the distribution networks and consumer site known as Distributed Generation (DG). These technologies employ both conventional and unconventional sources of energy. There are main reasons that made this technology catch attention of power companies such as; national requirement for power, provision of different sources of energy, ease in selecting a place with short building times due to the small size of generating units compared to the main power plants, reduction in the transmission lines which indirectly will also reduce the power losses due to the generation unit that is located nearby to the load [4]. This is due to the reason that the performance of DG units depends on load demand. Also, the reliability and efficiency of the distribution network can decrease or increase based on the location and size of DG units installed in the distribution network. If optimal location and optimal size of any DG units are not researched before its installation in the distribution network, it may create problems in terms of safety and technical issues such as interference in the processes of voltage control, voltage oscillations, add to that it can reverse power flow direction, etc. which affect the amount of power that may not cover the demand and cause an increase in power losses and unwanted voltage profile [5]. Basically, the optimal location and optimal size of DG units are a complex optimization problem that needs synchronous optimization of different objectives such as minimising the total real and reactive power losses and managing the voltage deviation of the buses to increase the reliability of the network. The multi-objective optimization provides attractive choices to address the optimization problem to obtain optimal location and optimal size of DG units of any distribution network. Besides, it is important to be sure that the installation of DG units in the distribution network will enhance system technical parameters [6]. Therefore, various optimization techniques have been applied to find solutions for multiobjective optimization problems. Several artificial intelligence algorithms have been employed to solve DG units problems as they can achieve global solutions. Mainly, such artificial intelligence algorithms include Particle Swarm Optimization (PSO), Genetic Algorithm (GA), Ant Search Colony (ASC), Artificial Bee Colony (ABC), Firefly Algorithm (FA), and Differential Evaluation (DE). One of the main benefits of artificial intelligence algorithms is their ability to apply in different qualitative constraints [7].

1.2 Problem Statement

Recently, electrical power demand is increasing very fast, and the electrical load demands in a power utility service can be varied depending on the number and type of consumers at each location. The main function of power companies is generating power from new recourses such as DG units energy resources to face the high demand of electrical power consumption and sending the power safely to the consumers [8]. In spite of the advantages that are provided by the implementation of DG units in the distribution network, the problems of generation may increase when the DG unit is located at not optimal locations with non-optimal size in the distribution network which can lead to real and reactive power losses, and high voltage deviation [9]. Many studies have presented artificial intelligence algorithms for finding the optimal location and size of DG units to decrease the real and reactive power losses and enhance the voltage profile of buses in the distribution network. PSO and GA considered as the global algorithms in term artificial intelligence algorithms due to the easy implementation and the ability to find the optimal or near optimal solution. However, the original PSO and GA demonstrated high execution time in solving DG units optimal allocation problems [10, 11].

1.3 Research Objectives

This work is aimed at finding the optimal locations and sizes for multi DG units in the distribution network to decrease the total real and reactive power losses, and to improve the voltage profile of the network. The specific objective of this study are;

1) To formulate the multi-objective function for solving the optimal DG unit location and size problem by considering several indices such as real power loss index, reactive power loss index, and cumulative voltage deviation index.

2) To propose the new optimization algorithms called grouping particle swarm optimization (GrPSO) and grouping genetic algorithm (GrGA) in order to reduce the computation time in determining the optimal size units that installed in the distribution network.

3) To investigate the impact of multi DG units installation on the system power losses and voltage profile and validate the proposed artificial intelligence algorithms, i.e. GrPSO, GrGA by comparing the results obtained using original artificial intelligence algorithms, i.e., PSO and GA.

1.4 Research Scope and Limitations

This work focuses on developing new proposed artificial intelligence algorithms, i.e., GrPSO and GrGA to find the optimum location and size of DG units, with the consideration of the computation time. Note that, the cost of DG unit installation is not considered in this research. This study is aimed to minimize the real and reactive power losses and improve the voltage profile. We are looking for the limit of total DG units that could be implemented in IEEE 30-bus test system while enhancing the reliability of the network where the number of installed DG units depends on the previous work. This work considered only DG with PV type. Based on the previous study conducted as reviewed in [69]. The implementation of the proposed IEEE 30-bus test system is established. However, the only major difference lies in the variations in the implemented system parameters, which is not provided in the paper.

1.5 Thesis Organization

Chapter 1 introduces the important information on DG with its impact on the power system. Also, present an overview of the research background and problem statement with clarifying the need for of optimal location and size of DG units to ensure the system reliability at all times. The objectives of this work and its limitations proposed in this chapter.

In Chapter 2, review on DG and its value in power system are presented. Also, optimization techniques that employed for finding the optimal location and size of DG units in the distribution network are discussed.

Chapter 3 detailed the four artificial intelligence algorithms that were employed in this work in detail, which are the two original artificial intelligence algorithms, i.e., PSO and GA and two proposed artificial intelligence algorithms, i.e., GrPSO and GrGA.

While in chapter 4 and 5, the results for IEEE 30-bus test system are obtained and concluded, respectively.

REFERENCES

- B. Singh, V. Mukherjee, and P. Tiwari, "A survey on impact assessment of DG and FACTS controllers in power systems," *Renew. Sustain. Energy Rev.*, vol. 42, pp. 846-882, 2015.
- [2] D. Kavitha, P. Renuga and S. M. Priya, "Optimal placement and location of distributed generators in distorted distribution system," 2014 International Conference on Circuits, Power and Computing Technologies [ICCPCT-2014], Nagercoil, 2014, pp. 533-539.
- [3] S. P. Torres, R. A. de Araujo, C. A. Castro and J. Pissolato, "Security constrained transmission expansion planning for smart transmission grids based on the AC network model," 2014 IEEE PES Transmission & Distribution Conference and Exposition - Latin America (PES T&D-LA), Medellin, 2014, pp. 1-6.
- [4] R. Payasi, A. Singh, and D. Singh, "Review of distributed generation planning: objectives, constraints, and algorithms," *International J. Eng. Sci. Technol.*, vol. 3, no. 3, pp. 133-153, 2011.
- [5] K. Kamdar and G. G. Karady, "Optimal capacity and location assessment of natural gas fired distributed generation in residential areas," 2014 Clemson University Power Systems Conference, Clemson, SC, 2014, pp. 1-5.
- [6] T. Adefarati and R. C. Bansal, "Integration of renewable distributed generators into the distribution system: a review," *IET Renew. Power Gener.*, vol. 10, no. 7, pp. 873 884, 2016.
- [7] N.Mohandas, R.Balamurugan, and L.Lakshminarasimman, "Optimal location and sizing of real power DG units to improve the voltage stability in the distribution system using ABC algorithm united with chaos," *International J. Electr. Power Energy Syst.*, vol. 66, pp. 41-52, 2015.
- [8] SamirDahal and HosseinSalehfar, "Impact of distributed generators in the power loss and voltage profile of three phase unbalanced distribution network," *Int. J. Electr. Power Energy Syst.*, vol. 77, pp. 256-262, 2016.
- [9] PeymanKarimyan, G.B.Gharehpetian, M.Abedi, and A.Gavili, "Long term scheduling for optimal allocation and sizing of DG unit considering load variations and DG type," *Int. J. Electr. Power Energy Syst.*, vol. 54, pp. 277-287, 2014.
- [10] S. V. Gollapudi, S. S., Pattnaik, O. P., Bajpai, S., Devi, and K. M. and Bakwad, "Velocity modulated bacterial foraging optimization technique (VMBFO)," Appl. Soft Comput., vol. 11, no. 1, pp. 154-165, 2011.
- [11] S. Devi and M. Geethanjali, "Application of Modified Bacterial Foraging Optimization algorithm for optimal placement and sizing of Distributed Generation," Expert Syst. Appl., vol. 41, no. 6, pp. 2772–2781, 2014.

- [12] M. AlHajri, "Sizing and placement of distributed generation in electrical distribution systems using conventional and heuristic optimization methods," PhD.thesis,Dalhousie University, 2009.
- [13] J. D. Glover, M. S. Sarma, and T. J. Overbye, *Power System analysis and design*, Fifth Edit.Cengage Learning, United States of America, 2012.
- [14] L. Yadav, A., Srivastava, "Optimal placement of distributed generation: An overview and key issues.," in *Power Signals Control and Computations* (*EPSCICON*), 2014, Delhie, India, pp. 1-6.
- [15] Y. Alinejad-Beromi, M. Sedighizadeh, and M. Sadighi, "No TitleLosses, A particle swarm optimization for sitting and sizing of Distributed Generation in distribution network to improve voltage profile and reduce THD and," in *Univ. Power Eng. Conf. 2008. UPEC 2008*, pp. 1-5.
- [16] M. M. Pisică, I., Postolache, P., Edvall, "Optimal Planning of Distributed Generation via Nonlinear Optimization and Genetic Algorithms.," *Springer*, pp. 451-482, 2010.
- [17] R. M. S. Pahwa, D. Weerasinghe, C. Scoglio, "A complex networks approach for sizing and siting of distributed generators in the distribution system," in 45th North American Power Symposium., Manhattan, KS, 2013, pp. 1-5.
- [18] D. P. K. P. Gupta, M. Pandit, "A Review on Optimal Sizing and Siting of Distributed Generation System," in *Power India International Conference(PIICON) 2014, Delhi, India*, 2014, pp. 1-6.
- [19] D. S. Haidar, Ahmed MA, K. Muttaqi, "Smart Grid and its future perspectives in Australia.", *Renew. Sustain. Energy Rev.*, vol. 51, pp. 1375-1389, 2015.
- [20] S. SINGH, J. ØSTERGAARD, and N. JAIN, "Distributed Generation in Power Systems : An Overview and Key Issues," in 24rth Indian Engineering Congress, Kerala, India, 2009, pp. 1–8.
- [21] A. Z. Shalash, N. A., Ahmad, "Distributed generation location using multiagent system for reliability assessment," in *Power and Energy Engineering Conference (APPEEC)*, Kowloon, Hong Kong, 2013, pp. 1-8.
- [22] W. Cui, H., & Dai, "Multi-objective optimal allocation of distributed generation in smart grid," in *Electrical and Control Engineering (ICECE)*, 2011 *International Conference*, Yichang, China, 2011, pp. 713-717.
- [23] M. A. Araújo, R. A. Flauzino, O. E. Batista, L. A. Moraes and C. H. R. Martins, "Protection of the distribution lines with distributed generation against lightning overvoltages in the context of smart grids," 2013 World Congress on Sustainable Technologies (WCST), London, 2013, pp. 36-41.
- [24] P. S. Georgilakis and N. D. Hatziargyriou, "Optimal Distributed Generation Placement in Power Distribution Networks: Models, Methods, and Future Research," in *IEEE Transactions on Power Systems*, vol. 28, no. 3, pp. 3420-3428, 2013.

- [25] T. Ackermann, G. Andersson, and L. Söder, "Distributed generation: A definition," *Electr. Power Syst. Res.*, vol. 57, no. 3, pp. 195-204, 2001.
- [26] A. M. Stankovic and T. Aydin, "Analysis of asymmetrical faults in power systems using dynamic phasors," in *IEEE Transactions on Power Systems*, vol. 15, no. 3, pp. 1062-1068, 2000.
- [27] M. H. Moradi and M. Abedini, "A combination of genetic algorithm and particle swarm optimization for optimal DG location and sizing in distribution systems," *Int. J. Electr. Power Energy Syst.*, vol. 34, no. 1, pp. 66-74, 2012.
- [28] D. Kavitha, P. Renuga and S. M. Priya, "Optimal placement and location of distributed generators in distorted distribution system," 2014 International Conference on Circuits, Power and Computing Technologies [ICCPCT-2014], Nagercoil, 2014, pp. 533-539.
- [29] Gopiya-Naik, D. K. Khatod, and M. P. and Sharma, "Optimal allocation of distributed generation in distribution system for loss reduction," in *In Proc. IACSIT Coimbatore Conferences*, Singapore, 2012, pp. 42-46.
- [30] T. S. Sirish, G. V. S. Rao, and K. V. S. R. Murthy, "Optimal Capacitor and DG Placement for Loss Less Distribution on 69- Bus System using KVS – Direct Search Algorithm," Int. J. Eng. Trends Electr. Electron., vol. 3, no. 1, pp. 31-34, 2013.
- [31] K. M. Jagtap and D. K. K. Alternate, "Electrical Power and Energy Systems Loss allocation in radial distribution networks with various distributed generation and load models," *Int. J. Electr. POWER ENERGY Syst.*, vol. 75, pp. 173-186, 2016.
- [32] S. Jaganathan, S., & Palaniswami, "Control of voltage profile with optimal control and placement of distributed generation using the refined bacterial foraging algorithm," *J. Vib. Control*, vol. 20, no. 13, pp. 2006-2018, 2014.
- [33] Aman, M., Jasmon, G., Bakar, A. and Mokhlis, H, "Optimum capacitor placement and sizing for distribution system based on an improved voltage stability index," *Int. Rev. Electr. Eng.*, vol. 7, no. 3, pp. 4622-4630, 2012.
- [34] A. Keane, F. O. Luis, E. Vittal, C. J. Dent and G. P. Harrison, "Enhanced utilization of voltage control resources with distributed generation," *2011 IEEE Power and Energy Society General Meeting*, San Diego, CA, 2011, pp.1-1.
- [35] A. M. A. Haidar, "Optimal Location of Distributed Generation Using Intelligent Optimization," 2011 IEEE 23rd International Conference on Tools with Artificial Intelligence, Boca Raton, FL, 2011, pp. 891-893.
- [36] E. S. Brunette, R. C. Flemmer and C. L. Flemmer, "A review of artificial intelligence," 2009 4th International Conference on Autonomous Robots and Agents, Wellington, 2009, pp. 385-392.
- [37] S. Busam, S. Hota, G. V. N. Kumar and R. S. K. Naidu, "Multiobjective optimization of radial distribution system with multiple distributed generation units using genetic algorithm," 2015 International Conference on Electrical,

Electronics, Signals, Communication and Optimization (EESCO), Visakhapatnam, 2015, pp. 1-5.

- [38] D. Singh, D. Singh and K. S. Verma, "Multiobjective Optimization for DG Planning With Load Models," in *IEEE Transactions on Power Systems*, vol. 24, no. 1, pp. 427-436, 2009.
- [39] N. Mancer, B. Mahdad, and K. Srairi, "Multi Objective Optimal Reactive Power Flow Based STATCOM Using Three Variant of PSO," *Int. J. Energy Eng.*, vol. 2, no. 2, pp. 1-7, 2012.
- [40] R. T. F. A. King, H. C. S. Rughooputh and K. Deb, "Solving the multiobjective environmental/economic dispatch problem with prohibited operating zones using NSGA-II," *Proceedings of 2011 IEEE Pacific Rim Conference on Communications, Computers and Signal Processing*, Victoria, BC, 2011, pp. 298-303.
- [41] M. Wang and J. Zhong, "A novel method for distributed generation and capacitor optimal placement considering voltage profiles," 2011 IEEE Power and Energy Society General Meeting, San Diego, CA, 2011, pp. 1-6.
- [42] G. N. S., D. K. Khatod, and M. P. Sharma, "Optimal Allocation of Distributed Generation in Distribution System for Loss Reduction," in *IACSIT Press*, *Singapore*, 2012, vol. 28, pp. 42-46.
- [43] S. S. Rawat and D. Das, "Optimum placement and sizing of DGs using analytical method for different types of loads," 2015 Annual IEEE India Conference (INDICON), New Delhi, 2015, pp. 1-5.
- [44] D. S. K. Kanth, M. P. Lalita, and P. S. Babu, "Siting & Sizing of Dg for Power Loss & Thd Reduction, Voltage Improvement Using Pso & Sensitivity Analysis," *Int. J. Eng. Res. Dev.*, vol. 9, no. 6, pp. 1-7, 2013.
- [45] C. Pinto, T., Morais, H., Oliveira, P., Vale, Z., Praça, I., & Ramos, "A new approach for multi-agent coalition formation and management in the scope of electricity markets," *Energy*, vol. 36, no. 38, pp. 5004-5015, 2011.
- [46] G. S. Rao and Y. P. Obulesh, "ABC and ANN based minimization of power loss for distribution system stability," 2015 IEEE 10th Conference on Industrial Electronics and Applications (ICIEA), Auckland, 2015, pp. 772-777.
- [47] R. B. Magadum and D. B. Kulkarni, "Power loss reduction by optimal location of DG using fuzzy logic," 2015 International Conference on Smart Technologies and Management for Computing, Communication, Controls, Energy and Materials (ICSTM), Chennai, 2015, pp. 338-343.
- [48] P. Suresh Babu and R. Madhan Mohan, "Optimal performance enhancement of DG for loss reduction using Fuzzy and Harmony Search Algorithm," 2015 International Conference on Electrical, Electronics, Signals, Communication and Optimization (EESCO), Visakhapatnam, 2015, pp. 1-5.
- [49] J. Kennedy and R. Eberhart, "Particle swarm optimization," *Neural Networks*, 1995. *Proceedings.*, *IEEE International Conference on*, Perth, WA, 1995,

vol.4, pp. 1942-1948.

- [50] M. Li, W. Du, and F. Nian, "An Adaptive Particle Swarm Optimization Algorithm Based on Directed Weighted Complex Network," *Hindawi*, vol. 2014, pp. 1-7, 2014.
- [51] X. Hu, "PSO Tutorial," 2006. [Online]. Available: http://www.swarmintelligence.org/tutorials.php.
- [52] Y. Alinejad-Beromi, M. Sedighizadeh and M. Sadighi, "A particle swarm optimization for sitting and sizing of Distributed Generation in distribution network to improve voltage profile and reduce THD and losses," 2008 43rd International Universities Power Engineering Conference, Padova, 2008, pp. 1-5.
- [53] S. Kansal, V. Kumar, and B. Tyagi, "Optimal placement of different type of DG sources in distribution networks," *Electr. Power Energy Sys*, vol. 53, pp. 752-760, 2013.
- [54] W. S. Tan, M. Y. Hassan and M. S. Majid, "Multi population genetic algorithm for allocation and sizing of distributed generation," 2012 IEEE International Power Engineering and Optimization Conference Melaka, Malaysia, Melaka, 2012, pp. 108-113.
- [55] H. A. Maruthi Prasanna, M. V. Likith Kumar and T. Ananthapadmanabha, "Genetic algorithm based optimal allocation of a distributed generator in a radial distribution feeder," 2014 International Conference on Circuits, Power and Computing Technologies [ICCPCT-2014], Nagercoil, 2014, pp. 184-190.
- [56] X.-S. Yang, *Nature-Inspired Metaheuristic Algorithms*, Second Edi. United Kingdom: Luniver Press, 2010.
- [57] M. F. Kotb, K. M. Shebl, M. El Khazendar, and A. El Husseiny, "Genetic Algorithm for Optimum Siting and Sizing of Distributed Generation," *in the 14th International Middle East Power Systems Conference (MEPCON'10)*, Cairo, Egypt, 2010, pp. 433-440.
- [58] T. N. Shukla, S. P. Singh, and K. B. Naik, "Allocation of optimal distributed generation using GA for minimum system losses in radial distribution networks," *Int. J. Eng. Sci. Technol.*, vol. 2, no. 3, pp. 94-106, 2010.
- [59] Bongkoj Sookananta, Pattana Utaton and Rungson Khongsila, "Determination of the optimal location and sizing of Distributed Generation using Ant Colony Search," ECTI-CON2010: The 2010 ECTI International Conference on Electrical Engineering/Electronics, Computer, Telecommunications and Information Technology, Chaing Mai, 2010, pp. 814-817.
- [60] V.Selvi and Dr.R.Umarani, "Comparative Analysis of Ant Colony and Particle Swarm Optimization Techniques," *Int. J. Comput. Appl.*, vol. 5, no. 4, pp. 1-6, 2010.
- [61] G.V.Naga Lakshmi, A.Jaya Laxmi, and S.Vijender Reddy "Optimal Allocation and Sizing of Distributed Generation in Distribution Network using Ant Colony

Search Algorithm," Proc. Int. Conf. Adv. Commun. Network, Comput. CNC Optim., Chennai, India, pp. 1-8, 2014.

- [62] F. Sheidaei, M. Shadkam, and M. Zarei, "Optimal Distributed Generation allocation in distirbution systems employing ant colony to reduce losses," 2008 43rd Int. Univ. Power Eng. Conf., Padova, Italy, 1-4 Sep. 2008, pp. 1-5.
- [63] M. Moghimi Hadji and B. Vahidi, "A Solution to the Unit Commitment Problem Using Imperialistic Competition Algorithm," in *IEEE Transactions on Power Systems*, vol. 27, no. 1, pp. 117-124, Feb. 2012.
- [64] Z. Beheshti, S. Mariyam, and H. Shamsuddin, "A review of population-based meta-heuristic algorithm A Review of Population-based Meta-Heuristic Algorithm," *Int. J. Adv. Soft Comput. Appl.*, vol. 5, no. 1, pp. 1-35, 2013.
- [65] R. Jahani, A. Hosseinzadeh, A. Gharegozi, and M. M. Abadi, "ICA-based Allocation of DGs in a Distribution System," *American Journal Of Scientifc Research*., vol. 33, no. 33, pp. 64-75, 2011.
- [66] A. Mahari and E. Babaei, "Optimal DG placement and sizing in distribution systems using imperialistic competition algorithm," *India Int. Conf. Power Electron. IICPE*, Delhi, India, 6-8 Dec. 2012, no. 2, pp. 2-7.
- [67] J. Brownlee, Clever Algorithms Nature-Inspired Programming Recipes. Melbourne, Australia, 2011.
- [68] M. R. Aghaebrahimi, M. Amiri, and S. H. Zahiri, "An immune-based optimization method for distributed generation placement in order to minimize power losses," 2009 Int. Conf. Sustain. Power Gener. Supply, Nanjing, China, 6-7 April 2009, pp. 1-6.
- [69] D. A. V. V. Coello, Carlos A. Coello, Gary B. Lamont, *Evolutionary algorithms* for solving multi-objective problems. New York: Springer, 2007.
- [70] M. Junjie, W. Yulong, and L. Yang, "Size and Location of Distributed Generation in Distribution System Based on Immune Algorithm," *The 2nd International Conference on Complex Science Theory and Application*, New Mexice, United State, 5-7 Dec. 2012, vol. 4, no. 2011, pp. 124-132.
- [71] M. R. Aghaebrahimi, M. Amiri, and S. H. Zahiri, "An immune-based optimization method for distributed generation placement in order to minimize power losses," 2009 *Int. Conf. Sustain. Power Gener. Supply*, Nanjing, China, 6-7 April 2009, pp. 1-6.
- [72] M. Dell and D. Teodorovic, "Bee colony optimization A cooperative learning approach to complex transportation problems," *Adv. OR AI Methods Transp.*, pp. 51-60, 2005.
- [73] E. Gerhardt and H. M. Gomes, "Artificial Bee Colony (ABC) Algorithm for Engineering Optimization Problems," *in International Conference on Engineering Optimization*, Rio de Janeiro, Brazil, 2012, pp. 1-11.

- [74] A. K. Hussain, I. ; Roy, "Optimal distributed generation allocation in distribution systems employing modified artificial bee colony algorithm to reduce losses and improve voltage profile," IEEE Trans. Power Deliv., Tamil Nadu, India, 30-31 March 2012, pp. 565-570.
- [75] A. A. Seker and M. H. Hocaoglu, "Artificial Bee Colony algorithm for optimal placement and sizing of distributed generation," 2013 8th Int. Conf. Electr. Electron. Eng.(ELECO), Bursa, Turkey, 28-30 Nov. 2013, pp. 127-131.
- [76] S. Biswas, A. Chatterjee, and S. K. Goswami, "An artificial bee colony based optimal placement and sizing of distributed generation," Proc. 2014 Int. Conf. Control. Instrumentation, Energy Commun.(CIEC), Kolkata, India, Jan. 31 2014- Feb. 2 2014, pp. 356-360.
- [77] O. Amanifar, "Optimal distributed generation placement and sizing for loss and the reduction and voltage profile improvement in distribution systems using particle swarm optimization and sensitivity analysis," *16th Electrical Power Distribution Conference*, Bandar Abbas, 2011, pp. 1-1.
- [78] S. C. Reddy, P. V. N. Prasad, and A. J. Laxmi, "Power Quality Improvement of Distribution System by Optimal Placement and Power Generation of DGs using GA and NN," *Eur. J. Sci. Res.*, vol. 69, no. 3, pp. 326-336, 2012.
- [79] H. M. and S. S. Adamu, "Distributed Generation Placement And Sizing Using Newly Improved Pso For Radial Distribution Systems," in 2 nd International Conference on Energy Systems and Technologies, Cairo, Egypt,2013, pp. 237-245.
- [80] Ghosh, Sudipta, S. P. Ghoshal, and S. Ghosh, "Optimal sizing and placement of distributed generation in a network system," *Int. J. Electr. Power Energy Syst.*, vol. 32, no. 8, pp. 849-856, 2010.
- [81] H. Saadat, Power System Analysis, *Mc-Graw-Hill Co.*, New York, 1998, pp. 189-256.
- [82] S. W. Ng and Y. S. Lee, "Variable dimension Newton-Raphson method," in *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications*, vol. 47, no. 6, pp. 809-817, Jun 2000.
- [83] M. R. AlRashidi and M. F. AlHajri, "Proper planning of multiple distributed generation sources using heuristic approach," 2011 Fourth International Conference on Modeling, Simulation and Applied Optimization, Kuala Lumpur, 2011, pp. 1-5.
- [84] R. P. Payasi and D. S., Asheesh K. Singh, "Review of distributed generation planning: objectives, constraints, and algorithms," *Int. J. Eng. Sci. Technol.*, vol. 3, no. 3, pp. 133-153, 2011.
- [85] D. D. Cherry, "Optimal Placement Of Distributed Generation On A Power System Using Particle Swarm Optimization," Mississippi State University, 2012.

- [86] I. Kumaraswamy, S. Tarakalyani, and B. V. Prasanth, "Optimal location of distributed generation on radial distribution system for loss reduction and voltage profile improvement," *Afr. J. Comput. ICT*, vol. 7, no. 5, pp. 29-36, 2014.
- [87] Seifinajmi, Ebrahim, Saghi, and M. N. Sakhavat, "Optimal Placement of DGs in Radial Distribution Systems Considering Power Quality Improvement and Reduce Losses," *Bull. Env. Pharmacol. Life Sci*, vol. 3, pp. 37-41, 2014.
- [88] L. Wang, K. Deb, and A. H. C. Ng, "Multi-objective Evolutionary Optimization for Product Design and Manufacturing". London: *Sipringer*, 2011.
- [89] M. M. S. Elnashar, Mohab M., Ramadan El Shatshat, "Optimum siting and sizing of a large distributed generator in a mesh connected system," *Electr. Power Syst. Res.*, vol. 80, no. 6, pp. 690-697, 2010.
- [90] S. Kansal, B. B. R. Sai, B. Tyagi, and V. Kumar, "Optimal placement of distributed generation in distribution networks," *Int. J. Eng. Sci. Technol.*, vol. 3, no. 3, pp. 47-55, 2011.
- [91] R. Eberhart and J. Kennedy, "A new optimizer using particle swarm theory," *Micro Machine and Human Science*, 1995. MHS '95., Proceedings of the Sixth International Symposium on, Nagoya, 1995, pp. 39-43.
- [92] C. K. M. Ozcan, Ender, "Analysis of a simple particle swarm optimization system," *Intel. Eng. Syst. through Artif. neural networks*, vol. 8, pp. 253-258, 1998.
- [93] Singh, Bindeshwar, V. Mukherjee, and P. Tiwari, "Genetic algorithm optimized impact assessment of optimally placed DGs and FACTS controller with different load models from minimum total real power loss viewpoint," *Energy Build.*, vol. 126, pp. 194-219, 2016.
- [94] H. A. Maruthi Prasanna, M. V. Likith Kumar and T. Ananthapadmanabha, "Genetic algorithm based optimal allocation of a distributed generator in a radial distribution feeder," 2014 International Conference on Circuits, Power and Computing Technologies [ICCPCT-2014], Nagercoil, 2014, pp. 184-190.
- [95] K. Nigim, "Integration of Distributed Generation with Electrical Power System," in *Power Systems*, London: Springer, 2008, pp. 203-228.
- [96] C. Grigg *et al.*, "The IEEE Reliability Test System-1996. A report prepared by the Reliability Test System Task Force of the Application of Probability Methods Subcommittee," in *IEEE Transactions on Power Systems*, vol. 14, no. 3, pp. 1010-1020, Aug 1999.
- [97] W. Group, "Format for the Exchange of Solved Load Flow Data," *IEEE Trans. Power Appar. Syst.*, vol. 92, no. 6, pp. 1916-1925, 1973.

LIST OF PUBLICATIONS

- Z. Abdulkareem, W. F. W. Ahmad, J. Jasni, and N. I. A. Wahab, "A Review on Optimal Location of Distributed Generation Techniques in Electrical Network,"*IEEE 6th International Conference on Power and Energy (PECON* 2016), Melaka, Malaysia. 28-29 Nov. 2016, pp. 1-6
- Z. Abdulkareem, W. F. W. Ahmad, J. Jasni, and N. I. A. Wahab, A Review on Optimal Location of Distributed Generation Techniques in Electrical Network, *The 2016 MyHVnet, Colloquium*, Johor Bahru, Malaysia,2015.

