



UNIVERSITI PUTRA MALAYSIA

CONSTANT LOCK CIRCUIT FOR DC MICRO-GRID SYSTEM

ASAAD ABDULJABBAR MOHAMMED

FK 2017 75



CONSTANT LOCK CIRCUIT FOR DC MICRO-GRID SYSTEM

By

ASAAD ABDULJABBAR MOHAMMED

**Thesis Submitted to the School of Graduate Studies, Universiti Putra Malaysia,
in Fulfillment of the Requirements for the Degree of Master of Science**

May 2017

COPYRIGHT

All material contained within the thesis, including without limitation text, logos, icons, photographs and all other artwork, is copyright material of Universiti Putra Malaysia unless otherwise stated. Use may be made of any material contained within the thesis for non-commercial purposes from the copyright holder. Commercial use of material may only be made with the express, prior, written permission of Universiti Putra Malaysia.

Copyright © Universiti Putra Malaysia



Abstract of thesis presented to the Senate of Universiti Putra Malaysia in fulfillment of the requirement for the Degree of Master of Science

CONSTANT LOCK CIRCUIT FOR DC MICRO-GRID SYSTEM

By

ASAAD ABDULJABBAR MOHAMMED

May 2017

Chairman : Associate Professor Wan Zuha bin Wan Hasan, PhD
Faculty : Engineering

The escalating rates of fossil fuels have enforced researchers to seek renewable energy systems. Power generation from fossil fuels may not be possible for very long as they are depleting. Recently, the researchers have been interested in the techniques of exploiting renewable energy sources such as solar, hydro, wind, etc. The energy conversion from water flow streams to electrical energy via Pico turbine generator is the only solution. The only disadvantage of hydro energy is the seasonal variations when it cannot generate enough power to meet the load demand. Also, the changing of water flow rates causes a variable output voltage. In this renewable system, continuous power flow to meet load demand is not possible. For integration of REs to optimal results, an excellent option for energy production can be obtained by using a micro-grid system by combining the renewable energy source with a backup source such as a utility grid.

Therefore, this thesis develops DC micro-grid control strategies based on providing continuous load power regardless of the generated power and load demand. The comparison between generated power and load consumption leads the monitoring system to determine the proper mode that the system should follow. Three modes come into view during DC micro-grid operations. These operational scenarios are the stand-alone scenario, grid scenario, and feedback scenario.

A simulation of the DC micro-grid in order to provide a continuous load demand based on using a CLC which is keeping the DC link at a 24v constant value is designed. Due to the ongoing interaction between the fluctuating weather conditions and load demands in a DC micro-grid, each source needs to be in a highly precise control regulation to link with the DC link node. So, it requires voltage compatibility of all sources associated with the DC link bus for keeping the stability of the DC link at a constant value. Moreover, parallel sources connection for sharing power at a DC

micro-grid have problems such as reverse current, and degradation of power conversion efficiency, due to a slight difference between output voltages. For all the above, there is a need for a new interface block control to deal with these problems.

For this, an algorithm system strategy for utilizing a Constant Lock Circuit in the DC micro-grid aims at maintaining a constant DC link voltage at the desired constant value of 24v to ensure high stability voltage and current without any ripple. Furthermore, it is deemed relevant to give priority to the renewable energy production for supplying load extracting maximum power from the REs. Moreover, it is also necessary to provide an adequate load demand regardless the power generation amount for satisfying an easy connection between two parallel sources for sharing power. On top of that, the power that the load needs from the backup source to meet load demand should be compensated to export the surplus RE power to the backup source.

The models of the DC micro-grid with CLC system are simulated in Proteus8 Professional. Results obtained from simulations have proven that the proposed algorithm system strategy have achieved its aims through keeping constant 24v with percentage error 0.059%.

Abstrak tesis yang dikemukakan kepada Senat Universiti Putra Malaysia
sebagai memenuhi keperluan untuk Ijazah Sarjana Sains

KAWALAN BEBAN KUASA SISTEM MIKRO-GRID DC MENGGUNAKAN TEKNIK LITAR KUNCI BERTERUSAN

Oleh

ASAAD ABDULJABBAR MOHAMMED

Mei 2017

Pengerusi : Profesor Madya Wan Zuha bin Wan Hasan, PhD
Fakulti : Kejuruteraan

Kenaikan kadar bahan api fosil telah menyebabkan para penyelidik mencari sistem tenaga yang boleh diperbaharui. Penjana tenaga daripada bahan api fosil mungkin tidak boleh dilakukan buat masa yang lama kerana ia semakin berkurangan. Baru-baru ini, para penyelidik telah berminat dalam teknik mengeksploitasi sumber-sumber tenaga boleh diperbaharui seperti solar, hidro, angin dan lain-lain. Penukaran tenaga daripada aliran air kepada tenaga elektrik melalui penjana turbin Pico adalah satu-satunya penyelesaian. Kelemahan tunggal tenaga hidro adalah variasi bermusim, apabila ia tidak boleh menjana kuasa yang mencukupi untuk memenuhi permintaan beban. Juga, perubahan kadar aliran air menyebabkan voltan keluaran berubah-ubah. Di dalam sistem yang boleh diperbaharui ini, aliran kuasa yang berterusan untuk memenuhi permintaan beban adalah tidak mungkin. Untuk integrasi tenaga yang boleh diperbaharui ke arah hasil yang optimum, pilihan yang sangat baik untuk pengeluaran tenaga boleh diperolehi dengan menggunakan sistem mikro-grid secara menggabungkan tenaga boleh diperbaharui dengan sumber sandaran seperti grid utiliti. Oleh itu, tesis ini membangunkan strategi kawalan mikro-grid Arus terus berasaskan kepada penyediaan kuasa beban berterusan tanpa mengira kuasa yang dijanakan dan permintaan beban. Perbandingan antara kuasa yang dijanakan dan penggunaan beban membawa sistem pemantauan itu ke arah menentukan mod yang betul yang sistem tersebut perlu ikuti. Tiga mod diperlihatkan semasa operasi mikro-grid Arus terus. Senario-senario operasi ini adalah senario berdiri sendiri, senario grid, dan senario maklum balas.

Suatu simulasi mikro-grid Arus terus untuk menyediakan permintaan beban yang berterusan berasaskan penggunaan litar kunci berterusan yang mengekalkan pautan Arus terus pada nilai yang tetap direka. Oleh kerana interaksi yang sentiasa berlaku antara keadaan cuaca yang berubah-ubah dan permintaan beban di dalam sesuatu

mikro-grid Arus terus, setiap sumber perlu berada dalam pengaturan kawalan yang sangat tepat untuk dihubungkan dengan nod pautan Arus terus tersebut.

Dengan itu, untuk mengekalkan kestabilan pautan Arus terus pada nilai yang malar, adalah diperlukan keserasian voltan semua sumber yang berkaitan dengan bas pautan Arus terus itu. Selain itu, sambungan sumber selari untuk berkongsi kuasa di mikro-grid Arus terus mempunyai masalah seperti arus balikan, dan degradasi kecekapan penukaran kuasa, oleh kerana sedikit perbezaan antara voltan-voltan output. Untuk semua di atas, terdapat keperluan untuk kawalan blok antara muka baru bagi menangani masalah-masalah ini.

Untuk itu, strategi sistem algoritma untuk menggunakan suatu litar kunci berterusan di mikro-grid Arus terus bertujuan untuk mengekalkan secara berterusan voltan pautan Arus terus malar pada nilai 24v yang dikehendaki untuk memastikan kestabilan voltan dan arus yang tinggi tanpa sebarang ombak kecil, mengekstrak kuasa maksimum dari RE apa juga kuasa tersebut, dan memberi keutamaan kepada pengeluaran tenaga boleh diperbaharui untuk membekalkan beban. Ia juga menyediakan permintaan beban yang mencukupi tanpa mengira jumlah penjanaan kuasa, mengadakan sambungan mudah antara dua sumber selari untuk berkongsi kuasa, mengganti kuasa yang beban itu perlukan dari sumber sandaran untuk memenuhi permintaan beban, dan mengeksport kuasa RE lebihan ke sumber sandaran.

Model mikro-grid Arus terus dengan sistem litar kunci berterusan disimulasi melalui Proteus 8 Profesional. Keputusan yang diperolehi daripada simulasi telah membuktikan bahawa strategi sistem algoritma yang dicadangkan telah mencapai matlamat melalui 24v yang malar dengan peratusan ralat 0.059%.

ACKNOWLEDGEMENTS

I thank ALLAH for his generosity, that has brought all of us to encourage and tell each other and who has pulled us from the darkness to the light. All respect for our holy prophet (Peace be upon him), who guided us to identify our creator.

I sense a deep emotion of gratefulness for my father and mother, who taught me good things and established part of my vision that truly affair in life. I am also very much grateful to all my family members for their constant inspiration and encouragement.

My heartfelt thanks to my wife and my sons for their support. They helped me out when it happened any difficulties regarding in all the aspects of our life.

I also take this occasion to express my deep acknowledgement and profound regards to my guide Prof. Madya Dr. Wan Zuha b. Wan Hasan for his ideal guidance, monitoring and continuous motivation during the course of this thesis. The help, blessing and guidance offered by him from time to time will support me a long way in the study journey.

I acknowledge my committee Prof. Madya Dr. Suhaidi B. Shafie and Prof. Madya Dr. Hashim b. Hizam, for the valuable information provided by them in their respective fields. I am grateful for their cooperation.

This thesis was submitted to the Senate of the Universiti Putra Malaysia and has been accepted as fulfillment of the requirement for the degree of Master of Science. The members of the Supervisory Committee were as follows:

Wan Zuha bin Wan Hasan, PhD

Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Suhaidi B. Shafie, PhD

Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

Hashim b. Hizam, PhD

Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

ROBIAH BINTI YUNUS, PhD

Professor and Dean
School of Graduate Studies
Universiti Putra Malaysia

Date:

Declaration by Members of Supervisory Committee

This is to confirm that:

- the research conducted and the writing of this thesis was under our supervision;
- supervision responsibilities as stated in the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) were adhered to.

Signature: _____

Name of Chairman
of Supervisory
Committee:

Associate Professor Dr. Wan Zuha bin Wan Hasan

Signature: _____

Name of Member
of Supervisory
Committee:

Associate Professor Dr. Suhaidi B. Shafie

Signature: _____

Name of Member
of Supervisory
Committee:

Associate Professor Dr. Hashim b. Hizam

TABLE OF CONTENTS

	Page
ABSTRACT	i
ABSTRAK	iii
ACKNOWLEDGEMENTS	v
APPROVAL	vi
DECLARATION	viii
LIST OF TABLES	xii
LIST OF FIGURES	xiii
LIST OF ABBREVIATIONS	xvi
 CHAPTER	
1 INTRODUCTION	1
1.1 Research Overview	1
1.2 Problem Statement	2
1.3 Research Objectives	3
1.4 Scope of Research	3
1.5 Research Contributions	3
1.6 Organization of Thesis	4
 2 LITERATURE REVIEW	6
2.1 Introduction	6
2.2 Concept Micro-Grid Power System	7
2.2.1 Micro-Grid Operation Overview	8
2.2.2 Micro-Grid System Structure	9
2.2.3 Micro-grid Operation	10
2.3 Control Strategies for DC Micro-grid	11
2.3.1 Droop Control Architecture	13
2.3.2 Hierarchical Control Architecture	14
2.3.3 Fuzzy Control Architecture	14
2.3.4 Multi-Agent Based Control	15
2.4 Micro-Grid Control Options	15
2.5 Control Topologies	15
2.5.1 Central Control	16
2.5.2 Decentralized Control	16
2.5.3 Distributed Control	18
2.6 Hybrid Topologies	19
2.6.1 Hybrid Central Control	19
2.6.2 Hybrid Distributed Control	19
2.7 Hydropower Generation	21
2.7.1 General Pico Hydro Principles	22
2.8 Maximum Power Point Tracking (MPPT)	22
2.9 Power Electronic System	23
2.9.1 Overview on DC-DC converter	24
2.9.2 Boost Converter Operating Modes	24
2.10 Power Quality in DC Micro-grid system	27

2.11	Summary	28
3	METHODOLOGY	29
3.1	Overview Methodology	29
3.2	Pico Turbine Generator	30
3.3	AC-DC Converter / Uncontrolled AC-DC Rectifier	31
3.4	DC-DC Boost Converter	32
3.5	DC-DC Boost Converter Design	34
3.6	Proposed Constant Lock Circuit CLC	35
3.6.1	Design of Proposed CLC	36
3.6.2	Proposed a CLC Control Circuit / CLCC	38
3.6.3	Overall CLC work strategy	39
3.7	DC Micro-Grid Operational Strategy Modes	40
3.8	Scenario 1 / Islanded Mode	42
3.9	Scenario 2 / compensated Mode	45
3.9.1	Scenario 2 Case 1	50
3.9.2	Scenario 2 Case 2	50
3.9.3	The backup voltage changing	50
3.9.4	Current Source Stage Design / CS	50
3.10	Scenario 3 / Excess Mode	52
3.10.1	Scenario 3 / Case 1	56
3.10.2	Scenario 3 / Case 2	56
3.10.3	Current Source Stage Design /CS1	57
3.11	Summary	62
4	RESULTES AND DISCUSSION	63
4.1	Introduction	63
4.2	Results of CLC Design	63
4.3	Results of Standalone Mode	66
4.4	Results of Grid Mode	67
4.4.1	Results of Case 1	68
4.4.2	Results of Case 2	71
4.4.3	Results of Backup Voltage Changing	74
4.5	Results of Excess Mode	76
4.5.1	Results of Case 1	77
4.5.2	Results of Case 2	79
4.6	Validation of the proposed CLC circuit in DC Micro-Grid	83
4.7	Summary	85
5	CONCLUSION AND FUTURE WORK	87
5.1	Conclusion	87
5.2	Future Work	88
	REFERENCES	89
	APPENDICES	98
	BIODATA OF STUDENT	115
	PUBLICATION	116

LIST OF TABLES

Table	Page
1.1 Standard hydropower Classification	22
3.1 Parameters which are used in DC-DC Boost Converter simulation	34
4.1 CLC Simulation Results Tested (a, b, c, and d)	64
4.2 Study cases in simulation	66
4.3 The obtained simulation results at scenario 1	66
4.4 Scenario 2 Case 1 Simulation Results	68
4.5 Scenario 2 Case 2 Simulation Results	71
4.6 Changing the Backup Source Voltage vs. constant DC link voltage	75
4.7 Scenario 3, Case 1 Simulation Results	77
4.8 The Scenario 3 Case 2 Simulation Outcome	80
4.9 Comparison Table Between With or Without CLC system	84
4.10 Comparison Performance with Proposed CLC in DC Micro-Grid system	85

LIST OF FIGURES

Figure	Page
2.1 DC MG Standard Topology	12
2.2 Generation of circular current	13
2.3 Micro-Grid Control Topology - Central Control	16
2.4 Micro-Grid Control Topology - Decentralized Control	17
2.5 Micro-Grid Control Topology – Distributed Control	18
2.6 Basic Hybrid Control Typologies	19
2.7 Basic Diagram Circuit of Boost Converter	25
2.8 Duty Cycle Period and Switch State	26
2.9 Equivalent circuit of the DC-DC converter in the first operating phase	26
2.10 Equivalent Circuit of the DC-DC Converter in the Second Operating Phase	27
3.1 Block Diagram of Proposed DC-Micro-Grid system	30
3.2 Proposed Output Voltage of Pico Turbine Generator during Simulation	31
3.3 Uncontrolled AC-DC Rectifier	32
3.4 Boost Converter Model	33
3.5 Frequency Duty Cycle D is 80% from Time Period	35
3.6 CLC Position in Proposed Circuit	35
3.7 CLC Loop Control Diagram	36
3.8 Simulated CLC by Proteus 8 Professional	37
3.9 Schematic Diagram of the CLC	38
3.10 CLCC Loop Control Diagram	39
3.11 Schematic Diagram of the CLC Control Circuit / CLCC	39

3.12	Flow Chart Algorithm with CLC for DC Micro-Grid System	42
3.13	Block Diagram of DC Micro-Grid System - Scenario 1	43
3.14	Schematic Diagram in Scenario 1 Simulation	44
3.15	Work Strategy Flow Chart in Scenario 1	45
3.16	Block Diagram of Proposed DC-Micro-Grid System at Scenario	46
3.17	Schematic Diagram Simulation in Scenario 2	47
3.18	Work Strategy Flow Chart in Scenario 2	47
3.19	Flow Chart Strategy of the Control Performance during Scenario 2	49
3.20	Current Source Stage Design	51
3.21	Current Source Control Stage Design CS	52
3.22	Block Diagram of DC Micro-Grid system - Scenario 3	53
3.23	Scenario 3 Schematic Diagram Simulated in Proteus 8 professional	54
3.24	Work Strategy Flow Chart of Scenario 3	54
3.25	Flow Chart Strategy of the Control System Performance during Scenario 3	57
3.26	Current Source Circuit CS1	58
3.27	Current Source Control Stage Scheme CSC1	59
3.28	Shows the Overall Flow Chart Scenarios of CLC in DC Micro-Grid System	60
3.29	Full diagram of Suggested CLC system for DC Micro-Grid	61
4.1	(a, b, and c) Constant CLC Output Voltage with Variable Input Voltage	65
4.2	Constant VDC Link with Variable RE Vin	67
4.3	Constant DC Link Voltage Vs Resistive Load Variation	69
4.4	Changing at Vc with REs Current	69

4.5	Relation between I_1 , I_2 , and I_L when changing R_L	70
4.6	P_L , P_{RES} , and P_{grid} Relationship to Meet Load Demand	70
4.7	Constant DC Link Voltage with Variable P_{RES}	72
4.8	Compensated the Shortfall Power by Backup Source	73
4.9	Changing V_c with REs Current	74
4.10	Constant DC Link Voltage with Variable V_{grid}	75
4.11	Constant Parameters System with V_{grid} Changing	76
4.12	Constant DC Link Voltage Vs R_L Variation	78
4.13	Changing V_{cex} with I_L Variation	79
4.14	Exporting Power with Changing in Load Demand	79
4.15	Constant DC Link with P_{RES}	80
4.16	Relation of I_1 , I_L , and I_3 with P_{RES} Variation	81
4.17	Changing in V_{cex} with P_{RES}	82
4.18	Exporting Excess Power in terms of I_3	83

LIST OF ABBREVIATIONS

EPS	Electric Power System
MGP	Micro-Grid Power System
MG	Micro-grid
RE	Renewable Energy
PE	Power Electronic
CLC	Constant Lock Circuit
PTG	Pico turbine generator
CLCC	Constant Lock Control Circuit
CSVC1	Current Source Voltage Control
CSVC2	Current Source Voltage Control
SOC	State of Charge
CAN	Controller Area Network
MPPT	Maximum Power Point Tracking
MCC	Magnetically Coupled Converters
ECC	Electrically Coupled Converters
MAS	Multi-Agent Systems

CHAPTER 1

INTRODUCTION

1.1 Research Overview

The global resources of nuclear fuel and fossil are limited due to the global warming caused by the abundance of CO₂ in the atmosphere [1]. Not only that, it is also expensive to carry out the linking of remote areas with master electric grid, especially when the utility national network is not suitably designed for the growing needs of the population and some of them may be damaged by new consumers [95]. For all these reasons, it is necessary to conduct an imperative study for alternative sources of energy to meet any future demands. Renewable energy system (REs) is one of these energies which meets the continuously increasing demands. The REs is connected differently to the electric power system (EPS) depending upon the overall system structures. One of these structures is a micro-grid power system (MGPs). The MGPs has a fantastic prospect for supplying higher quality and more trustworthy power to end users [96]. The REs can be operated either off-grid style or an on-grid connected style. An off-grid system is defined as standalone power system, which operates independently without a grid support. For providing continuous power to the load, a standalone RES cannot be operated effectively and efficiently in the off-grid system; thus, it is always operated in a grid connected mode to maximize its optimal use and credentials. The fluctuating weather condition, on the other hand, also impacts on the REs output power. So, the mismatch between the RE power and variation in load demands is compensated by a grid. The major important renewable sources are hydropower, solar, biomass, wind, and geothermal.

Hydropower energy is considered as promising power sources which not polluted, free in terms of their availability and is renewable as well. Hydropower plant is classified according to its capacity to large, medium, small, mini, micro, and Pico. Pico power deals with the lower-level production of energy production under a few kilowatts only. It can be made at a relatively cheap cost and applied to small streams. A Pico hydro energy is specified to the process of taking out the potential capacity from water flow. However, due to their unpredictability and weather dependency, the integration of REs to form a hybrid system is an excellent option for energy production [97].

Since a hybrid power system augments the renewable energy sources in DC MG by a grid network or saving system as energy storage, the overall power system can overcome the power load demands. The chief advantage of this architecture is that the power capacity rating of the hybrid system is required to meet load consumption. Major problems of the hybrid methods are concerning to the management and control of the power flow. An uninterrupted dynamic interaction between the load demand consumption and the renewable energy generation can be pushed to enhance the power quality and stability of critical troubles that are not very concerted in traditional power

systems. Thus, managing outflow power during the hybrid style is fundamental to guarantee the supplying load demand continuously.

This thesis presents an optimized management strategy for providing continuous power load demand in DC micro-grid DC (MG) power systems by using constant lock circuit (CLC) which keeps the DC link at a constant value. The importance of this study lies in the hybrid system which deals with low RE voltage systems and provides continuous load demand. The DC micro-grid system consists of Pico turbine generator (PTG) to convert the kinetic energy from the hydro flow into electrical energy. The DC-DC also boosts the converter to increase the output voltage to a higher value than input voltage, constant lock circuit CLC holds the DC link node or load voltage at a constant value, CLC controls (CLCC) to ensure fixing a CLC output voltage. The AC-DC converter, on the other hand, converts AC grid voltage to DC required voltage. Current source voltage control (CSVC1) controls the injected power to DC link for meeting load demand. Current source control circuit (CSCC) sets the injected current to meet the load demand at shortage RE generation mode. Moreover, Current source control circuit (CSVC2) and its control for exporting power at generation power is more than the load demand mode.

1.2 Problem Statement

Linking the main electric power system grid to remote areas is very uneconomical to carry out. Moreover, the utility network is not designed to achieve the fast growth of the population needs and may be damaged by new users. Thus, it is not expensive to electrify those areas with a MG by methods of existing RE sources which are available locally. Due to the fast growth of renewable energy and PE technologies, different control strategies and power management systems have been proposed to ensure balancing systems. Therefore, there are many drawbacks such as: fluctuations Voltage which are caused by natural variability of renewable energy resources, and harmonics which are caused by power electronic devices used in renewable energy generation become an important aspect of renewable energy integration. So, these significant technical challenges need to solve for increasing contribution to our modern society [103].

Likewise, the ongoing interaction between fluctuating weather conditions and load demands in DC micro-grid causes instability DC link voltage on constant value. So, it requires an interface unit to face this problem in DC link node for keeping the stability of the DC link at constant value [98].

Similarly, providing continuous power from a RE source which has low electricity generation or operating limits to the load, cannot operate satisfactorily to meet the load demand. Therefore, some additional source or sources are required to compensate this shortage of power [104].

1.3 Research Objectives

Management control system for power flow is an essential part of developing any hybrid power system. The ultimate aim of this investigation is to develop a more robust control algorithm for providing continuous load power. In addition, depending on the new management criteria, a constant lock circuit CLC is used with a control circuit which deals with a change in both power generation and load demand as a major part for fixing DC link to manage and control system with an ability to overcome various changes. The advanced algorithm is designed to optimize the power flow between the renewable power system and local grid as a backup source to satisfy the load requirements by providing with continuous power using a constant lock circuit CLC. Thus, the thesis objectives are:

1. To investigate design and simulate a CLC circuit with stabilized constant voltage.
2. To install the DC link voltage at a constant value to ensure stability and accurate higher flow of energy.
3. To provide sufficient power for loads connected with renewable energy sources in the DC micro-grid system.

1.4 Scope of Research

The focus of this thesis is on developing a power administration of monitoring strategies at a DC micro-grid hybrid system by using a CLC in different modes. The hybrid power system consists of PTG as a REs and utility grid as a non-REs. So, this thesis develops DC micro-grid control strategies for a hybrid system to provide continuous load power regardless of the consumption of power and generation of power. A comparison between load consumption and RE generation power leads the system to monitor and determine the proper mode that the system should follow. Three modes come into view during DC micro-grid operation. These operational scenarios are the stand-alone scenario, grid scenario, and feedback scenario. Thus, a DC micro-grid control strategy is implemented to achieve: fixing DC link voltage despite variable input voltage or changing in load consumption. Furthermore, extracting maximum power from REs, compensating the shortage power from non-REs to meet load demand, exporting the excess power generated from REs to the grid, and protecting the REs from any overload due to load consumption. In order to achieve our aims in this thesis, it will use the following tool: PROTEUS8 professional software which is a tool for simulating, modeling and analyzing electronic control systems.

1.5 Research Contributions

The major contributions of the dissertation can be summarized as:

1. Fixing the DC link node in DC MG system by constant lock circuit CLC which is proposed. The CLC control strategy fixes the DC link voltage at required value without battery or dummy load. The objective of this integrated strategy is to fix the DC link voltage to the specified voltage value

so as to make the power flow process smoother irrespective of the fluctuating in the generation of power and varying load demand. It also equips DC load with a current which is free of any ripple.

2. The CLC control in a DC MG system is suggested. The CLCC functions to generate a control voltage to CLC to hold the DC link node voltage at a required voltage. Therefore, the target of a CLCC is to monitor the DC link voltage permanently to generate an appropriate control voltage which is applied to CLC for getting the required voltage 24v.
3. The organized control for DC micro-grid system consists of PTG as REs, utility grid, CLC, CLCC, CS, and CSC is proposed for providing enough load demand on the system regardless of the oscillation in odd weather conditions and load demand.
4. Ease of connecting the parallel sources for sharing power in DC micro-grid at grid scenario whatever their voltage is. Therefore, it does not need the precise voltage converter for matching with their voltage. Consequently, consumption power is less.

The notable features of the proposed control strategy are:

- It provides adequate load power regardless the power generation amount.
- It ensures comfortable design for selecting DC link voltage for any desired value.
- It requires no real time communication link which takes no delay time within the control process.
- It is possible to plug and play.
- It is easy to connect parallel source whatever their voltage is because of the constancy of the DC link node.

1.6 Organization of Thesis

This thesis is structured into the following chapters:

Chapter 1 begins with the research overview which is followed by the problem statement. Scope of research is discussed after that. Research contributions are highlighted before the chapter finishes in giving the organizational scheme of the thesis.

Chapter 2 focuses on the micro-grid power system concept, micro-grid operation overview. Then it introduces hydropower generation, power electronic system, and DC microgrid strategies developed for this scientific study.

Chapter 3 describes the overall methodology for DC micro-grid system that includes a brief introduction to the power management algorithm, Pico turbine generator system which consists of energy conversion and regulation system. In addition, discussion is

made on the DC-DC boost converter scheme and the appropriate methodology applied to develop the system. It offers the constant lock circuit CLC and its CLCC control methodology and describes its work strategy. Furthermore, power management algorithm with control system strategies is discussed. It covers methods like standalone scenario, grid scenario, and feedback scenario which are applied to develop the DC micro-grid system. It marks out to backup source stages which consist of a current source CS stage design. Besides these, it also provides exporting power stages and its current source design to enhance DC micro-grid system.

In chapter 4, the results and discussion are discussed. The DC-DC boost converter simulation with constant duty cycle is presented next. A CLC output voltage simulation under variable test is performed. It also provides the results obtained from the simulation study. Integration of operation modes strategy is developed with CLC in DC MG system. This chapter offers standalone scenario and its configuration. The results of this scenario are also presented. The grid scenarios are well brought in this chapter. It also displays the results obtained from simulation study in two cases. Moreover, feedback scenario with its two cases is simulated. The third scenario results are discussed in the end.

Chapter 5 concludes the contributions of this study and provides an overview of the development of CLC with DC micro-grid system. It also recommends the future research scopes to improve the power management control strategy in DC micro-grid system for the electrical market.

REFERENCES

- [1] Patrao, I., Figueres, E., Garcerá, G., & González-Medina, R. (2015). Micro-grid architectures for low voltage distributed generation. *Renewable and Sustainable Energy Reviews*.
- [2] Faggio, A. (2015). Hierarchical control of a DC low voltage micro-grid supplied by Distributed Energy Resources (DERs).
- [3] Luu, N. A. (2014). Control and management strategies for a micro-grid (Doctoral dissertation, Université de Grenoble).
- [4] Myles, P., Miller, J., Knudsen, S., & Grabowski, T. (2011). *Electric Power System Asset Optimization*. Morgantown, WV: National Energy Technology Laboratory.
- [5] Campbell, R. J. (2012, August). Weather-related power outages and electric system resiliency. Washington, DC: Congressional Research Service, Library of Congress.
- [6] Lopes, J. P. (2004). MICROGRIDS Large Scale Integration of Micro generation to Low Voltage Grids-Emergency Strategies and Algorithms.
- [7] Kumar, A., Sah, B., Deng, Y., He, X., Bansal, R. C., & Kumar, P. (2015). Autonomous hybrid renewable energy system optimization for minimum cost.
- [8] Smart Grids, E. T. P. (2006). Vision and Strategy for Europe's Electricity Networks of the Future. European Commission.
- [9] Chu, Z. (2010). PSCAD/EMTDC-based Modeling and Analysis of a Micro-grid with Renewable Energy Sources (Doctoral dissertation, Texas A&M University).
- [10] Lasseter, R. H., & Paigi, P. (2004, June). Microgrid: A conceptual solution. In *Power Electronics Specialists Conference, IEEE*.
- [11] Farhat Quinones, Y., & Martino, M. (2012). Intelligent control for distributed system (Master's thesis, Universitat Politècnica de Catalunya).
- [12] Lee, J., Han, B., & Choi, N. (2010, September). DC micro-grid operational analysis with detailed simulation model for distributed generation. In *Energy Conversion Congress and Exposition (ECCE), IEEE*.
- [13] Kurohane, K., Uehara, A., Senjyu, T., Yona, A., Urasaki, N., Funabashi, T., & Kim, C. H. (2011). Control strategy for a distributed DC power system with renewable energy. *Renewable Energy*.

- [14] Kakigano, H., Miura, Y., Ise, T., & Uchida, R. (2006, June). DC micro-grid for super high quality distribution-system configuration and control of distributed generations and energy storage devices. IEEE.
- [15] H. Kakigano, Y. Miura, T. Ise, and R. Uchida, (2007) "DC voltage control of the DC micro-grid for super high quality distribution," in Power Conversion Conference-Nagoya.
- [16] Ito, Y., Zhongqing, Y., & Akagi, H. (2004, August). DC microgrid based distribution power generation system. In Power Electronics and Motion Control Conference.
- [17] Masters, G. M. (2013). Renewable and efficient electric power systems. John Wiley & Sons.
- [18] Liu, X., Wang, P., & Loh, P. C. (2011). A hybrid AC/DC microgrid and its coordination control. IEEE Transactions on Smart Grid.
- [19] Jian, Z. H., He, Z. Y., Jia, J., & Xie, Y. (2013, June). A review of control strategies for DC micro-grid. In Intelligent Control and Information Processing (ICICIP), 2013 Fourth International Conference. IEEE.
- [20] Timbus, A., Liserre, M., Teodorescu, R., Rodriguez, P., & Blaabjerg, F. (2009). Evaluation of current controllers for distributed power generation systems. IEEE Transactions on power electronics..
- [21] Lasseter, R. H. (2011). Smart distribution: Coupled micro-grids. Proceedings of the IEEE.
- [22] Liu, X., Wang, P., & Loh, P. C. (2011). A hybrid AC/DC microgrid and its coordination control. IEEE Transactions on Smart Grid.
- [23] Baran, M. E., & Mahajan, N. R. (2003). DC distribution for industrial systems: Opportunities and challenges. IEEE Transactions on Industry Applications.
- [24] Liu, C., Chau, K. T., Diao, C., Zhong, J., Zhang, X., Gao, S., & Wu, D. (2010, September). A new DC micro-grid system using renewable energy and electric vehicles for smart energy delivery. In Vehicle Power and Propulsion Conference (VPPC). IEEE.
- [25] S. V. Dhople, A. Davoudi, P. L. Chapman, and A. D. Dominguez-Garcia, "A unified approach to reliability assessment of multiphase dc/dc converters in photovoltaic energy conversion systems," IEEE Trans.
- [26] Jian, Z. H., He, Z. Y., Jia, J., & Xie, Y. (2013, June). A review of control strategies for DC micro-grid. In Intelligent Control and Information Processing (ICICIP), 2013 Fourth International Conference. IEEE.

- [27] Baker, P., McGranaghan, M., Ortmeier, T., Crudele, D., Key, T., & Smith, J. (2008). Advanced Grid Planning and Operation. NREL/SR-581-42294. Golden, CO: National Renewable Energy Laboratory.
- [28] Kakigano, H., Miura, Y., Ise, T., & Uchida, R. (2006, June). DC micro-grid for super high quality distribution-system configuration and control of distributed generations and energy storage devices. IEEE.
- [29] El-Samahy, I., & El-Saadany, E. (2005, June). The effect of DG on power quality in a deregulated environment. In Power Engineering Society General Meeting. IEEE.
- [30] Khatri, P. R., Jape, V. S., Lokhande, M., & Motling, B. S. (2005, November). Improving power quality by distributed generation. In Power Engineering Conference. IEEE.
- [31] Lazaroiu, G. C., Popescu, M. O., Dumbrava, V., & Stroe, C. (2011, September). Voltage control system and transient analysis of DG interfaced dc distribution system. In Renewable Power Generation. IET.
- [32] Schonberger, J. K. (2006). Distributed control of a nano-grid using dc bus signalling.
- [33] Barnes, M., Kondoh, J., Asano, H., Oyarzabal, J., Ventakaramanan, G., Lasseter, R. & Green, T. (2007, April). Real-world micro-grids-an overview. In System of Systems Engineering. IEEE.
- [34] Bottaccioli, L., Patti, E., Acquaviva, A., Macii, E., Jarre, M., & Noussan, M. (2015, September). A tool-chain to foster a new business model for photovoltaic systems integration exploiting an Energy Community approach. In Emerging Technologies & Factory Automation (ETFA). IEEE.
- [35] Jian, Z. H., He, Z. Y., Jia, J., & Xie, Y. (2013, June). A review of control strategies for DC micro-grid. In Intelligent Control and Information Processing (ICICIP). IEEE.
- [36] Dalbon, W., Roscia, M., & Zaninelli, D. (2002, July). Hybrid photovoltaic system control for enhancing sustainable energy. In Power Engineering Society Summer Meeting. IEEE.
- [37] Chedid, R., & Rahman, S. (1997). Unit sizing and control of hybrid wind-solar power systems. IEEE Transactions on energy conversion.
- [38] Kim, J. W., Choi, H. S., & Cho, B. H. (2002). A novel droop method for converter parallel operation. IEEE Transactions on Power Electronics.
- [39] Kurohane, K., Senjyu, T., Yona, A., Urasaki, N., Muhando, E. B., & Funabashi, T. (2010, April). A high quality power supply system with DC smart grid. In Transmission and Distribution Conference and Exposition. IEEE.

- [40] 15 Boroyevich, D., Cvetković, I., Dong, D., Burgos, R., Wang, F., & Lee, F. (2010, May). Future electronic power distribution systems a contemplative view. In Optimization of Electrical and Electronic Equipment (OPTIM), 2010 12th International Conference. IEEE.
- [41] Ito, Y., Zhongqing, Y., & Akagi, H. (2004, August). DC micro-grid based distribution power generation system. In Power Electronics and Motion Control Conference. IEEE.
- [42] Zhang, L., Wu, T., Xing, Y., Sun, K., & Gurrero, J. M. (2011, March). Power control of DC microgrid using DC bus signaling. In Applied Power Electronics Conference and Exposition (APEC). IEEE.
- [43] Chen, D., & Xu, L. (2012). Autonomous DC voltage control of a DC micro-grid with multiple slack terminals. IEEE Transactions on Power Systems.
- [44] Sun, X., Lian, Z., Wang, B., & Li, X. (2009, May). A hybrid renewable DC micro-grid voltage control. In Power Electronics and Motion Control Conference. IEEE.
- [45] Salomonsson, D., Soder, L., & Sannino, A. (2007, September). An adaptive control system for a DC microgrid for data centers. In Industry Applications Conference. IEEE.
- [46] Boroyevich, D., Cvetković, I., Dong, D., Burgos, R., Wang, F., & Lee, F. (2010, May). Future electronic power distribution systems a contemplative view. In Optimization of Electrical and Electronic Equipment (OPTIM). IEEE.
- [47] Bhaskara, S. N., & Chowdhury, B. H. (2012, July). Micro-grids—A review of modeling, control, protection, simulation and future potential. In Power and Energy Society General Meeting. IEEE.
- [48] Tsikalakis, A. G., & Hatziargyriou, N. D. (2011, July). Centralized control for optimizing microgrids operation. In Power and Energy Society General Meeting. IEEE.
- [49] Guerrero, J. M., Vasquez, J. C., Matas, J., De Vicuña, L. G., & Castilla, M. (2011). Hierarchical control of droop-controlled AC and DC micro-grids - general approach toward standardization. IEEE Transactions on Industrial Electronics.
- [50] Chen, D., & Xu, L. (2011, September). DC microgrid with variable generations and energy storage. In Renewable Power Generation. IET.
- [51] Kakigano, H., Miura, Y., & Ise, T. (2013). Distribution voltage control for dc micro-grids using fuzzy control and gain-scheduling technique. IEEE transactions on power electronics.

- [52] Kakigano, H., Nishino, A., & Ise, T. (2011, May). Distribution voltage control for DC micro-grid with fuzzy control and gain-scheduling control. In Power Electronics and ECCE Asia (ICPE & ECCE). IEEE.
- [53] Kakigano, H., Nishino, A., Miura, Y., & Ise, T. (2010, September). Distribution voltage control for DC micro-grid by converters of energy storages considering the stored energy. In Energy Conversion Congress and Exposition (ECCE). IEEE.
- [54] Kakigano, H., Miura, Y., & Ise, T. (2010). Low-voltage bipolar-type DC micro-grid for super high quality distribution. IEEE transactions on power electronics.
- [55] Thounthong, P., Sikkabut, S., Luksanasakul, A., Koseeyaporn, P., Sethakul, P., Pierfederici, S., & Davat, B. (2012, May). Fuzzy logic based DC bus voltage control of a standalone photovoltaic/fuel cell/super capacitor power plant. In Environment and electrical engineering (EEEIC). IEEE.
- [56] Colson, C.M. Nehrir, M.H. A Review of Challenges to Real-Time Power Management of Micro-grids[C]. '09. IEEE Power & Energy Society General Meeting.
- [57] Kulasekera, A. L., et al. "A review on multi-agent systems in micro-grid applications." Innovative Smart Grid Technologies-India (ISGT India). IEEE.
- [58] Jiang, Z. (2006, December). Agent-based control framework for distributed energy resources micro-grids. In Proceedings of the IEEE/WIC/ACM international conference on Intelligent Agent Technology. IEEE Computer Society.
- [59] Aung, H. N., Khambadkone, A. M., Srinivasan, D., & Logenthiran, T. (2010, December). Agent-based intelligent control for real-time operation of a micro-grid. In Power Electronics, Drives and Energy Systems (PEDES). IEEE.
- [60] Magne, P., Nahid-Mobarakkeh, B., & Pierfederici, S. (2012, June). A design method for a fault-tolerant multi-agent stabilizing system for DC micro-grids with constant power loads. In Transportation Electrification Conference and Expo (ITEC). IEEE.
- [61] Yoo, C. H., Choi, W. J., Chung, I. Y., Won, D. J., Hong, S. S., & Jang, B. J. (2012, July). Hardware-in-the-loop simulation of DC micro-grid with Multi-Agent System for emergency demand response. In Power and Energy Society General Meeting. IEEE.
- [62] Fardanesh, B. (2002). Future trends in power system control. IEEE Computer Applications in Power.
- [63] Luo, S., Ye, Z., Lin, R. L., & Lee, F. C. (1999). A classification and evaluation of paralleling methods for power supply modules. In Power Electronics Specialists Conference. IEEE.

- [64] Tang, W., & Lasseter, R. H. (2000). An LVDC industrial power distribution system without central control unit. In Power Electronics Specialists Conference. IEEE.
- [65] Karlsson, P., & Svensson, J. (2003). DC bus voltage control for a distributed power system. IEEE Transactions on Power Electronics.
- [66] Tuladhar, A., Jin, H., Unger, T., & Mauch, K. (1997, February). Parallel operation of single phase inverter modules with no control interconnections. In Applied Power Electronics Conference and Exposition. IEEE.
- [67] Kundur, P. (1994). Power system stability and control (Vol. 7). N. J. Balu, & M. G. Lauby (Eds.). New York: McGraw-hill.
- [68] Boroyevich, D., Xing, K., & Lee, F. C. (1999, August). Design of parallel sources in DC distributed power systems by using gain-scheduling technique. In Power Electronics Specialists Conference. IEEE.
- [69] Sebastian, R., Castro, M., Sancristobal, E., Yeves, F., Peire, J., & Quesada, J. (2002, November). Approaching hybrid wind-diesel systems and Controller Area Network. In IECON 02 [Industrial Electronics Society. IEEE.
- [70] Wood, A. J., & Wollenberg, B. F. (2012). Power generation, operation, and control. John Wiley & Sons.
- [71] Nogaret, E., Stavrakakis, G., Kariniotakis, G., Papadopoulos, M., Hatziaargyriou, N., Androutsos, A. & Gatopoulos, J. (1997). An advanced control system for the optimal operation and management of medium size power systems with a large penetration from renewable power sources. Renewable Energy.
- [72] Agbossou, K., Kolhe, M., Hamelin, J., & Bose, T. K. (2004). Performance of a stand-alone renewable energy system based on energy storage as hydrogen. IEEE Transactions on energy Conversion.
- [73] Newbury, J. E., & Morris, K. J. (1999). Power line carrier systems for industrial control applications. IEEE Transactions on Power Delivery.
- [74] Shickhuber, G., & McCarthy, O. (1997). Control using power lines-a European view. Computing & Control Engineering Journal.
- [75] Johnson, B. K., & Lasseter, R. (1993, June). An industrial power distribution system featuring UPS properties. In Power Electronics Specialists Conference. IEEE.
- [76] Tang, W., & Lasseter, R. H. (2000). An LVDC industrial power distribution system without central control unit. In Power Electronics Specialists Conference. IEEE.

- [77] Razak, J. A., Ali, Y., Alghoul, M. A., Zainol, M. S., Zaharim, A., & Sopian, K. (2010). Application of cross flow turbine in off-grid Pico hydro renewable energy system. Proceeding of the American-Math.
- [78] Thakur, D. (2015). Power management strategies for a wind energy source in an isolated micro-grid and grid connected system (Doctoral dissertation, The University of Western Ontario).
- [79] Mei, Q., Shan, M., Liu, L., & Guerrero, J. M. (2011). A novel improved variable step-size incremental-resistance MPPT method for PV systems. IEEE Transactions on Industrial Electronics.
- [80] Elgendy, M. A., Zahawi, B., & Atkinson, D. J. (2013). Assessment of the incremental conductance maximum power point tracking algorithm. IEEE Transactions on sustainable energy.
- [81] Jiang, Y., Qahouq, J. A. A., & Haskew, T. A. (2013). Adaptive step size with adaptive-perturbation-frequency digital MPPT controller for a single-sensor photovoltaic solar system. IEEE transactions on power Electronics.
- [82] FAGGIO, A. (2015). Hierarchical control of a DC low voltage micro-grid supplied by Distributed Energy Resources (DERs).
- [83] Ranjbar, A. H. (2013). Reliability analysis of modern hybrid micro-grids. The university of Texas at Dallas.
- [84] Tao, H., Kotsopoulos, A., Duarte, J. L., & Hendrix, M. A. (2006). Family of multiport bidirectional DC–DC converters. IEE Proceedings-Electric Power Applications.
- [85] Kwasinski, A. (2009). Identification of feasible topologies for multiple-input DC–DC converters. IEEE Transactions on Power Electronics.
- [86] Jiang, W., & Fahimi, B. (2009, February). Multi-port power electric interface for renewable energy sources. In Applied Power Electronics Conference and Exposition. IEEE.
- [87] Jiang, W., & Fahimi, B. (2011). Multiport power electronic interface—concept, modeling, and design. IEEE Transactions on Power Electronics.
- [88] Jiang, W., Brunet, J., & Fahimi, B. (2008, June). Application of active current sharing control in fuel cell-battery off-line ups system. In Power Electronics Specialists Conference. IEEE.
- [89] Patel, R. (2014). Design and Implementation of an Isolated Solar Photovoltaic Power Generation System (Doctoral dissertation).
- [90] Rashid, M. H. (2009). Power electronics: circuits, devices, and applications. Pearson Education India.

- [91] Xiao, W., Ozog, N., & Dunford, W. G. (2007). Topology study of photovoltaic interface for maximum power point tracking. *IEEE Transactions on Industrial Electronics*.
- [92] Zhang, L., Hurley, W. G., & Wölfle, W. H. (2011). A new approach to achieve maximum power point tracking for PV system with a variable inductor. *IEEE Transactions on Power Electronics*.
- [93] Roman, E., Alonso, R., Ibañez, P., Elorduizapatrietxe, S., & Goitia, D. (2006). Intelligent PV module for grid-connected PV systems. *IEEE Transactions on Industrial electronics*.
- [94] Islam, M. (2014). Power management and control for solar-wind-diesel stand-alone hybrid energy systems.
- [95] Phrakonkham, S., Le Chenadec, J. Y., Diallo, D., Remy, G., & Marchand, C. (2010). Reviews on micro-grid configuration and dedicated hybrid system optimization software tools: application to Laos. *Engineering journal*.
- [96] Sadorsky, P. (2009). Renewable energy consumption and income in emerging economies. *Energy policy*.
- [97] Ho-Yan, B. (2012). Design of a low head Pico hydro turbine for rural electrification in Cameroon (Doctoral dissertation).
- [98] Abdel-Rahim, O., Funato, H., & Junnosuke, H. (2016, November). Droop method based on model predictive control for DC micro-grid. In *Electrical Machines and Systems (ICEMS)*. IEEE.
- [99] Mirshekarpour, B., & Davari, S. A. (2016, February). Efficiency optimization and power management in a stand-alone photovoltaic (PV) water pumping system. In *Power Electronics and Drive Systems Technologies Conference (PEDSTC)*. IEEE.
- [100] Lin, Z., Du, J., Wu, J., & He, X. (2015, June). Novel communication method between power converters for DC micro-grid applications. In *DC Micro-grids (ICDCM)*. IEEE.
- [101] Liu, C., Chau, K. T., Diao, C., Zhong, J., Zhang, X., Gao, S., & Wu, D. (2010, September). A new DC micro-grid system using renewable energy and electric vehicles for smart energy delivery. In *Vehicle Power and Propulsion Conference (VPPC)*. IEEE.
- [102] Liang, X. (2016). Emerging power quality challenges due to integration of renewable energy sources. *IEEE Transactions on Industry Applications*.
- [103] Thakur, D. (2015). Power management strategies for a wind energy source in an isolated micro-grid and grid connected system (Doctoral dissertation, The University of Western Ontario).

- [104] Kakigano, H., Miura, Y., Ise, T., Momose, T., & Hayakawa, H. (2008, July). Fundamental characteristics of DC micro-grid for residential houses with cogeneration system in each house. In Power and Energy Society General Meeting-Conversion and Delivery of Electrical Energy. IEEE.
- [105] Corcau, J. I., & Dinca, L. (2014, October). Numerical modeling of a DC to DC boost converter. In Applied and Theoretical Electricity (ICATE). IEEE.
- [106] Reji, B., Arun, S., & Benny, A. (2014, July). Solar powered multilevel dc fed simplified inverter. In Emerging Research Areas: Magnetics, Machines and Drives (AICERA/ ICMMD). IEEE.
- [107] Yu, J., Ming, W., Haitao, L., Yang, L., & Ying, Z. (2016, July). Bidirectional Droop Control of Interlinking Converter in AC/DC Hybrid Micro-Grid. In Information Science and Control Engineering (ICISCE). IEEE.