



UNIVERSITI PUTRA MALAYSIA

***LIGHTNING-INDUCED TRANSIENT EFFECTS IN HYBRID PV-WIND
SYSTEM AND ITS MITIGATIONS***

ZMNAKO MOHAMMED KHURSHID

FK 2018 119



**LIGHTNING-INDUCED TRANSIENT EFFECTS IN HYBRID PV-WIND
SYSTEM AND ITS MITIGATION**

By

ZMNAKO MOHAMMED KHURSHID

**Thesis Submitted to the School of Graduate Studies, Universiti Putra Malaysia,
in Fulfillment of the Requirements for the Degree of Master of Science**

August 2018

COPYRIGHT

All material contained within the thesis, including without limitation text, logos, icons, photographs, and all other artwork, is copyright material of Universiti Putra Malaysia unless otherwise stated. Use may be made of any material contained within the thesis for non-commercial purposes from the copyright holder. Commercial use of material may only be made with the express, prior, written permission of Universiti Putra Malaysia.

Copyright © Universiti Putra Malaysia



Abstract of thesis presented to the Senate of Universiti Putra Malaysia in fulfillment of the requirement for the degree of Master of Science

LIGHTNING-INDUCED TRANSIENT EFFECTS IN HYBRID PV–WIND SYSTEM AND ITS MITIGATION

By

ZMNAKO MOHAMMED KHURSHID

August 2018

Chairman : Associate Professor Hashim Hizam, PhD
Faculty : Engineering

Lightning strikes cause current injection into the hybrid PV–wind system at the point of contact. Overvoltage generated due to lightning travels along the system where it can affect expensive equipment in the hybrid PV–wind system. The literature review examines related previous works and identifies the gaps created by earlier works that have focused only on the problems associated with the lightning effects on the PV and WT systems either theoretically or experimentally. Studies also have focused on a single type of RE source and not on hybrid systems. The current study fills the gap concerning the lightning-induced transient effect on a 4.1 MW grid-connected hybrid PV–wind system and the mitigation of the lightning effect using the Power Systems Computer Aided Design (PSCAD) software. The system consists of a 2 MW PV farm, a 2.1 MW wind farm, battery system and loads which are all connected to a 33 kV grid along with a 0.480 kV AC bus and a boost interfacing transformer. In addition, the Heidler function was modelled to generate different lightning currents using the software mentioned above.

In this research, transient effects simulation and analysis due to direct lightning strikes to the system were conducted, three points of the hybrid system were selected to observe the transient overvoltage when each point was subjected to lightning strokes separately. The simulation results were obtained for different lightning current waveforms such as 8/20 μ s, 10/350 μ s, negative first stroke, negative subsequent stroke and positive stroke with and without lightning protection system (LPS) in several simulation cases. In addition, surge protective devices (SPDs) have been developed based on the European Commission for Electrotechnical Standardization (CENELEC) standard with the most appropriate ratings for the threat level and the equipment/component specification of the hybrid system to investigate mitigation of the lightning transient to an acceptable level. The results showed that the connected

SPDs to the system can successfully clamp the generated transient overvoltages due to lightning for all simulation cases, except the SPDs connected at the DC side of PV system fail to clamp the generated overvoltage in the case with 5% of positive stroke lightning current. On the basis of the simulation results, the recommendations have been proposed to developers of lightning protection. The research objectives were achieved through simulation and analysis, findings of this research can be a useful guideline towards the application of a lightning protection standard for the hybrid PV–wind system.



Abstrak tesis yang dikemukakan kepada Senat Universiti Putra Malaysia sebagai memenuhi keperluan untuk ijazah Master Sains

KESAN FANA ARUHAN-KILAT DI DALAM SISTEM HIBRID PV-ANGIN DAN PENGURANGAN

Oleh

ZMNAKO MOHAMMED KHURSHID

Ogos 2018

Pengerusi : Profesor Madya Hashim Hizam, PhD
Fakulti : Kejuruteraan

Sambaran kilat menyebabkan suntikan arus ke dalam sistem hibrid PV-angin di titik sentuhan. Voltan lampau yang dihasilkan oleh kilat berjalan di sepanjang sistem di mana ia boleh menjejaskan peralatan mahal di dalam sistem hibrid PV-angin. Kajian kepustakaan mengkaji kerja-kerja berkaitan yang lalu dan mengenal pasti jurang-jurang yang dihasilkan oleh karya-karya terdahulu yang hanya memberi tumpuan pada masalah-masalah yang berkaitan dengan kesan kilat ke atas sistem PV dan WT baik secara teori atau eksperimen. Kajian juga telah menumpukan pada satu jenis sumber RE dan bukan pada sistem-sistem hibrid. Kajian semasa ini mengisi jurang mengenai kesan sementara yang disebabkan oleh kilat pada sistem hibrid PV-angin yang terhubung-grid 4.1 MW dan pengurangan kesan kilat menggunakan perisian Reka Bentuk Bantuan Komputer Sistem Kuasa (PSCAD). Sistem ini terdiri dari ladang PV 2 MW, sebuah ladang angin 2.1 MW, sistem bateri dan beban yang semuanya disambungkan ke grid 33 kV bersama dengan bus AC 0.480 kV dan satu transformer penambah antara muka. Di samping itu, fungsi Heidler telah dimodelkan untuk menghasilkan arus kilat yang berbeza menggunakan perisian yang disebutkan di atas.

Dalam kajian ini, simulasi dan analisis kesan-kesan fana disebabkan oleh kilat terus kepada sistem telah dijalankan, tiga titik sistem hibrid tersebut telah dipilih untuk memerhatikan voltan lampau fana apabila setiap titik tertakluk kepada kilat secara berasingan. Hasil simulasi diperoleh untuk bentuk gelombang arus kilat yang berbeza seperti 8/20 μ s, 10/350 μ s, sambaran pertama negatif, sambaran seterusnya negatif dan sambaran positif dengan dan tanpa sistem perlindungan kilat (LPS) di dalam beberapa kes simulasi. Di samping itu, peranti pelindung pusuan (SPD) telah dibangunkan berdasarkan piawaian Suruhanjaya Eropah bagi Pemiawaian Elektroteknik (CENELEC) dengan penilaian yang paling sesuai untuk tahap ancaman dan spesifikasi peralatan/komponen sistem hibrid untuk menyiasat pengurangan kesan

sementara kilat ke suatu tahap yang boleh diterima. Hasilnya menunjukkan bahawa SPD yang bersambung ke sistem itu dapat berjaya mengatasi voltan sementara yang dijana disebabkan oleh kilat bagi semua kes simulasi, kecuali SPD yang disambungkan di sebelah DC sistem PV gagal untuk mengatasi voltan lampau yang dijanakan dalam kes 5% arus sambaran kilat positif. Berdasarkan keputusan simulasi, saranan telah dicadangkan kepada pemaju perlindungan kilat. Objektif penyelidikan telah dicapai melalui simulasi dan analisis, penemuan penyelidikan ini boleh menjadi garis panduan yang berguna ke arah penggunaan piawaian perlindungan kilat untuk sistem hibrid PV-angin.



ACKNOWLEDGEMENTS

All praises to Allah who gave me the ability, capacity, health, and sanity to reach this level of education. Peace and blessings of Allah be upon our beloved Prophet Muhammad.

I am heartily thankful to my chairperson of the supervisory committee, Prof. Dr. Hashim Hizam, and supervisory committee member Prof. Dr. Chandima Gomes, for their valuable guidance, patience and constant encouragement throughout my study. I am deeply grateful to have such a wonderful team of supervisors. I also wish to acknowledge and commend the Department of Electrical and Electronics Engineering staffs and technicians who have provided me with the place and equipment to do the study. I am highly thankful to my family and my brothers for their support, patience, endurance, and perseverance during my absence being away for my study.

I am also grateful to all my friends both in Malaysia and Kurdistan who are too many to be mentioned individually here. They contributed morally and psychologically in my moments during the hurdles of this study.

This thesis was submitted to the Senate of the Universiti Putra Malaysia and has been accepted as fulfillment of the requirement for the degree of Master of Science. The members of the Supervisory Committee were as follows:

Hashim Hizam, PhD

Associate Professor
Faculty of Engineering
Universiti Putra Malaysia
(Chairman)

Chandima Gomes, PhD

Professor
Faculty of Engineering
Universiti Putra Malaysia
(Member)

ROBIAH BINTI YUNUS, PhD

Professor and Dean
School of Graduate Studies
Universiti Putra Malaysia

Date:

Declaration by graduate student

I hereby confirm that:

- this thesis is my original work;
- quotations, illustrations and citations have been duly referenced;
- this thesis has not been submitted previously or concurrently for any other degree at any institutions;
- intellectual property from the thesis and copyright of thesis are fully-owned by Universiti Putra Malaysia, as according to the Universiti Putra Malaysia (Research) Rules 2012;
- written permission must be obtained from supervisor and the office of Deputy Vice-Chancellor (Research and innovation) before thesis is published (in the form of written, printed or in electronic form) including books, journals, modules, proceedings, popular writings, seminar papers, manuscripts, posters, reports, lecture notes, learning modules or any other materials as stated in the Universiti Putra Malaysia (Research) Rules 2012;
- there is no plagiarism or data falsification/fabrication in the thesis, and scholarly integrity is upheld as according to the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) and the Universiti Putra Malaysia (Research) Rules 2012. The thesis has undergone plagiarism detection software

Signature: _____ Date: _____

Name and Matric No: Zmnako Mohammed Khurshid, GS45919

Declaration by Members of Supervisory Committee

This is to confirm that:

- the research conducted and the writing of this thesis was under our supervision;
- supervision responsibilities as stated in the Universiti Putra Malaysia (Graduate Studies) Rules 2003 (Revision 2012-2013) were adhered to.

Signature: _____

Name of Chairman
of Supervisory
Committee:

Associate Professor Dr. Hashim Hizam

Signature: _____

Name of Member
of Supervisory
Committee:

Professor Dr. Chandima Gomes

TABLE OF CONTENTS

	Page
ABSTRACT	i
ABSTRAK	iii
ACKNOWLEDGEMENTS	v
APPROVAL	vi
DECLARATION	viii
LIST OF TABLES	xiii
LIST OF FIGURES	xv
LIST OF ABBREVIATIONS	xix
LIST OF NOTATIONS	xxi
 CHAPTER	
1 INTRODUCTION	1
1.1 Background	1
1.2 Problem Statement	1
1.3 Objectives of the Research	2
1.4 Scope of the Work	3
1.5 Significance of the Research	3
1.6 Thesis Layout	3
 2 LITERATURE REVIEW	5
2.1 Introduction	5
2.2 Lightning	5
2.3 Overview of PV Energy	8
2.3.1 Hybrid PV System	9
2.3.2 PV Module	10
2.3.3 DC–DC Converter	11
2.3.4 Energy Storage	11
2.3.5 DC–AC Inverter	11
2.4 Overview of Wind Energy	12
2.4.1 WT Generator	12
2.4.2 WT Transformer	14
2.5 Global Lightning Protection Codes and Standards	14
2.5.1 Lightning Protection Codes and Standards in the U.S.	14
2.5.2 Lightning Protection Codes and Standards in Other Nations	15
2.5.3 CENELEC, CIGRE, and IEC Standards	15
2.5.4 Risk Evaluation According to IEC EN 62305-2	16
2.6 Overview of Previous Lightning Studies on PV and Wind Systems	17
2.6.1 Lightning Studies based on Theoretical and Simulation Works	18
2.6.2 Lightning Studies based on Experimental Works	18
2.7 SPD	22

2.7.1	Spark Gaps	22
2.7.2	GDTs	23
2.7.3	SAD	24
2.7.4	MOVs	24
2.8	Surge Arrester Models	25
2.8.1	Physical Model	25
2.8.2	IEEE Model	25
2.8.3	Pinceti–Gianettoni Model	26
2.8.4	Fernandez–Diaz Model	27
2.9	Summary	28
3	METHODOLOGY	29
3.1	Introduction	29
3.2	Modelling of Hybrid PV-wind System	31
3.2.1	Modelling of PV Farm	33
3.2.2	Modelling of Voltage Source Inverter (VSI)	34
3.2.3	Modelling of Battery System	41
3.2.4	Modelling of Wind Farm	43
3.2.5	Modelling of Load	47
3.3	Modelling of Lightning Current Using Heidler Function	47
3.4	Description of Case Study	49
3.4.1	Hybrid System at Steady-state Condition	50
3.4.2	Transient Effects Analysis on Hybrid System without LPS	50
3.4.3	Design LPS based on CENELEC Standard	54
3.4.4	Transient Effects Analysis on Hybrid System with LPS	62
3.4.5	Transient Effects Analysis with Different Load Value	62
3.5	Validation	62
3.6	Summary	65
4	RESULTS AND DISCUSSION	66
4.1	Introduction	66
4.2	Simulation Result of Hybrid System at Steady-state Condition	66
4.3	Simulation Results of Transient Effects Analysis of Hybrid System	68
4.3.1	Case 1 : 8/20 μ s Standard Lightning Waveform	68
4.3.2	Case 2 : 10/350 μ s Standard Lightning Waveform	76
4.3.3	Case 3 : Negative First Stroke	82
4.3.4	Case 4 : Negative Subsequent Stroke	92
4.3.5	Case 5 : Positive Stroke	93
4.4	Simulation Results of Different SPD Tests Connected at WT Side	95
4.4.1	Case 1 : Parallel MOV Surge Arrester Test	95
4.4.2	Case 2 : Parallel MOV and Spark Gap Test	98
4.5	Simulation Results of Transient Effects Analysis with Different Load Value	102
4.6	Recommendations to Lightning Protection Developers	102
4.7	Validation Results	103

5	CONCLUSION AND FUTURE WORK	107
5.1	Conclusion	107
5.2	Contribution	108
5.3	Future Work	108
	REFERENCES	109
	APPENDICES	119
	BIODATA OF STUDENT	144
	LIST OF PUBLICATIONS	145



LIST OF TABLES

Table	Page
2.1 Tabulated values of lightning current parameters taken from CIGRE (Standard, 2006a)	7
2.2 Summary of lightning studies based on theoretical and simulation works	20
2.3 Summary of lightning studies based on experimental works	21
2.4 Characteristics of different types of surge arresters	24
3.1 Parameters of a PV system	34
3.2 Parameters of inverters	35
3.3 Parameters of wind farm modelling	44
3.4 Parameters of SPDs used in the system	56
3.5 I–V characteristics of 2.3 kV SPDs on AC system side	56
3.6 I–V characteristics of 4 kV surge arresters on DC side of PV system	57
3.7 Data of surge arresters 1, 2 and 3	62
3.8 Model parameters of arresters	63
3.9 : I–V characteristics of surge arrester 1	63
3.10 I–V characteristics of surge arrester 2	63
3.11 I–V characteristics of surge arrester 3	63
4.1 Observed transient overvoltage and current at different points of the system due to 8/20 μ s lightning current without LPS	74
4.2 Observed transient overvoltage and current at different points of the system due to 8/20 μ s lightning current with LPS	74
4.3 Observed energy and current through arresters due to 8/20 μ s lightning current	75
4.4 Observed transient overvoltage and current at different points of the system due to 10/350 μ s lightning current without LPS	80

4.5	Observed transient overvoltage and current at different points of the system due to 10/350 μ s lightning current with LPS	80
4.6	Observed energy and current through arresters due to 10/350 μ s lightning current	81
4.7	Observed transient overvoltage and current at different points of the system due to negative first-stroke lightning current without LPS	90
4.8	Observed transient overvoltage and current at different points of the system due to negative first-stroke lightning current with LPS	90
4.9	Observed energy and current through arresters due to negative first-stroke lightning current	91
4.10	Summary results of different SPD connections at WT side	101
4.11	Residual voltage to varistors with 8/20 μ s 10 kA current impulse based on ATP	105
4.12	Absorbed energy by varistors with 8/20 μ s 10 kA current impulse based on ATP	105
4.13	Residual voltage to varistors with 8/20 μ s 10 kA current impulse based on PSCAD	106
4.14	Absorbed energy by varistors with 8/20 μ s 10 kA current impulse based on PSCAD	106

LIST OF FIGURES

Figure	Page
2.1 Types of cloud-to-ground lightning flashes: (a) downward negative lightning, (b) downward positive lightning, (c) upward positive lightning and (d) upward negative lightning	6
2.2 Parameters of lightning current waveshape	7
2.3 Classification of PV systems	8
2.4 Simplified block diagram of a hybrid system	10
2.5 Processes in an irradiated solar cell	10
2.6 Buck–boost converter	11
2.7 Dominant WT technologies	13
2.8 Typical wind energy stand-alone system	14
2.9 Risk components for a solar power plant	17
2.10 Induced voltage for flashes to a natural LPS	17
2.11 Spark gap surge arrester	23
2.12 GDT arrester	23
2.13 Physical model	25
2.14 IEEE model	26
2.15 Pinceti–Gianettoni model	27
2.16 Fernandez–Diaz model	27
3.1 Flow chart of research design and methodology	30
3.2 Classification of main modelling parts of hybrid PV–wind system	31
3.3 4.1 MW hybrid grid-connected system	32
3.4 Modelling design of 2 MW PV farm	33
3.5 Modelling circuit of a two-level three - phase inverter	35

3.6	PLL block and Clarke and Park transformations applied to the VSI three-phase voltage	36
3.7	Flow chart of inverter control system	36
3.8	PI controller	38
3.9	Control circuit of VSI using Clark and Park transformation	39
3.10	abc axis reference voltage calculated by using inverse Clark and Park transformations	40
3.11	Modulator to generate IGBT signals	41
3.12	Power storage system with a bidirectional DC–DC converter	42
3.13	: 200 V battery pack circuit	42
3.14	DC–DC buck–boost converter circuit	42
3.15	Upper-level manual controller	43
3.16	Modelling design of 2.1 MW wind farm	45
3.17	WT model to produce required torque	46
3.18	2.1 MW induction generator modelling of wind farm	47
3.19	RLC variable load	47
3.20	Heidler function using PSCAD	48
3.21	Classification of case study	49
3.22	8/20 μ s and 10/350 μ s 100 kA standard lightning current waveforms	50
3.23	Negative first stroke, negative subsequent stroke and positive stroke with 95% value	51
3.24	Negative first stroke, negative subsequent stroke and positive stroke with 50% value	51
3.25	Negative first stroke, negative subsequent stroke and positive stroke with 5% value	51
3.26	Lightning striking points at hybrid system	53
3.27	SPD installation on hybrid system according to CENELEC standard	55
3.28	I–V characteristic curves of 4 and 2.3 kV surge arresters	57

3.29	I–V characteristics of surge arresters in PSCAD: (A) 4 kV and (B) 2.3 kV	58
3.30	SPD test circuit using PSCAD	59
3.31	10/350 μ s 25 kA lightning current waveform	59
3.32	Clamping voltage of 2.3 kV class 1 SPD	59
3.33	Clamping voltage of 4 kV class 1 SPD	59
3.34	Hybrid system with connection of surge arresters according to standards	61
3.35	IEEE model for surge arrester 1 with PSCAD	64
3.36	Pinceti–Gianettoni model for surge arrester 1 with PSCAD	65
3.37	8/20 μ s 10 kA lightning current waveform	65
4.1	Output power, voltage and current at steady-state condition: (A) PV farm, (B) wind farm, (C) entire 4.1 MW grid-connected hybrid system	67
4.2	Direction of transient overvoltage at wind farm without LPS	69
4.3	Direction of transient overvoltage at wind farm without LPS	69
4.4	Direction of transient overvoltage at PV farm with LPS	71
4.5	Observed transient overvoltage and current at different points of the system due to 8/20 μ s 100 kA lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, without LPS	72
4.6	Transient overvoltage, current and arrester's energy of the system due to 8/20 μ s 100 kA lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, with LPS	73
4.7	8/20 μ s and 10/350 μ s 100 kA standard lightning current waveforms	77
4.8	Observed transient overvoltage and current at different points of the system due to 10/350 μ s 100 kA lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, without LPS	78
4.9	Transient overvoltage, current and arrester's energy of the system due to 10/350 μ s 100 kA lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, with LPS	79

4.10	Observed transient overvoltage and current at different points of the system due to 95% of negative first stroke lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, without LPS	84
4.11	Transient overvoltage, current and arrester's energy of the system due to 95% of negative first stroke lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, with LPS	85
4.12	Observed transient overvoltage and current at different points of the system due to 50% of negative first stroke lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, without LPS	86
4.13	Transient overvoltage, current and arrester's energy of the system due to 50% of negative first stroke lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, with LPS	87
4.14	Observed transient overvoltage and current at different points of the system due to 5% of negative first stroke lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, without LPS	88
4.15	Transient overvoltage, current and arrester's energy of the system due to 5% of negative first stroke lightning current when it strikes at (A) DC side of PV farm, (B) load side, (C) WT side, with LPS	89
4.16	Parallel MOV Surge arrester connection at WT side	95
4.17	Observed transient overvoltage, current and arrester's energy at different points of the system due to (A) 10/350 μ s lightning waveform, (B) 5% of negative first stroke, (C) 5% of positive stroke when striking at WT side with parallel MOV surge arrester connection	97
4.18	Parallel MOV and spark gap SPDs at WT side	98
4.19	Observed transient overvoltage, current and arrester's energy at different points of the system due to (A) 10/350 μ s lightning waveform, (B) 5% of negative first stroke, (C) 5% of positive stroke when striking at WT side with parallel MOV and spark gap arrester connection	100

LIST OF ABBREVIATIONS

AC	Alternating Current
ANSI	American National Standards Association
ATP	Alternative Transient Program
CENELEC	European Commission for Electrotechnical Standardization
CIGRE	International Council on Large Electric Systems
DC	Direct Current
DFIG	Doubly-Fed Induction Generator
DLP	Dynamic Lightning Protection
EMTDC	Electromagnetic Transient Direct Current
EMTP	Electro-Magnetic Transients Program
EPRI	Electric Power Research Institute
ESE	Early Streamer Emitter
FDTD	Finite Difference Time Domain
FEM	Finite Element Method
GB	GigaByte
GDT	Gas Discharge Tubes
GHz	GigaHertz
IEC	International Electrotechnical Commission
IEEE	Institute of Electrical and Electronic Engineers
IGBT	Insulate Gate Bipolar Transistor
ILPA	International Lightning Protection Association
ISO	International Organization for Standards
ITU	International Telecommunications Union
JISC	Japan Industrial Standards Commission

LPS	Lightning Protection System
MCOV	Maximum Continuous Operating Voltage
MOV	Metal Oxide Varistor
MPPT	Maximum Power Point Tracking
NFPA	National Fire Protection Association
P & O	Perturb and Observe
PLL	Phase Locked Loop
PSCAD	Power System Computer Aided Design
PV	Photovoltaic
PWM	Pulse Width Modulation
RAM	Random-Access Memory
RE	Renewable Energy
SAD	Silicon Avalanche Diode
SPD	Surge Protective Device
STC	Standard Test Condition
TV	Television
US	United State
UPS	Uninterruptible Power Supply
VSI	Voltage Source Inverter
WT	Wind Turbine

LIST OF NOTATIONS

$^{\circ}\text{C}$	Celsius
μF	Microfarad
μs	Microsecond
A	Ampere; Turbine Swept Area
C	Capacitor
CO_2	Carbon Dioxide
C_p	Coefficient Performance of the Turbine
d	Length of Arrester Column
E	Energy
EN	European Standard
exp	Exponential
F	Frequency
Hz	Hertz
I	Current
i	Peak Value of Lightning Current
I_0	Maximum Peak Current
I-V	Current-Voltage
J	Joule
kA	Kilo Ampere
kg	Kilogram
K_i	Integral Gain
K_p	Proportional Gain
kV	Kilo Volt
kW	Kilo Watt

L	Inductance
m	Meter
mH	Millihenry
ms	Millisecond
MW	Mega Watt
n	Steepness Factor; Number of Parallel Columns of Metal Oxide Disks
ns	Nanosecond
N-type	Negative Charge of the Electron
Θ	Phase Angle
P	Active Power
PI	Proportional-Integral Controller
P-type	Positive Charge of the Hole
pu	Per Unit
Q	Reactive Power
R	Resistance
r	Wind Turbine Rotor Blade Radius
RLC	Resistor, Inductor, And Capacitor
s	Second
T	Mechanical Torque from Wind Turbine
t	Time
Uc	Maximum Continuous Operating Voltage
Up	Protection Level
V	Voltage
Vmax	Threat Level
Vn	Arrester Rated Voltage

V_r	Residual Voltage
W	Watt
W/R	Energy Dissipation
η	Peak Current Correction Factor
v	Wind Speed
π	Pi
ρ	Air Density
τ_1	Rise Time Constant
τ_2	Decay Time Constant
Ω	Ohm
ω	Rotor Angular Speed in Rad/Sec
β	Blade Pitch Angle

CHAPTER 1

INTRODUCTION

1.1 Background

Grid-connected hybrid systems which are based on renewable energy (RE), such as combined generations of wind turbine (WT) and photovoltaic (PV) power, have become increasingly popular. This popularity is due to the need to address environmental issues, the outlook of depletion of fossil fuel reserves and the world's energy demands (Ghoddami, 2013). The significance of hybrid systems arises from several factors, such as the security of electricity supply to customers, reduced CO₂ emissions by introducing RE sources, liberalisation of the electricity market, increased power availability and reliability, improved power quality, grid support and great long-term potential for the development of sustainable energy (Massoud et al., 2009; Renewables, 2012). They can also overcome the disadvantage of intermittent power output in stand-alone RE source and provide constant power supply. These systems, however, have disadvantages, such as high installation costs compared with those of traditional technologies for power generation (Nehrir et al., 2011). Moreover, they are vulnerable to direct or indirect lightning strokes due to their installation location and their expanded surface in wide-open areas (Christodoulou et al., 2016). Lightning stroke is an impulsive transient variation which is unidirectional in polarity (either negative or positive) generated during a thunderstorm (Berger, 1975). This transient variation is occasionally related to thunder due to electric charges that pass through the lightning channel. The main lightning source is rainstorms which infrequently occur during snowstorms (Sabiha, 2010).

1.2 Problem Statement

Hybrid PV–wind systems are exposed to direct and indirect lightning discharge. The probability of the hybrid systems to be struck by lightning is higher than that of conventional power systems due to the larger layout of PV and wind farm installations contained in the systems. WTs are also tall structures of more than 150 m in height and frequently placed at locations highly exposed to lightning. The International Electrotechnical Commission (IEC) standard for lightning protection recognises four sources of damage due to direct and indirect lightning flashes (Rodrigues et al., 2011; Pons & Tommasini, 2013). The travelling waves resulted from lightning flashes cause a temporary increase in voltage (overvoltage) within the systems. This overvoltage is a transitory phenomenon that plays a harasser roll over insulation of electrical systems and can affect other equipment connected to the hybrid systems, such as PV modules, inverters, batteries, control systems, distribution boards, induction generators, transformers and circuit breakers (Bak et al., 2008; Quintana, 2017).

Such frequent problems may cause a deterioration in the utilisation rate and interruption of power supply and thus increase power generation costs (Rodrigues et al., 2012). Various studies have been conducted on the lightning effects on PV and WT systems either theoretically or experimentally. However, the most of studies have focused on a single type of RE source, and researches on hybrid systems remain few, which more studies need to be conducted on such systems. Therefore, this study aims to fill the gap by analysing lightning-induced transient effects on a grid-connected hybrid PV–wind system, and mitigation of lightning effects is investigated by using PSCAD/EMTDC software. The primary step to reduce the harmful impacts of overvoltage is by determining the background of this phenomenon. The point where lightning current may possibly flow from a system without lightning-protective devices is then identified.

Many lightning protection standards are available for PV and wind systems. However, standards for hybrid systems remain unavailable. In this study, the European Commission for Electrotechnical Standardization (CENELEC) standard, which is available for PV systems, is applied to the hybrid system. The selection of SPDs is according to the said standard. Whether the selected SPDs are appropriate is investigated. In any case, the compliance with national and international standards is significant to ensure the effectiveness of protection measures and thus guarantee the safe operation of the installation and the quality of supplied energy (Pons & Tommasini, 2013). The overvoltage waveforms that appear in various parts of a hybrid electrical system are computed. The possibility of damage depends on the impulse-withstanding voltage of each component. Thus, vital information is provided to enable relevant engineers to select surge protective devices (SPDs) with the most appropriate ratings for a given point according to threat level, and the equipment/component specifications can determine the vulnerability level. The selection of SPDs for a given purpose depends on threat level (V_{max}), component vulnerability, impulse-withstanding voltage, lightning magnitude, rise time, decay time, maximum energy and total released lightning discharge.

1.3 Objectives of the Research

The objectives of this study are as follows:

- 1) To simulate a hybrid PV–wind system for lightning effects analysis performance,
- 2) to investigate the distribution of current and voltage in a hybrid PV–wind system due to direct lightning strikes,
- 3) to examine the levels of mitigation of lightning-related effects on the hybrid PV–wind system with the application of the recommendations given by the standard and determine whether they are appropriate, and
- 4) to propose recommendations for extending the existing lightning protection standards on PV energy source to hybrid systems.

1.4 Scope of the Work

The scope and limitation of this study are as follows:

- 1) The lightning-induced transient effects on a grid-connected hybrid PV–wind system and its mitigation are implemented using PSCAD/EMTDC software. The system consists of a 2 MW PV farm, a 2.1 MW wind farm, a back_{up} battery system and a 300 kW three-phase resistor–inductor–capacitor (RLC) load bank. The temperature and solar irradiation of PV models are fixed at 25 °C and 1000 W/m², respectively. A fixed-speed WT generator is used in the wind farm to convert mechanical power into electrical power at a constant wind speed of 12 m/s.
- 2) The study is conducted for several simulation cases by using standard lightning impulses such as 8/20 μs and 10/350 μs, and also actual direct lightning current waveforms, such as negative first stroke, negative subsequent stroke and positive stroke. The lightning current waveforms are generated using Heidler function, and the transient overvoltage is evaluated at various parts of the system for each of those simulation cases.
- 3) The hybrid system does not include transmission lines; therefore, the corona effect on the lightning channel is not considered.

1.5 Significance of the Research

Lightning and its characteristic is significant to understand because it can only be diverted or intercepted to the path, if well-constructed and designed, which will reduce damage to hybrid PV–wind systems. Every year, lightning flashes cause damage to utility grids, including hybrid systems. Hybrid PV–wind systems comprise expensive components that cost a large amount of money in case of any damage due to lightning, especially in the large-scale power generation. Therefore, lightning protection for hybrid PV–wind systems based on the available standards for PV systems must be studied to design appropriate lightning protection measures for mitigating the transient effects of lightning strikes, considering that no standards are available for hybrid systems. This study helps to secure the operation of hybrid systems and ensure electrical power supply with reduced costs for customers.

1.6 Thesis Layout

This thesis is organised into the following five chapters: Introduction, Literature Review, Methodology, Results and Discussions, and Conclusions and Future Works.

Chapter 1 presents the research background, problem statements, research objectives, scope of work, significance of the research and thesis layout.

Chapter 2 provides the literature review. This chapter contains overviews on lightning, PV system and its different parts and configurations and wind energy. Overviews on global lightning protection codes and standards, previous studies on the lightning effects on PV and WT systems and different SPD types are also discussed.

Chapter 3 explains the research methodology. The model design of a hybrid PV–wind system is implemented using PSCAD/EMTDC software. This chapter includes the modelling of PV farm, battery system, wind farm, load, lightning current and surge arrester. Case studies for simulation are also described.

Chapter 4 discusses the simulation results. Results are generated from the hybrid system at normal steady-state operation condition without lightning current injection. The simulation results of the transient effect across the system without LPS and the system with LPS are given. In addition, this chapter includes the proposed recommendation guidelines to lightning protection developers.

Chapter 5 concludes the study, and future research is suggested to investigate and mitigate the transient effects on the hybrid PV–wind system due to indirect lightning strikes.

REFERENCES

- Ab-Kadir, M. Z. A. (2016). Lightning severity in Malaysia and some parameters of interest for engineering applications. *Thermal Science*, 20(suppl. 2), 437-450.
- Abdalrahman, A., Zekry, A., & Alshazly, A. (2012). Simulation and implementation of grid-connected inverters. *International Journal of Computer Applications*, 60(4).
- Ackermann, T. (2005). *Wind power in power systems*. England, UK: John Wiley & Sons.
- Albadi, M., Al Abri, R., Masoud, M., Al Saidi, K., Al Busaidi, A., Al Lawati, A., . . . Al Farsi, I. (2014). Design of a 50 kW solar PV rooftop system. *International Journal of Smart Grid and Clean Energy*, 3(4), 401-409.
- Association, N. F. P. (2017). NFPA 780: Standard for the Installation of Lightning Protection Systems *Standard for the Installation of Lightning Protection Systems*. Quincy, Massachusetts: National Fire Protection Association (NFPA).
- Babu, B. C., & Mohanty, K. (2010). Doubly-fed induction generator for variable speed wind energy conversion systems-modeling & simulation. *International Journal of Computer and Electrical Engineering*, 2(1), 141.
- Bagherian, H., & Karegar, H. K. (2011). *Over-Voltage and Transient Impedance Study of Wind Turbine Blades Struck by Lightning*. 26th International Power System Conference (PSC), Tehran, Iran.
- Bajpai, P., & Dash, V. (2012). Hybrid renewable energy systems for power generation in stand-alone applications: a review. *Renewable and Sustainable Energy Reviews*, 16(5), 2926-2939.
- Bak, C. L., Einarsdóttir, K. E., Andresson, E., Rasmussen, J. M., Lykkegaard, J., & Wiechowski, W. (2008). Overvoltage protection of large power transformers—A real-life study case. *IEEE Transactions on Power Delivery*, 23(2), 657-666.
- Bayrak, G., & Lebeli, M. (2011). *A PV based automation system for fish farms: An application study*. 7th International Conference on Electrical and Electronics Engineering (ELECO), Bursa, Turkey.
- Belik, M. (2014). *PV panels under lightning conditions*. 15th International Scientific Conference on Electric Power Engineering (EPE), Brno, Czech Republic.
- Berger, K. (1975). Parameters of lightning flashes. *Electra*, 41, 23-37.
- Bouquegneau, C. (2007). A critical view on the lightning protection international standard. *Journal of electrostatics*, 65(5), 395-399.

- Breza, P. (2013). *Modelling and simulation of a PV generator for applications on distributed generation systems*. (Master of Science), Delft University of Technology.
- Charalambous, C. A., Kokkinos, N., Christofides, N., Ab Kadir, M. Z. A., & Gomes, C. (2014). *A simulation tool to assess the lightning induced over-voltages on dc cables of photovoltaic installations*. International Conference on Lightning Protection (ICLP), Shanghai, China.
- Chowdhuri, P., Anderson, J., Chisholm, W., Field, T., Ishii, M., Martinez, J., . . . Mousa, A. (2005). Parameters of lightning strokes: a review. *IEEE Transactions on Power Delivery*, 20(1), 346-358.
- Christodoulou, C. A., Ekonomou, L., Gonos, I. F., & Papanikolaou, N. P. (2016). Lightning protection of PV systems. *Energy Systems*, 7(3), 469-482.
- Christodoulou, C. A., Ekonomou, L., Mitropoulou, A., Vita, V., & Stathopoulos, I. (2010). Surge arresters' circuit models review and their application to a Hellenic 150kV transmission line. *Simulation Modelling Practice and Theory*, 18(6), 836-849.
- Christodoulou, C. A., Vita, V., & Maris, T. I. (2017). Lightning protection of distribution substations by using metal oxide gapless surge arresters connected in parallel. *International Journal of Power and Energy Research*, 1, 1-7.
- CLC. (2013). Low-voltage surge protective devices (pp. 34): European Committee for Electrotechnical Standardization (CENELEC).
- Cohen, R., Dorr, D., Funke, J., Jensen, C., & Waterer, S. F. (2005). IEEE Guide to Surge Protection of Equipment Connected to AC Power and Communication Circuits *How To Protect Your House and Its Contents From Lightning*: IEEE Press/Standards Information Network.
- Cotton, I., Jenkins, N., & Pandiaraj, K. (2001). Lightning protection for wind turbine blades and bearings. *Wind Energy*, 4(1), 23-37.
- Das, J. (2010). *Transients in electrical systems*: McGraw-Hill Professional Publishing.
- Dau, S. (2012). *Modelling of metal oxide surge arresters as elements of overvoltage protection systems*. International Conference on Lightning Protection (ICLP), Vienna, Austria.
- DEHN. (2014). *Lightning Protection Guide*. Neumarkt, Germany: DEHN + SÖHNE.
- Diaz, O., Cooray, V., & Schleimann-Jensen, J. (2010). *Energy dissipation in a new flat low voltage surge protective gas discharge tube*. 30th International Conference on Lightning Protection (ICLP).

- Ehrhardt, A., & Zahlmann, P. (2006). *Information Technology and Electrical Engineering-Devices and Systems, Materials and Technologies for the Future*. 51st International Scientific Colloquium.
- Emam, M. R. (2015). *Modelling of tall-structure lightning return-stroke current using the electromagnetic transients program*. (Doctor of Philosophy), Ryerson University, Toronto, Ontario, Canada.
- Enrique, J., Duran, E., Sidrach-de-Cardona, M., & Andujar, J. (2007). Theoretical assessment of the maximum power point tracking efficiency of photovoltaic facilities with different converter topologies. *Solar Energy*, 81(1), 31-38.
- Fallah, N., Gomes, C., Ab Kadir, M. Z. A., Nourirad, G., & Baojahmadi, M. (2013). *Lightning protection techniques for Roof-Top PV systems*. 7th International Power Engineering and Optimization Conference (PEOCO), Langkawi, Malaysia.
- Gas, P. (2000). Surge Suppressors. Retrieved from https://www.pge.com/includes/docs/pdfs/mybusiness/customerservice/energy/status/powerquality/surge_suppressors.pdf
- Ghoddami, H. (2013). *Enhanced Voltage-Sourced Inverters for Large-Scale Grid-Connected Photovoltaic Systems*. (Doctor of Philosophy), The University of Western Ontario, Ontario, Canada.
- Han, Y., Tang, L., Li, L., He, Q., Hao, Y., & Yao, S. (2015). Influence of lightning flashover criterion on the calculated lightning withstand level of ± 800 kV UHVDC transmission lines at high altitude. *IEEE Transactions on Dielectrics and Electrical Insulation*, 22(1), 185-191.
- He, Z., & Du, Y. (2016). Influence of different factors on coordination of two cascaded SPDs. *Electric Power Systems Research*, 139, 139-145.
- Heidler, F. (1985). *Analytic lightning current functions for LEMP calculations*. 18th International Conference on Lightning Protection (ICLP), VDE Verlag, Berlin, West Germany.
- Heidler, F., Zischank, W., Flisowski, Z., Bouquegneau, C., & Mazzetti, C. (2008). *Parameters of lightning current given in IEC 62305-background, experience and outlook*. 29th International Conference on Lightning Protection, Uppsala, Sweden.
- Hernandez, J. C., Vidal, P. G., & Jurado, F. (2008). Lightning and surge protection in photovoltaic installations. *IEEE Transactions on Power Delivery*, 23(4), 1961-1971.

- Hernandez, Y. M., Ioannidis, D., Ferlas, G., Tsovilis, E. G. T., Politis, Z., & Samaras, K. (2014). *An experimental approach of the transient effects of lightning currents on the overvoltage protection system in MW-class photovoltaic plants*. International Conference on Lightning Protection (ICLP), Shanghai, China.
- Houssamo, I., Locment, F., & Sechilariu, M. (2010). Maximum power tracking for photovoltaic power system: Development and experimental comparison of two algorithms. *Renewable energy*, 35(10), 2381-2387.
- Ittarat, S., Hiranvarodom, S., & Plangklang, B. (2013). A computer program for evaluating the risk of lightning impact and for designing the installation of lightning rod protection for photovoltaic system. *Energy Procedia*, 34, 318-325.
- Jamshidi, A., Ghahderijani, M. M., & Barakati, S. M. (2012). *Power quality improvement in stand-alone microgrid including fixed-speed wind farm: Role of dynamic voltage restorer*. 11th International Conference on Environment and Electrical Engineering (EEEIC), Venice, Italy.
- Jiang, J.-A., Huang, T.-L., Hsiao, Y.-T., & Chen, C.-H. (2005). Maximum power tracking for photovoltaic power systems. *Journal of Taizhou University of Technology*, 8(2), 147-153.
- Jiang, T., & Grzybowski, S. (2013). *Impact of lightning impulse voltage on polycrystalline silicon photovoltaic modules*. International Symposium on Lightning Protection
- Johnson, B. A. (2013). *Modeling and Analysis of a PV Grid-Tied Smart Inverter's Support Functions*. (Master of Science), California State University, San Luis Obispo.
- Kalbat, A. (2013). *PSCAD simulation of grid-tied photovoltaic systems and Total Harmonic Distortion analysis*. 3rd International Conference on Electric Power and Energy Conversion Systems (EPECS), Istanbul, Turkey.
- Kaldellis, J. K. (2010). *Stand-alone and hybrid wind energy systems: technology, energy storage and applications*: Elsevier.
- Khamis, A., Mohamed, A., Shareef, H., & Ayob, A. (2012). Modeling and simulation of small scale microgrid system. *Australian Journal of Basic and Applied Sciences*, 6(9), 412-421.
- Khatib, T., Mohamed, A., & Sopian, K. (2013). A review of photovoltaic systems size optimization techniques. *Renewable and Sustainable Energy Reviews*, 22, 454-465.

- Kheshti, M., Kang, X., & Jiao, Z. (2014). *PSCAD modeling of doubly fed induction generators for wind turbines application*. 12th IET International Conference on Developments in Power System Protection (DPSP), Copenhagen, Denmark.
- Kim, R.-Y., Choi, S.-Y., & Suh, I.-Y. (2004). *Instantaneous control of average power for grid tie inverter using single phase DQ rotating frame with all pass filter*. 30th Annual Conference of IEEE Industrial Electronics Society ECON, Busan, South Korea.
- Kim, S.-K., Jeon, J.-H., Cho, C.-H., Ahn, J.-B., & Kwon, S.-H. (2008). Dynamic modeling and control of a grid-connected hybrid generation system with versatile power transfer. *IEEE Transactions on Industrial Electronics*, 55(4), 1677-1688.
- Kim, S.-K., Jeon, J.-H., Cho, C.-H., Kim, E.-S., & Ahn, J.-B. (2009). Modeling and simulation of a grid-connected PV generation system for electromagnetic transient analysis. *Solar Energy*, 83(5), 664-678.
- Kim, S.-K., & Kim, E.-S. (2007). PSCAD/EMTDC-based modeling and analysis of a gearless variable speed wind turbine. *IEEE Transactions on Energy Conversion*, 22(2), 421-430.
- Kisielewicz, T., Fiamingo, F., Flisowski, Z., Kuca, B., Piparo, G. L., & Mazzetti, C. (2012). *Factors influencing the selection and installation of surge protective devices for low voltage systems*. International Conference on Lightning Protection (ICLP), Vienna, Austria.
- Kithil, R. (2006). *Overview of global lightning protection codes and standards*. International Lightning Detection Conference Tucson, Arizona, USA.
- Kjaer, S. B., Pedersen, J. K., & Blaabjerg, F. (2002). *Power inverter topologies for photovoltaic modules-a review*. 37th IEEE Annual Meeting of Industry Applications Conference (IAS), Pittsburgh, PA, USA.
- Lira, G., Fernandes Jr, D., & Costa, E. (2007). *Computation of energy absorption and residual voltage in metal oxide surge arrester from digital models and lab tests: a comparative study*. International Conference on Power Systems Transients (IPST'07), Lyon, France.
- Luque, A., & Hegedus, S. (2011). *Handbook of photovoltaic science and engineering*: John Wiley & Sons.
- Ma, A. W. (2012). *Modeling and analysis of a photovoltaic system with a distributed energy storage system*. (Master of Science), Faculty of California Polytechnic State University, US, California.

- Manitoba, H. (1994a). Grid-Connected VSC with DC Voltage Control. *PSCAD/EMTDC: Electromagnetic transients program including dc systems*. Retrieved from <https://hvdc.ca/knowledge-base/read,article/256/grid-connected-vsc-with-dc-voltage-control/v>:
- Manitoba, H. (1994b). Battery System A Generic Example. *PSCAD/EMTDC: Electromagnetic transients program including dc systems*. Retrieved from <https://hvdc.ca/knowledge-base/read,article/434/single-phase-battery-system-a-generic-example/v>:
- Mardira, K., & Saha, T. (2002). *A simplified lightning model for metal oxide surge arrester*. Australasian Universities Power Engineering Conference, Melbourne, Australia.
- Martinez-Velasco, J. A. (2017). *Power system transients: parameter determination*: CRC press.
- Massoud, A., Ahmed, K., Finney, S., & Williams, B. (2009). Harmonic distortion-based island detection technique for inverter-based distributed generation. *IET Renewable Power Generation*, 3(4), 493-507.
- Meppelink, J., Drilling, C., Droidener, C., Jordan, E., & Trinkwald, J. (2000). *Lightning arresters with spark gaps—Requirements and future trends of development and application*. International Conference on Lightning Protection, Greece.
- Messenger, R., & Abtahi, A. (2017). *Photovoltaic systems engineering*: CRC press.
- Milan, S. (2005). *Selection of the surge arrester energy absorption capability relating to lightning overvoltages*. International Conference and Exhibition on Electricity Distribution (CIRED).
- Mohammed, Z., Hizam, H., & Gomes, C. (2017). Lightning Strike Impacts on Hybrid Photovoltaic-Wind System. *Indonesian Journal of Electrical Engineering and Computer Science (ijeecs)*, 8(1), 115-121. doi:10.11591.
- Muljadi, E., Singh, M., & Gevorgian, V. (2014). *User guide for PV dynamic model simulation written on PSCAD platform*. Retrieved from Denver West Parkway Golden, CO:
- Nehrir, M., Wang, C., Strunz, K., Aki, H., Ramakumar, R., Bing, J., . . . Salameh, Z. (2011). A review of hybrid renewable/alternative energy systems for electric power generation: Configurations, control, and applications. *IEEE Transactions on Sustainable Energy*, 2(4), 392-403.
- Nema, P., Nema, R., & Rangnekar, S. (2009). A current and future state of art development of hybrid energy system using wind and PV-solar: A review. *Renewable and Sustainable Energy Reviews*, 13(8), 2096-2103.

- Ngampradit, V. (2010). *Discussion on measured impulse sparkover voltage of gas discharge tubes (GDT)*. 30th International Conference on Lightning Protection (ICLP), Cagliari, Italy.
- Pinceti, P., & Giannettoni, M. (1999). A simplified model for zinc oxide surge arresters. *IEEE Transactions on Power Delivery*, 14(2), 393-398.
- Pons, E., & Tommasini, R. (2013). *Lightning protection of PV systems*. 4th International Youth Conference on Energy (IYCE), Siofok, Hungary.
- Quaschnig, V. (2005). *Understanding Renewable Energy Systems*. London: Earthscan Canada: Earthscan.
- Quyen, H. A., & Le, Q. T. (2017). Selection Guide for Low Voltage Surge Protector. *International Journal of Engineering Research & Technology (IJERT)*, 6(10, October - 2017).
- Rachidi, F., Rubinstein, M., Montanya, J., Bermudez, J.-L., Sola, R. R., Sola, G., & Korovkin, N. (2008). A review of current issues in lightning protection of new-generation wind-turbine blades. *IEEE Transactions on Industrial Electronics*, 55(6), 2489-2496.
- Rakov, V. A., & Uman, M. A. (2004). *Lightning: physics and effects*. Cambridge, UK: Wiley Online Library.
- Renewables, R. (2012). *Global status report*. Retrieved from http://www.ren21.net/Portals/0/documents/Resources/GSR2012_low%20res_FINAL.pdf
- Rodrigues, R. B., Mendes, V. M., & Catalão, J. P. (2012). Analysis of transient phenomena due to a direct lightning strike on a wind energy system. *Energies*, 5(7), 2545-2558.
- Rodrigues, R. B., Mendes, V. M. F., & Catalão, J. P. d. S. (2011). Protection of wind energy systems against the indirect effects of lightning. *Renewable energy*, 36(11), 2888-2896.
- Sabiha, N. A. (2010). *Lightning-induced overvoltages in medium voltage distribution systems and customer experienced voltage spikes*. (Doctor of Science in Technology), Aalto University School of Science and Technology, Espoo, Finland. Retrieved from <http://lib.tkk.fi/Diss/2010/isbn9789526030463/>
- Saleh, M. S., El-Betar, A., & El-Assal, A. (2014). Review of modeling and simulation technologies application to wind turbines drive train. *Journal on Today's Ideas –Tomorrow's Technologies (jotitt)*, 2, No. 2, 117–131.
- Saraf, P. (2012). *Fault analysis of an unbalanced distribution system with distributed generation*. (Degree Master of Science), Clemson University.

- Sciutto, D., & Rizzo, D. (2002). *New approach on raw-land base transmission system overvoltage protection*. International Conference on Lightning Protection, Cracow, Poland.
- Shih, T.-C. Y. C.-F., Chen, C. B. G. C.-H., & Liou, Y.-C. (2014). A Study of the Dynamic Characteristics for the Wind Power Generation System. *Journal of Longhua University of Science and Technology*.
- Sick, F., & Erge, T. (1996). *Photovoltaics in buildings: a design handbook for architects and engineers*: Earthscan.
- Singh, M., & Santoso, S. (2011). *Dynamic models for wind turbines and wind power plants*. Retrieved from Austin, Texas:
- Skolthanarat, S. (2009). *The Modeling and Control of a Wind Farm and Grid Interconnection in a multi-machine system*. (Doctor of Philosophy), Virginia Polytechnic Institute and State University, Virginia, USA.
- Skuletic, S., & Radulovic, V. (2008). *Effective protection distance from cascade coordinated surge protective devices to equipment in low-voltage AC power circuits*. 43rd International Universities Power Engineering Conference UPEC, Padova, Italy.
- Standard, I. (2006a). 1: General principles *Protection Against Lightning-Part-1*, (pp. 69). Italy: International Electrotechnical Commission, IEC.
- Standard, I. (2006b). 2: Risk management *Protection Against Lightning-Part-2*, (pp. 112). Italy: International Electrotechnical Commission, IEC.
- Standard, I. (2006c). 62305 (Parts 1-4) *Protection Against Lightning*, . Italy: International Electrotechnical Commission, IEC.
- Stuckenholtz, C.-H., & Gamlin, M. (2012). *Overview of impulse current test standards and the impact on test equipment*. International Conference on Lightning Protection (ICLP), Vienna, Austria.
- Sumathi, S., Ashok Kumar, L., & Surekha, P. (2015). *Solar PV and Wind Energy Conversion Systems*. Switzerland: Springer.
- Syahirah, A. H. (2016). *Design and evaluation of metal oxide surge arrester parameters for lightning over voltages*. (Doctor of Philosophy), University of Malaya.
- Tahir, S., Wang, J., Baloch, M. H., & Kaloi, G. S. (2018). Digital control techniques based on voltage source inverters in renewable energy applications: A Review. *Electronics*, 7(2), 18.

- Terespolsky, B. R., & Nixon, K. J. (2014). *Developing an approximation to the Heidler Function-with an analytical transformation into the frequency domain*. International Conference on Lightning Protection (ICLP), Shanghai, China.
- Tomar, V., & Tiwari, G. (2017). Techno-economic evaluation of grid connected PV system for households with feed in tariff and time of day tariff regulation in New Delhi–A sustainable approach. *Renewable and Sustainable Energy Reviews*, 70, 822-835.
- Tong, C., Wang, Q., Gao, Y., Tong, M., & Luo, J. (2014). Dynamic lightning protection of smart grid distribution system. *Electric Power Systems Research*, 113, 228-236.
- Tremblay, O., Dessaint, L.-A., & Dekkiche, A.-I. (2007). *A generic battery model for the dynamic simulation of hybrid electric vehicles*. Vehicle Power and Propulsion Conference (VPPC 2007), Arlington, TX, USA.
- Tu, Y., Zhang, C., Hu, J., Wang, S., Sun, W., & Li, H. (2013). Research on lightning overvoltages of solar arrays in a rooftop photovoltaic power system. *Electric Power Systems Research*, 94, 10-15.
- Uma, U. U., & Laz, U. (2014). Computer-Based Model for Design Selection of Lightning Arrester for 132/33kV Substation. *IOSR Journal of Engineering (IOSRJEN)*, 04, 5446.
- Vangala, P., Ropp, M., Haggerty, K., Lynn, K., & Wilson, W. (2008). *Field measurements of lightning-induced voltage transients in PV arrays*. Photovoltaic Specialists Conference (PVSC), San Diego, CA, USA.
- Vyas, M., Singh, M., & Santoso, S. (2013). Grid Integration of Wind Power Systems: Modeling of Wind Power Plants *Handbook of Wind Power Systems* (pp. 153-209): Springer.
- WAGO. (2018). Transient Surges and Surge Suppressor Technologies: Comparing Apples to Oranges. Retrieved from https://www.controlglobal.com/assets/Media/MediaManager/wp_080107_WAGO_transient.pdf.
- Walaszczyk, B., Tidey, D., & Bellew, P. (2001). *Does size really matter? – an exploration of the utilization of a single higher energy rated MOV VS. Paralleling multiple lower energy MOVs*. Power Systems World, Rosemont, IL.
- Woodworth, J., & Limburg, D. (2017, 2/5/2018). Arrester V-I Characteristics Tool. Retrieved from http://www.arresterworks.com/arresterfacts/Arresterfacts_Arrester_Modeling.php.

- Quintana, G. A. (2017). Evaluation of metal oxide surge arrester models based on laboratory experiments. *International Journal of Mechanical And Production Engineering (IJMPE)*, 5(1), 32-37.
- Yasuda, Y., Uno, N., Kobayashi, H., & Funabashi, T. (2008). Surge analysis on wind farm when winter lightning strikes. *IEEE Transactions on Energy Conversion*, 23(1), 257-262.
- Yokoyama, S. (2013). Lightning protection of wind turbine blades. *Electric Power Systems Research*, 94, 3-9.
- Yonezawa, K., Mochizuki, S., Takahashi, Y., Idogawa, T., & Morii, N. (2014). *Evaluation of SPDs for a PV system using the FDTD method taking concrete foundations into consideration*. International Conference on Lightning Protection (ICLP), Shanghai, China.
- Yu, Z., Yu, J., Rong, Z., Wang, X., & Sun, W. (2014). *Arc characteristics of parallel gap for composite insulator*. International Conference on Lightning Protection (ICLP), Shanghai, China.
- Zaini, N., Ab-Kadir, M., Izadi, M., Ahmad, N., Radzi, M. M., Azis, N., & Hasan, W. W. (2016). *On the effect of lightning on a solar photovoltaic system*. 33rd International Conference on Lightning Protection (ICLP), Estoril, Portugal.
- Zhang, N., Tang, H., & Yao, C. (2014). A systematic method for designing a PR controller and active damping of the LCL filter for single-phase grid-connected PV inverters. *Energies*, 7(6), 3934-3954.
- Zhang, W., Remon, D., Cantarellas, A. M., & Rodriguez, P. (2016). A unified current loop tuning approach for grid-connected photovoltaic inverters. *Energies*, 9(9), 723.